

Monitoring Report #2009-1
For the Greater New Bedford LFG Utilization Project
Dartmouth, Massachusetts
For Verification Period January 1, 2009 through June 30, 2009

Date of Report: July 20, 2009

CommonWealth

Resource Management Corporation

July 20, 2009

Greg Kozak
Senior Environmental Engineer
First Environment, Inc.
Chicago Civic Opera Building
20 N. Wacker Dr., Suite 1545

Re: Greater New Bedford LFG Utilization Project Emissions Reductions Verification
Verification Processes: Voluntary Carbon Standard
For the Periods: July 1, 2008 through December 31, 2008, and
January 1, 2009 through June 30, 2009

Dear Greg,

On behalf of our subsidiary CommonWealth New Bedford Energy LLC, we are hereby submitting for your review the information required to perform a Verification of documented methane emissions reductions achieved from July 1, 2008 through December 31, 2008 and January 1, 2009 through June 30, 2009 (the GHG Reductions or Emission Reductions) at the Greater New Bedford LFG Utilization Project (the Project) in Dartmouth, Massachusetts.

Please perform the Verification and prepare a Verification Report required for verification process under the Voluntary Carbon Standard. Specifically, we are asking you to Verify our documented claims that the emission reductions generated by the Project during second half of 2008, previously verified by First Environment under other protocols, are equivalent to 56,952 metric tons of Voluntary Carbon Units (VCUs) in accordance with verification protocol under the Voluntary Carbon Standard. We are also asking you to Verify our documented claims that emission reductions generated by the Project during the first half of 2009 are equivalent to 56,481 VCUs.

In support of claims, attached for your review are the following:


1. Exhibit 1 summarizes the emission reductions from methane oxidation during energy generation and flaring from July 1, 2008 through December 31, 2008 and January 1, 2009 through June 30, 2009.
2. Exhibit 2 provides LFG totalizer readings, and methane content readings for the periods from July 1, 2008 through December 31, 2008 and January 1, 2009

through June 30, 2009, and calculations using the verification protocols under the VCS to obtain emission reductions from methane oxidation during energy generation.

3. Exhibit 3 provides LFG totalizer readings, and methane content readings for the periods from July 1, 2008 through December 31, 2008 and January 1, 2009 through June 30, 2009, and calculations using the verification protocols under the VCS to obtain emission reductions from methane oxidation during flaring.
4. Exhibit 4 provides the key factors, equations, and calculation of VCUs in accordance with the approved consolidated baseline methodology ACM0001/Version 09.1 "Consolidated baseline and monitoring methodology for the landfill gas project activities" promulgated by the United Nations Framework Convention of Climate Change (UNFCCC) under the Clean Development Mechanism (CDM).
5. Exhibit 5 is a compilation of the field data logs recording the total landfill gas volumes and methane content readings for the identified reporting periods.
6. Exhibit 6 documents the calibration of the LFG flow rate and provides a compilation of methane content calibration reports for the California Analytical Analyzer for the periods.
7. Exhibit 7 provides hourly data for the months of March 2009 and June 2009 as representative of the data reported from the SCADA system for the first half of 2009. Note that this hourly data report format was initiated during January 2009. Previously, hourly data that covers the second half of 2008 was in the form of continuous chart data as previously submitted to you and reviewed by First Environment to support a verification report for another standard. This same data is being resubmitted to you by email in a compressed folder titled "CNBE Screen Shots Hourly data Jly - Dec 08".

Please call me with any questions at 508-339-3074. Thank you.

Sincerely,

A handwritten signature in black ink, appearing to read "Thomas Yeransian", with a stylized, flowing script and a long horizontal line extending from the end.

Thomas Yeransian
Principal

EXHIBIT 1				
CommonWealth New Bedford Energy LLC				
Greater New Bedford LFG Utilization Project				
Dartmouth, Massachusetts				
Calculation of Verified Emission Reduction Credits in CO2 equivalent tons in accordance with the Project Methodology				
Key parameters used in calculations				
Parameter		VCS	VCS	
Methane oxidation efficiency electricity generation		100.0%	100.0%	
Methane oxidation efficiency LFG flaring		50.0%	50.0%	
Methane, molecular weight		16	16	
Pounds per metric ton		2,205	2,205	
Gas constant (scf per lb-mole)		385	385	
Global Warming Potential (GWP) methane		21	21	
Summary results				
	Unit			
Electricity generation				
Start date		1-Jul-08	1-Jan-09	
End date		31-Dec-08	30-Jun-09	
Methane delivered	scf	162,373,183	316,474,489	
Emission Reductions	metric tons CO2e	64,266	60,992	
Flaring				
Start date		1-Jul-08	1-Jan-09	
End date		31-Dec-08	30-Jun-09	
Methane delivered	scf	-	9,545,112	
Emission Reductions	metric tons CO2e	-	1,889	
Subtotal				
Methane delivered	scf	162,373,183	326,019,601	
Emission Reductions	metric tons CO2e	64,266	62,881	
District Initial System				
Methane delivered	scf	18,480,113	16,170,099	
Emission Reductions	metric tons CO2e	7,314	6,400	
Total				
Emission Reductions eligible under VCS program	metric tons CO2e	56,952	56,481	

EXHIBIT 2														
CommonWealth New Bedford Energy LLC														
Emission Reductions from methane oxidation during energy generation														
Physical constants:														
Methane, molecular weight (lb per lb-mole)				16					Calculation of Verified Emission Reduction in CO2 equivalent tons per the following:					
Pounds to metric ton				2,205					Verification Process: UNFCCC's CDM methodology ACM0001 (Version 9.1)					
Gas constant, scf per lb-mole				385					Standard of Verification: Voluntary Carbon Standard 2007.1					
Begin period - date	End period - date	Totalizer reading end period	Totalizer reading start period	Total in period	Methane delivered to engines	Methane delivered cumulative	Methane delivered in the period	Methane delivered in the period	Methane oxidation efficiency	MD electricity, Mass methane destroyed in the period	MD electricity, Mass methane destroyed cumulative	Global warming potential methane	Emission reduction	Emission reduction cumulative
mm/dd/yy	mm/dd/yy	MMBtu HHV	MMBtu HHV	MMBtu HHV	scf	scf	metric tons	metric tons	%	metric tons	metric tons	tons CO2 equivalent per ton methane	CO2 equivalent metric tons	CO2 equivalent metric tons
1-Jul-08														
1-Jul-08	31-Jul-08	25,207	-	25,207	24,908,133	24,908,133	469	469	100.0%	469	469	21	9859	9,859
1-Aug-08	31-Aug-08	50,620	25,207	25,413	25,112,031	50,020,164	473	943	100.0%	473	943	21	9939	19,798
1-Sep-08	30-Sep-08	76,879	50,620	26,258	25,946,741	75,966,905	489	1,432	100.0%	489	1,432	21	10270	30,067
1-Oct-08	31-Oct-08	106,175	76,879	29,296	28,948,888	104,915,793	546	1,977	100.0%	546	1,977	21	11458	41,525
1-Nov-08	30-Nov-08	135,337	106,175	29,162	28,816,648	133,732,440	543	2,521	100.0%	543	2,521	21	11405	52,931
1-Dec-08	31-Dec-08	164,322	135,337	28,984	28,640,742	162,373,183	540	3,060	100.0%	540	3,060	21	11336	64,266
1-Jan-09														
1-Jan-09	31-Jan-09	24,475	-	24,475	24,184,783	186,557,965	456	456	100.0%	456	3,516	21	9,572	9,572
1-Feb-09	28-Feb-09	50,010	24,475	25,535	25,232,213	211,790,179	476	931	100.0%	476	3,992	21	9,987	19,559
1-Mar-09	31-Mar-09	78,789	50,010	28,779	28,437,747	240,227,926	536	1,467	100.0%	536	4,528	21	11,256	30,814
1-Apr-09	30-Apr-09	102,146	78,789	23,357	23,079,567	263,307,493	435	1,902	100.0%	435	4,963	21	9,135	39,949
1-May-09	31-May-09	127,896	102,146	25,750	25,444,664	288,752,157	480	2,382	100.0%	480	5,442	21	10,071	50,020
1-Jun-09	30-Jun-09	155,951	127,896	28,055	27,722,332	316,474,489	522	2,904	100.0%	522	5,965	21	10,972	60,992

EXHIBIT 3																
CommonWealth New Bedford Energy LLC																
Calculation of Verified Emission Reduction in CO2 equivalent tons per the Project Methodology																
Emission Reductions from methane oxidation from LFG flaring																
Physical constants:																
Methane, molecular weight (lb per lb-mole)				16												
Pounds to metric ton				2,205												
Gas constant, scf per lb-mole				385												
Calculation of Verified Emission Reduction in CO2 equivalent tons per the following																
Verification Process: UNFCCC's CDM methodology ACM0001 (Version 9.1)																
Standard of Verification: Voluntary Carbon Standard 2007.1																
Begin period - date	End period - date	Totalizer reading end period	Totalizer reading start period	Total in period	Methane delivered to flare	Methane delivered cumulative	Methane delivered in the period	Methane delivered cumulative	Methane oxidation efficiency	MD flare, Mass methane destroyed in the period	MD flare, Mass methane destroyed cumulative	Global warming potential methane	Emission reduction	Emission reduction cumulative	PE flare, Project emissions (uncontrolled emissions to atmosphere from flare)	PE flare, Project emissions cumulative (uncontrolled emissions to atmosphere from flare)
mm/dd/yy	mm/dd/yy	MMBtu HHV	MMBtu HHV	MMBtu HHV	scf	scf	metric tons	metric tons	%	metric tons	metric tons	tons CO2 equivalent per ton methane	CO2 equivalent metric tons	CO2 equivalent metric tons	CO2 equivalent metric tons	CO2 equivalent metric tons
1-Jul-08																
1-Jul-08	31-Jul-08	-	-	-	-	-			50%	-	-	21	-	-	-	-
1-Aug-08	31-Aug-08	-	-	-	-	-			50%	-	-	21	-	-	-	-
1-Sep-08	30-Sep-08	-	-	-	-	-			50%	-	-	21	-	-	-	-
1-Oct-08	31-Oct-08	-	-	-	-	-			50%	-	-	21	-	-	-	-
1-Nov-08	30-Nov-08	-	-	-	-	-			50%	-	-	21	-	-	-	-
1-Dec-08	31-Dec-08	-	-	-	-	-			50%	-	-	21	-	-	-	-
1-Jan-09																
1-Jan-09	31-Jan-09	2,520	-	2,520	2,490,016	2,490,016	47	47	50%	23	23	21	493	493	493	493
1-Feb-09	28-Feb-09	2,520	2,520	-	-	2,490,016	0	47	50%	-	23	21	-	493	-	493
1-Mar-09	31-Mar-09	2,520	2,520	-	-	2,490,016	0	47	50%	-	23	21	-	493	-	493
1-Apr-09	30-Apr-09	6,815	2,520	4,295	4,243,974	6,733,990	80	127	50%	40	63	21	840	1,333	840	1,333
1-May-09	31-May-09	9,660	6,815	2,845	2,811,123	9,545,112	53	180	50%	26	90	21	556	1,889	556	1,889
1-Jun-09	30-Jun-09	9,660	9,660	-	-	9,545,112	0	180	50%	-	90	21	-	1,889	-	1,889

EXHIBIT 4

Emission Reductions from the Greater New Bedford LFG Utilization Project using ACM0001 (Version 9.1) under the VCS Program

Key factors to determine baseline and emission reductions (1):								
Methane oxidation efficiency for electric generation:								100%
Methane oxidation efficiency for flare:								50%
GWP methane, Global warming potential for methane:								21
Quantity methane collected and controlled to make electricity								100%
Quantity methane collected and controlled by flare								0%
EL lfg	Indirect electricity required by baseline activity							0
ET lfg	Indirect thermal energy required by baseline activity							0
PE	Project emissions, which are indirect emissions from Project Activity							0
MD project	Methane destroyed by Project Activity							See below
MD bl	Methane destroyed in the District Initial System.							See below
MD flared	Methane destroyed by flaring = methane delivered to flare - methane emitted to atmosphere							See below
MD electricity	Methane destroyed by generation of electricity							See below
BE	Baseline emissions = (MD project-MD bl) * GWP methane + indirect emissions of baseline activity							See below
ER	Emission reductions, which is equal to BE - PE							See below

	Methane collected and delivered to engines and flare, methane metric tons	MD electricity, methane metric tons	MD flared, methane metric tons	MD project, methane metric tons	MD bl (2), methane metric tons	(MD project MD bl) methane metric tons	BE, CO2e metric tons	ER, CO2e metric tons
Year								
2nd Half 2008	3,060	3,060	-	3,060	348	2,712	56,952	56,952
1st Half 2009	2,904	2,904	90	2,994	305	2,690	56,481	56,481

(1) Key factors and equations are from UNFCCC CDM document ACM0001/Version 09.1.

(2) Calculation of MD bl in accordance with validation report shown below.

Year	Methane delivered to flare from District Initial System, metric tons	MD bl, Methane destroyed in the District Initial System, metric tons						
2001	3,548	1,774						
2002	3,104	1,552						
2003	2,716	1,358						
2004	2,377	1,188						
2005	2,080	1,040						
2006	1,820	910						
2007	1,592	796						
2008	1,393	697						
2009	1,219	610						
2010	1,067	533						
2011	933	467						
2012	817	408						
2013	715	357						
2014	625	313						
2015	547	274						
2016	479	239						
Annual rate of decline =	0.125							

EXHIBIT 5

Compilation of the field data logs recording the total landfill gas volumes and methane content readings for the identified reporting periods

FIRST HALF 2009

Compilation of the field data logs recording the total landfill gas volumes and methane content readings for the identified reporting periods

JANUARY 2009																		
CNBE Daily Reports Summary Data																		
	Thursday 1/1/2009	Friday 1/2/2009	Saturday 1/3/2009	Sunday 1/4/2009	Monday 1/5/2009	Tuesday 1/6/2009	Wednesday 1/7/2009	Thursday 1/8/2009	Friday 1/9/2009	Saturday 1/10/2009	Sunday 1/11/2009	Monday 1/12/2009	Tuesday 1/13/2009	Wednesday 1/14/2009	Thursday 1/15/2009	Friday 1/16/2009	Saturday 1/17/2009	
Landfill Gas Flow to the Engines (KSCF)	1,617	1,655	1,655	1,655	1,655	1,617	1,488	1,588	1,679	1,462	1,677	1,654	1,632	822	1,191	1,161	1,158	
Landfill Gas Flow to the Engines (MMBTU HHV)	924	929	929	929	929	924	872	921	943	800	938	887	908	475	700	674	665	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	281	446	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	144	230	
Landfill Gas Total Flow (KSCF)	1,617	1,655	1,655	1,655	1,655	1,617	1,488	1,588	1,679	1,462	1,677	1,654	1,632	822	1,191	1,442	1,604	
Landfill Gas Total Flow (MMBTU HHV)	924	929	929	929	929	924	872	921	943	800	938	887	908	475	700	818	895	
Average Methane Content (%)	56.5	55.5	55.5	55.5	55.5	56.5	57.9	57.3	55.5	54.1	55.3	53.0	55.0	57.1	58.1	56.1	55.1	
Engine 1 Hours	24	24	24	24	24	24	23	22	24	21	24	24	24	14	24	24	24	
Engine 2 Hours	24	24	24	24	24	24	22	24	24	17	24	24	24	14	24	24	24	
Engine 3 Hours	24	24	24	24	24	24	23	23	24	24	24	22	24	14	24	24	23	
Engine 4 Hours	24	24	24	24	24	24	23	24	24	21	24	24	24	11	24	-	-	
Generator 1 Power Output (kWhr)	19,375	19,578	19,578	19,578	19,578	19,375	16,493	16,513	17,538	16,175	19,179	19,074	18,976	11,062	19,871	19,855	19,605	
Generator 2 Power Output (kWhr)	16,341	18,061	18,061	18,061	18,061	16,341	14,336	17,696	18,244	11,963	16,693	17,594	18,464	9,094	19,404	18,123	18,233	
Generator 3 Power Output (kWhr)	18,796	17,067	17,067	17,067	17,067	18,796	17,180	17,472	17,796	18,358	19,335	16,931	17,483	10,788	19,687	19,776	18,304	
Generator 4 Power Output (kWhr)	18,673	18,762	18,762	18,762	18,762	18,673	16,536	18,060	18,491	16,076	18,873	18,489	18,283	2,221	-	-	-	
Gross Power Output (kWhr)	73,844	73,561	73,561	73,561	73,561	73,844	64,958	69,764	72,113	62,755	74,524	72,569	73,806	33,592	59,425	58,187	56,575	
Net Power Output (kWhr)	72,646	72,288	72,288	72,288	72,288	72,646	63,734	68,540	70,919	61,642	73,302	71,417	72,718	32,922	58,590	57,333	55,686	
Power Sold as metered by NStar, (kWhr)	72,418	71,598	72,103	72,112	72,132	72,776	65,112	69,644	72,184	62,215	73,208	71,969	73,219	32,979	58,837	57,579	55,684	
Offgrid RECs (kWhr)	1,198	1,273	1,273	1,273	1,273	1,198	1,224	1,224	1,194	1,113	1,222	1,152	1,088	670	835	854	889	
Calculated Performance Results																		
Daily																		
Power output (kW average when running)																		
Generator 1	807	816	816	816	816	807	717	751	731	770	799	795	791	790	828	827	817	
Generator 2	681	753	753	753	753	681	652	737	760	704	696	733	769	650	809	755	760	
Generator 3	783	711	711	711	711	783	747	760	742	765	806	770	728	771	820	824	796	
Generator 4	778	782	782	782	782	778	719	753	770	766	786	770	762	202	-	-	-	
Power output (kW average over 24-hrs)																		
Facility Gross	3,077	3,065	3,065	3,065	3,065	3,077	2,707	2,907	3,005	2,615	3,105	3,024	3,075	1,400	2,476	2,424	2,357	
Facility Net	3,027	3,012	3,012	3,012	3,012	3,027	2,656	2,856	2,955	2,568	3,054	2,976	3,030	1,372	2,441	2,389	2,320	
In-plant load	50	53	53	53	53	50	51	51	50	46	51	48	45	28	35	36	37	
Daily availability factor																		
Facility	100%	100%	100%	100%	100%	100%	95%	97%	100%	86%	100%	98%	100%	55%	75%	75%	74%	
Engine 1	100%	100%	100%	100%	100%	100%	96%	92%	100%	88%	100%	100%	100%	58%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	92%	100%	100%	71%	100%	100%	100%	58%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	96%	96%	100%	100%	100%	79%	100%	58%	100%	100%	96%	
Engine 4	100%	100%	100%	100%	100%	100%	96%	100%	100%	88%	100%	100%	100%	46%	0%	0%	0%	
Daily capacity factor																		
Facility	93%	93%	93%	93%	93%	93%	82%	88%	91%	79%	94%	92%	93%	42%	75%	73%	71%	
Engine 1	98%	99%	99%	99%	99%	98%	87%	91%	89%	93%	97%	96%	96%	100%	100%	99%	99%	
Engine 2	83%	91%	91%	91%	91%	83%	79%	89%	92%	85%	84%	89%	93%	79%	98%	92%	92%	
Engine 3	95%	86%	86%	86%	86%	95%	91%	92%	90%	93%	98%	93%	88%	93%	99%	100%	96%	
Engine 4	94%	95%	95%	95%	95%	94%	87%	91%	93%	93%	95%	93%	92%	24%	0%	0%	0%	
Cumulative by engine																		
Engine operating run hours in the month																		
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	408	
Engine 1	24	48	72	96	120	144	167	189	213	234	258	282	306	320	344	368	392	
Engine 2	24	48	72	96	120	144	166	190	214	231	255	279	303	317	341	365	389	
Engine 3	24	48	72	96	120	144	167	190	214	238	262	284	308	322	346	370	393	
Engine 4	24	48	72	96	120	144	167	191	215	236	260	284	308	319	319	319	319	
Engine operating run hours total from 0 hours																		
Engine 1	26,820	26,844	26,868	26,892	26,916	26,940	26,963	26,985	27,009	27,030	27,054	27,078	27,102	27,116	27,140	27,164	27,188	
Engine 2	26,691	26,715	26,739	26,763	26,787	26,811	26,833	26,857	26,881	26,898	26,922	26,946	26,970	26,984	27,008	27,032	27,056	
Engine 3	26,307	26,331	26,355	26,379	26,403	26,427	26,450	26,473	26,497	26,521	26,545	26,567	26,591	26,605	26,629	26,653	26,676	
Engine 4	26,558	26,582	26,606	26,630	26,654	26,678	26,701	26,725	26,749	26,770	26,794	26,818	26,842	26,853	26,853	26,853	26,853	
Cumulative availability, %																		
Engine 1	100%	100%	100%	100%	100%	100%	99%	98%	99%	98%	98%	98%	98%	95%	96%	96%	96%	
Engine 2	100%	100%	100%	100%	100%	100%	99%	99%	99%	96%	97%	97%	97%	94%	95%	95%	95%	
Engine 3	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	99%	96%	96%	96%	96%	
Engine 4	100%	100%	100%	100%	100%	100%	99%	99%	100%	98%	98%	99%	99%	95%	89%	83%	78%	
Engine cumulative gross output, kWhr																		
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200	14,025	
Engine 1	807	1,623	2,439	3,255	4,070	4,878	5,595	6,345	7,076	7,846	8,645	9,440	10,231	11,021	11,849	12,676	13,493	
Engine 2	681	1,433	2,186	2,939	3,691	4,372	5,024	5,761	6,521	7,225	7,920	8,653	9,423	10,072	10,881	11,636	12,396	
Engine 3	783	1,494	2,205	2,917	3,628	4,411	5,158	5,917	6,659	7,424	8,229	8,999	9,728	10,498	11,318	12,142	12,938	
Engine 4	778	1,560	2,342	3,123	3,905	4,683	5,402	6,155	6,925	7,691	8,477	9,247	10,009	10,211	10,211	10,211	10,211	
Cumulative capacity factor, %																		
Engine 1	98%	98%	99%	99%	99%	99%	97%	96%	95%	95%	95%	95%	95%	95%	96%	96%	96%	
Engine 2	83%	87%	88%	88%	88%	88%	87%	87%	88%	88%	87%	87%	88%	87%	88%	88%	88%	
Engine 3	95%	91%	89%	88%	88%	88%	89%	90%	90%	91%	91%	91%	91%	91%	91%	92%	92%	
Engine 4	94%	95%	95%	95%	95%	95%	94%	93%	93%	93%	93%	93%	93%	88%	83%	77%	73%	

	Thursday 1/1/2009	Friday 1/2/2009	Saturday 1/3/2009	Sunday 1/4/2009	Monday 1/5/2009	Tuesday 1/6/2009	Wednesday 1/7/2009	Thursday 1/8/2009	Friday 1/9/2009	Saturday 1/10/2009	Sunday 1/11/2009	Monday 1/12/2009	Tuesday 1/13/2009	Wednesday 1/14/2009	Thursday 1/15/2009	Friday 1/16/2009	Saturday 1/17/2009
Cumulative by Facility in month																	
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536	1,632
Actual cumulative engine run hours	96	192	288	384	480	576	667	760	856	939	1,035	1,129	1,225	1,278	1,350	1,422	1,493
Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	99.3%	99.0%	99.1%	97.8%	98.0%	98.0%	98.2%	95.1%	93.8%	92.6%	91.5%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200	1,346,400
Actual cumulative gross output, kWhr	73,844	147,405	220,966	294,527	368,088	441,932	506,890	576,654	648,767	711,522	786,046	858,615	932,421	966,013	1,025,438	1,083,625	1,140,200
Cumulative Capacity Factor	93.2%	93.1%	93.0%	93.0%	93.0%	93.0%	91.4%	91.0%	91.0%	89.8%	90.2%	90.3%	90.6%	87.1%	86.3%	85.5%	84.7%
Cumulative fuel input, MMBtu HHV	924	1,853	2,782	3,711	4,640	5,564	6,436	7,357	8,300	9,100	10,038	10,925	11,833	12,308	13,008	13,682	14,347
Cumulative gross output, kWhr	73,844	147,405	220,966	294,527	368,088	441,932	506,890	576,654	648,767	711,522	786,046	858,615	932,421	966,013	1,025,438	1,083,625	1,140,200
Heat Rate																	
Daily heat rate, Btu/kWe gross LHV	11,264	11,369	11,369	11,369	11,369	11,264	12,084	11,884	11,772	11,476	11,330	11,003	11,075	12,729	10,604	10,427	10,581
Daily heat rate, Btu/kWe gross HHV	12,513	12,629	12,629	12,629	12,629	12,513	13,424	13,202	13,077	12,748	12,587	12,223	12,303	14,140	11,780	11,583	11,754
Cumulative heat rate, Btu/kWe gross LHV	11,264	11,316	11,334	11,342	11,348	11,334	11,430	11,485	11,517	11,513	11,496	11,454	11,424	11,469	11,419	11,366	11,327
Cumulative heat rate, Btu/kWe gross HHV	12,513	12,571	12,590	12,600	12,606	12,590	12,697	12,758	12,793	12,789	12,770	12,724	12,691	12,741	12,685	12,626	12,583
Cumulative by Facility starting Calendar Year																	
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536	1,632
Actual cumulative engine run hours	96	192	288	384	480	576	667	760	856	939	1,035	1,129	1,225	1,278	1,350	1,422	1,493
Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	99.3%	99.0%	99.1%	97.8%	98.0%	98.0%	98.2%	95.1%	93.8%	92.6%	91.5%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200	1,346,400
Actual cumulative gross output, kWhr	73,844	147,405	220,966	294,527	368,088	441,932	506,890	576,654	648,767	711,522	786,046	858,615	932,421	966,013	1,025,438	1,083,625	1,140,200
Cumulative Capacity Factor	93.2%	93.1%	93.0%	93.0%	93.0%	93.0%	91.4%	91.0%	91.0%	89.8%	90.2%	90.3%	90.6%	87.1%	86.3%	85.5%	84.7%
Cumulative fuel input, MMBtu HHV	924	1,853	2,782	3,711	4,640	5,564	6,436	7,357	8,300	9,100	10,038	10,925	11,833	12,308	13,008	13,682	14,347
Cumulative gross output, kWhr	73,844	147,405	220,966	294,527	368,088	441,932	506,890	576,654	648,767	711,522	786,046	858,615	932,421	966,013	1,025,438	1,083,625	1,140,200
Cumulative heat rate, Btu/kWe gross LHV	11,264	11,316	11,334	11,342	11,348	11,334	11,430	11,485	11,517	11,513	11,496	11,454	11,424	11,469	11,419	11,366	11,327
Cumulative heat rate, Btu/kWe gross HHV	12,513	12,571	12,590	12,600	12,606	12,590	12,697	12,758	12,793	12,789	12,770	12,724	12,691	12,741	12,685	12,626	12,583
Service																	
Engine 1														NStar Trip			
Engine 2														Loss of radio.			
Engine 3																	
Engine 4														E4 fail to restart			
Oil - oil and filter change																	
Service - plugs, air filter, valve inspection and adjustment																	
NSTAR Power Reports																	
Date	Thursday 1/1/2009	Friday 1/2/2009	Saturday 1/3/2009	Sunday 1/4/2009	Monday 1/5/2009	Tuesday 1/6/2009	Wednesday 1/7/2009	Thursday 1/8/2009	Friday 1/9/2009	Saturday 1/10/2009	Sunday 1/11/2009	Monday 1/12/2009	Tuesday 1/13/2009	Wednesday 1/14/2009	Thursday 1/15/2009	Friday 1/16/2009	Saturday 1/17/2009
Hour																	
1	3,049	2,961	3,003	3,004	3,004	3,007	3,052	2,996	3,000	3,021	3,047	3,028	3,069	3,031	2,449	2,454	2,319
2	3,053	2,954	3,002	3,006	3,005	3,004	3,058	2,998	2,996	3,028	3,048	3,041	3,063	3,029	2,446	2,457	2,323
3	3,050	2,957	3,007	3,001	3,009	3,006	3,052	2,993	3,001	3,021	3,050	3,029	3,069	1,532	2,444	2,452	2,321
4	3,046	2,960	3,001	3,003	3,004	3,007	3,054	2,996	2,996	3,027	3,051	3,030	3,063	-	2,451	2,459	2,322
5	3,052	2,955	3,004	3,006	3,007	3,003	3,057	2,999	2,996	3,022	3,050	3,025	3,070	-	2,444	2,449	2,322
6	3,048	2,959	3,004	3,001	3,006	3,006	3,052	2,994	3,001	3,023	3,053	3,027	3,062	-	2,444	2,459	2,319
7	3,046	2,959	3,000	3,003	3,004	3,008	3,056	2,996	2,996	1,562	3,055	3,024	3,071	-	2,447	2,452	2,323
8	3,053	2,955	3,004	3,006	3,010	3,003	2,021	2,998	2,996	698	3,048	3,025	3,063	-	2,448	2,457	2,320
9	3,049	2,961	3,002	3,001	3,003	3,007	-	2,766	2,999	499	3,054	3,038	3,071	-	2,446	2,459	2,330
10	3,048	2,956	3,001	3,006	3,008	3,007	-	2,347	2,811	733	3,053	3,036	3,066	-	2,460	2,463	1,553
11	3,054	2,956	3,006	3,004	3,004	3,006	2,757	1,891	3,029	2,434	3,049	3,042	3,076	-	2,450	2,457	1,920
12	3,048	3,008	3,002	3,007	3,006	3,047	3,000	2,583	3,032	2,446	3,054	3,054	3,074	-	2,459	2,461	2,277
13	3,050	3,003	3,008	3,004	3,005	3,054	2,997	3,086	3,034	2,434	3,051	2,534	3,058	417	2,449	2,451	2,425
14	3,052	3,008	3,005	3,008	3,005	3,059	3,001	3,001	3,033	2,746	3,051	2,432	3,028	1,421	2,458	2,439	2,416
15	3,048	3,002	3,007	3,002	3,007	3,054	2,995	3,003	3,029	3,053	3,054	3,007	3,035	1,576	2,452	2,324	2,424
16	3,034	3,004	3,003	3,008	3,003	3,059	2,996	3,004	3,031	3,056	3,047	3,071	3,028	2,398	2,454	2,318	2,417
17	2,954	3,006	3,010	3,003	3,006	3,053	2,998	2,999	3,025	3,053	3,054	3,064	3,035	2,443	2,454	2,322	2,420
18	2,952	3,003	3,004	3,006	3,005	3,056	2,994	3,000	3,026	3,052	3,048	3,066	3,029	2,452	2,453	2,321	2,420
19	2,959	3,009	3,004	3,006	3,004	3,056	2,995	3,003	3,028	3,057	3,056	3,068	3,032	2,444	2,458	2,319	2,416
20	2,954	3,002	3,008	3,003	3,008	3,052	2,998	2,995	3,022	3,048	3,052	3,063	3,033	2,452	2,451	2,324	2,423
21	2,954	3,005	3,003	3,008	3,004	3,059	2,992	3,002	3,028	3,054	3,043	3,070	3,029	2,445	2,459	2,316	2,415
22	2,958	3,006	3,006	3,004	3,007	3,052	2,995	2,997	3,024	3,047	3,053	3,062	3,035	2,445	2,451	2,324	2,422
23	2,953	3,002	3,007	3,003	3,004	3,055	2,998	3,001	3,024	3,054	3,043	3,070	3,029	2,450	2,456	2,317	2,418
24	2,954	3,007	3,002	3,009	3,004	3,056	2,994	2,996	3,027	3,047	3,044	3,063	3,031	2,444	2,454	2,325	2,419
TOTAL	72,418	71,598	72,103	72,112	72,132	72,776	65,112	69,644	72,184	62,215	73,208	71,969	73,219	32,979	58,837	57,579	55,684
Cumulative Output Sold, kWhr	72,418	144,016	216,119	288,231	360,363	433,139	498,251	567,895	640,079	702,294	775,502	847,471	920,690	953,669	1,012,506	1,070,085	1,125,769
Transformer and line efficiency	99.7%	99.0%	99.7%	99.8%	99.8%	100.2%	102.2%	101.6%	101.8%	100.9%	99.9%	100.8%	100.7%	100.2%	100.4%	100.4%	100.0%
Hourly average	3,017	2,864	3,004	3,005	3,006	3,032	2,713	2,902	3,008	2,592	3,050	2,999	3,051	1,374	2,452	2,399	2,320

JANUARY 2009																	
CNBE Daily Reports Summary Data																	
	Sunday 1/18/2009	Monday 1/19/2009	Tuesday 1/20/2009	Wednesday 1/21/2009	Thursday 1/22/2009	Friday 1/23/2009	Saturday 1/24/2009	Sunday 1/25/2009	Monday 1/26/2009	Tuesday 1/27/2009	Wednesday 1/28/2009	Thursday 1/29/2009	Friday 1/30/2009	Saturday 1/31/2009	TOTAL		
Landfill Gas Flow to the Engines (KSCF)	1,206	1,242	1,242	1,230	1,197	1,181	1,191	1,160	1,134	1,199	1,199	1,266	1,452	1,585	42,850	Engine methane, %	
Landfill Gas Flow to the Engines (MMBTU HHV)	698	717	715	702	692	682	689	672	657	697	697	743	854	913	24,475	56.44	
Landfill Gas Flow to the Flare (KSCF)	446	446	446	372	246	230	272	282	284	334	323	325	147	-	4,882	Flare methane, %	
Landfill Gas Flow to the Flare (MMBTU HHV)	230	230	230	191	123	117	143	148	149	173	168	169	76	-	2,520	51.01	
Landfill Gas Total Flow (KSCF)	1,652	1,688	1,688	1,602	1,443	1,411	1,463	1,442	1,418	1,533	1,522	1,591	1,599	1,585	47,732		
Landfill Gas Total Flow (MMBTU HHV)	928	947	945	893	815	799	832	820	806	870	865	912	930	913	26,995		
Average Methane Content (%)	55.5	55.4	55.3	55.1	55.8	55.9	56.2	56.2	56.2	56.1	56.2	56.6	57.5	56.9	55.9		
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	728		
Engine 2 Hours	24	24	24	24	24	24	24	24	22	24	24	24	24	24	723		
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	729		
Engine 4 Hours	-	-	-	-	-	-	-	-	-	-	-	-	-	14	357		
Generator 1 Power Output (kWhr)	19,404	19,913	19,947	19,754	19,846	19,696	19,822	19,747	19,827	19,993	19,993	19,968	19,874	19,453	588,640		
Generator 2 Power Output (kWhr)	19,203	19,330	19,363	19,172	19,266	19,124	19,237	19,159	17,306	19,489	19,489	19,509	19,416	19,001	552,834		
Generator 3 Power Output (kWhr)	18,992	19,107	19,159	18,965	18,953	19,295	19,428	19,349	19,394	19,629	19,629	19,836	19,797	19,495	569,998		
Generator 4 Power Output (kWhr)	-	-	-	-	56	-	-	-	-	-	-	-	7,236	13,455	260,170		
Gross Power Output (kWhr)	58,083	58,854	58,965	58,355	58,575	58,581	58,969	58,767	56,934	59,624	59,624	59,743	66,928	72,074	1,984,276		
Net Power Output (kWhr)	57,207	57,968	58,079	57,508	57,817	57,939	58,310	58,106	56,269	58,855	58,855	58,859	65,936	71,016	1,953,971		
Power Sold as metered by NStar, (kWhr)	57,677	58,055	58,057	58,073	58,091	58,667	58,673	58,675	56,700	58,615	58,667	58,773	66,109	72,806	1,963,407		
Offgrid RECs (kWhr)	876	886	886	847	758	642	659	661	665	769	769	884	992	1,058	30,305		
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	809	830	831	823	827	821	826	823	826	833	833	832	828	811			
Generator 2	800	805	807	799	803	797	802	798	787	812	812	813	809	792			
Generator 3	791	796	798	790	790	804	810	806	808	818	818	827	825	812			
Generator 4	-	-	-	-	-	-	-	-	-	-	-	-	517	561			
Power output (kW average over 24-hrs)																	
Facility Gross	2,420	2,452	2,457	2,431	2,441	2,441	2,457	2,449	2,372	2,484	2,484	2,489	2,789	3,003			
Facility Net	2,384	2,415	2,420	2,396	2,409	2,414	2,430	2,421	2,345	2,452	2,452	2,452	2,747	2,959			
In-plant load	37	37	37	35	32	27	27	28	28	32	32	37	41	44			
Daily availability factor																	
Facility	75%	75%	75%	75%	75%	75%	75%	75%	73%	75%	75%	75%	90%	100%			
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%			
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%	100%	100%			
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%			
Engine 4	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	58%	100%			
Daily capacity factor																	
Facility	73%	74%	74%	74%	74%	74%	74%	74%	72%	75%	75%	75%	85%	91%			
Engine 1	98%	101%	101%	100%	100%	99%	100%	100%	101%	101%	101%	101%	100%	98%			
Engine 2	97%	98%	98%	97%	97%	97%	97%	97%	95%	98%	98%	99%	98%	96%			
Engine 3	96%	97%	97%	96%	96%	97%	98%	98%	98%	99%	99%	100%	100%	98%			
Engine 4	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	63%	68%			
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	432	456	480	504	528	552	576	600	624	648	672	696	720	744			
Engine 1	416	440	464	488	512	536	560	584	608	632	656	680	704	728			
Engine 2	413	437	461	485	509	533	557	581	603	627	651	675	699	723			
Engine 3	417	441	465	489	513	537	561	585	609	633	657	681	705	729			
Engine 4	319	319	319	319	319	319	319	319	319	319	319	319	333	357			
Engine operating run hours total from 0 hours																	
Engine 1	27,212	27,236	27,260	27,284	27,308	27,332	27,356	27,380	27,404	27,428	27,452	27,476	27,500	27,524			
Engine 2	27,080	27,104	27,128	27,152	27,176	27,200	27,224	27,248	27,272	27,296	27,320	27,344	27,368	27,392			
Engine 3	26,700	26,724	26,748	26,772	26,796	26,820	26,844	26,868	26,892	26,916	26,940	26,964	26,988	27,012			
Engine 4	26,853	26,853	26,853	26,853	26,853	26,853	26,853	26,853	26,853	26,853	26,853	26,853	26,867	26,891			
Cumulative availability, %																	
Engine 1	96%	96%	97%	97%	97%	97%	97%	97%	97%	98%	98%	98%	98%	98%			
Engine 2	96%	96%	96%	96%	96%	97%	97%	97%	97%	97%	97%	97%	97%	97%			
Engine 3	97%	97%	97%	97%	97%	97%	97%	98%	98%	98%	98%	98%	98%	98%			
Engine 4	74%	70%	66%	63%	60%	58%	55%	53%	51%	49%	47%	46%	46%	48%			
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575			
Engine 1	14,302	15,131	15,962	16,785	17,612	18,433	19,259	20,082	20,908	21,741	22,574	23,406	24,234	25,045			
Engine 2	13,196	14,001	14,808	15,607	16,410	17,206	18,008	18,806	19,593	20,405	21,217	22,030	22,839	23,631			
Engine 3	13,730	14,526	15,324	16,114	16,904	17,708	18,517	19,324	20,132	20,950	21,767	22,594	23,419	24,231			
Engine 4	10,211	10,211	10,211	10,211	10,211	10,211	10,211	10,211	10,211	10,211	10,211	10,211	10,211	11,288			
Cumulative capacity factor, %																	
Engine 1	96%	97%	97%	97%	97%	97%	97%	97%	97%	98%	98%	98%	98%	98%			
Engine 2	89%	89%	90%	90%	90%	91%	91%	91%	91%	92%	92%	92%	92%	92%			
Engine 3	92%	93%	93%	93%	93%	93%	94%	94%	94%	94%	94%	94%	95%	95%			
Engine 4	69%	65%	62%	59%	56%	54%	52%	50%	48%	46%	44%	43%	43%	44%			

	Sunday 1/18/2009	Monday 1/19/2009	Tuesday 1/20/2009	Wednesday 1/21/2009	Thursday 1/22/2009	Friday 1/23/2009	Saturday 1/24/2009	Sunday 1/25/2009	Monday 1/26/2009	Tuesday 1/27/2009	Wednesday 1/28/2009	Thursday 1/29/2009	Friday 1/30/2009	Saturday 1/31/2009	TOTAL	
Cumulative by Facility in month																
Max cumulative available engine run hours	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976		
Actual cumulative engine run hours	1,565	1,637	1,709	1,781	1,853	1,925	1,997	2,069	2,139	2,211	2,283	2,355	2,441	2,537		
Cumulative Availability, %	90.6%	89.7%	89.0%	88.3%	87.7%	87.2%	86.7%	86.2%	85.7%	85.3%	84.9%	84.6%	84.8%	85.2%		
Max cumulative gross output, kWhr	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200		
Actual cumulative gross output, kWhr	1,198,283	1,257,137	1,316,102	1,374,457	1,433,032	1,491,613	1,550,582	1,609,349	1,666,283	1,725,907	1,785,531	1,845,274	1,912,202	1,984,276		
Cumulative Capacity Factor	84.1%	83.5%	83.1%	82.6%	82.2%	81.9%	81.6%	81.3%	80.9%	80.7%	80.5%	80.3%	80.5%	80.8%		
Cumulative fuel input, MMBtu HHV	15,045	15,762	16,477	17,179	17,871	18,553	19,242	19,914	20,571	21,268	21,965	22,708	23,562	24,475		
Cumulative gross output, kWhr	1,198,283	1,257,137	1,316,102	1,374,457	1,433,032	1,491,613	1,550,582	1,609,349	1,666,283	1,725,907	1,785,531	1,845,274	1,912,202	1,984,276		
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	10,818	10,967	10,916	10,829	10,635	10,480	10,518	10,294	10,388	10,523	10,523	11,195	11,487	11,403		
Daily heat rate, Btu/kWe gross HHV	12,017	12,183	12,126	12,030	11,814	11,642	11,684	11,435	11,540	11,690	11,690	12,437	12,760	12,668		
Cumulative heat rate, Btu/kWe gross LHV	11,302	11,287	11,270	11,251	11,226	11,197	11,171	11,139	11,113	11,093	11,074	11,078	11,092	11,103		
Cumulative heat rate, Btu/kWe gross HHV	12,555	12,538	12,520	12,499	12,471	12,438	12,410	12,374	12,345	12,323	12,302	12,306	12,322	12,334		
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976		
Actual cumulative engine run hours	1,565	1,637	1,709	1,781	1,853	1,925	1,997	2,069	2,139	2,211	2,283	2,355	2,441	2,537		
Cumulative Availability, %	90.6%	89.7%	89.0%	88.3%	87.7%	87.2%	86.7%	86.2%	85.7%	85.3%	84.9%	84.6%	84.8%	85.2%		
Max cumulative gross output, kWhr	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200		
Actual cumulative gross output, kWhr	1,198,283	1,257,137	1,316,102	1,374,457	1,433,032	1,491,613	1,550,582	1,609,349	1,666,283	1,725,907	1,785,531	1,845,274	1,912,202	1,984,276		
Cumulative Capacity Factor	84.1%	83.5%	83.1%	82.6%	82.2%	81.9%	81.6%	81.3%	80.9%	80.7%	80.5%	80.3%	80.5%	80.8%		
Cumulative fuel input, MMBtu HHV	15,045	15,762	16,477	17,179	17,871	18,553	19,242	19,914	20,571	21,268	21,965	22,708	23,562	24,475		
Cumulative gross output, kWhr	1,198,283	1,257,137	1,316,102	1,374,457	1,433,032	1,491,613	1,550,582	1,609,349	1,666,283	1,725,907	1,785,531	1,845,274	1,912,202	1,984,276		
Cumulative heat rate, Btu/kWe gross LHV	11,302	11,287	11,270	11,251	11,226	11,197	11,171	11,139	11,113	11,093	11,074	11,078	11,092	11,103		
Cumulative heat rate, Btu/kWe gross HHV	12,555	12,538	12,520	12,499	12,471	12,438	12,410	12,374	12,345	12,323	12,302	12,306	12,322	12,334		
Service																
Engine 1		Ray Bedard														
Engine 2		starts.														
Engine 3		Ops meeting.														
Engine 4						D. Denietolis				Carter CAT	Carter CAT		Carter CAT			
Oil - oil and filter change						cylinder scope				travel	overhaul		overhaul completed.			
Service - plugs, air filter, valve inspection and adjus						and compression test				start			Restart E4			
NSTAR Power Reports																
Date	Sunday 1/18/2009	Monday 1/19/2009	Tuesday 1/20/2009	Wednesday 1/21/2009	Thursday 1/22/2009	Friday 1/23/2009	Saturday 1/24/2009	Sunday 1/25/2009	Monday 1/26/2009	Tuesday 1/27/2009	Wednesday 1/28/2009	Thursday 1/29/2009	Friday 1/30/2009	Saturday 1/31/2009	TOTAL	
Hour																
1	2,422	2,418	2,418	2,416	2,415	2,446	2,441	2,443	2,440	2,440	2,444	2,442	2,450	3,048		
2	2,416	2,420	2,422	2,419	2,425	2,439	2,447	2,441	2,447	2,444	2,443	2,443	2,441	3,039		
3	2,424	2,414	2,414	2,419	2,417	2,447	2,442	2,447	2,441	2,442	2,439	2,452	2,449	3,048		
4	2,415	2,420	2,423	2,418	2,422	2,439	2,447	2,440	2,444	2,442	2,447	2,444	2,440	3,039		
5	2,420	2,419	2,415	2,420	2,419	2,444	2,441	2,444	2,445	2,444	2,440	2,444	2,449	3,048		
6	2,419	2,415	2,422	2,416	2,420	2,442	2,447	2,444	2,441	2,440	2,442	2,451	2,440	3,039		
7	2,418	2,423	2,417	2,422	2,422	2,441	2,441	2,441	2,449	2,445	2,445	2,445	2,449	3,041		
8	2,424	2,416	2,422	2,414	2,418	2,447	2,448	2,449	2,440	2,439	2,440	2,447	2,438	3,040		
9	2,417	2,419	2,417	2,422	2,423	2,441	2,442	2,441	1,904	2,446	2,444	2,457	2,443	3,039		
10	2,422	2,418	2,421	2,412	2,423	2,447	2,449	2,449	1,612	2,439	2,434	2,438	2,447	3,043		
11	2,420	2,420	2,417	2,421	2,423	2,447	2,445	2,446	1,874	2,446	2,437	2,449	2,516	3,044		
12	2,415	2,418	2,419	2,424	2,424	2,446	2,450	2,447	2,445	2,446	2,452	2,456	2,834	3,046		
13	2,418	2,421	2,415	2,415	2,422	2,446	2,449	2,451	2,446	2,441	2,446	2,460	2,855	3,039		
14	2,287	2,417	2,421	2,423	2,470	2,446	2,445	2,444	2,447	2,441	2,450	2,458	3,015	3,039		
15	2,166	2,423	2,418	2,424	2,164	2,446	2,448	2,450	2,445	2,444	2,443	2,459	3,048	3,030		
16	2,422	2,418	2,421	2,418	2,444	2,445	2,447	2,443	2,440	2,439	2,449	2,453	3,044	3,021		
17	2,416	2,423	2,418	2,425	2,440	2,443	2,445	2,448	2,447	2,446	2,445	2,453	3,045	3,019		
18	2,424	2,417	2,422	2,419	2,447	2,447	2,441	2,442	2,439	2,441	2,444	2,447	3,043	3,030		
19	2,417	2,421	2,417	2,422	2,440	2,443	2,447	2,448	2,443	2,440	2,451	2,449	3,046	3,020		
20	2,420	2,418	2,423	2,421	2,444	2,447	2,439	2,441	2,441	2,446	2,447	2,444	3,042	3,028		
21	2,420	2,419	2,416	2,419	2,442	2,442	2,443	2,446	2,440	2,439	2,445	2,450	3,046	3,017		
22	2,416	2,419	2,423	2,423	2,443	2,447	2,445	2,442	2,446	2,441	2,450	2,442	3,042	3,007		
23	2,423	2,418	2,416	2,416	2,444	2,442	2,438	2,442	2,438	2,445	2,442	2,450	3,047	3,023		
24	2,416	2,421	2,420	2,425	2,440	2,447	2,446	2,446	2,446	2,439	2,448	2,440	3,040	3,019		
TOTAL	57,677	58,055	58,057	58,073	58,091	58,667	58,673	58,675	56,700	58,615	58,667	58,773	66,109	72,806		
Cumulative Output Sold, kWhr	1,183,446	1,241,501	1,299,558	1,357,631	1,415,722	1,474,389	1,533,062	1,591,737	1,648,437	1,707,052	1,765,719	1,824,492	1,890,601	1,963,407		
Transformer and line efficiency	100.8%	100.2%	100.0%	101.0%	100.5%	101.3%	100.6%	101.0%	100.8%	99.6%	99.7%	99.9%	100.3%	102.5%		
Hourly average	2,403	2,419	2,419	2,420	2,420	2,444	2,445	2,445	2,363	2,442	2,444	2,449	2,755	3,034	2,617	

FEBRUARY 2009															
CNBE Daily Reports Summary Data															
	Sunday 2/1/2009	Monday 2/2/2009	Tuesday 2/3/2009	Wednesday 2/4/2009	Thursday 2/5/2009	Friday 2/6/2009	Saturday 2/7/2009	Sunday 2/8/2009	Monday 2/9/2009	Tuesday 2/10/2009	Wednesday 2/11/2009	Thursday 2/12/2009	Friday 2/13/2009	Saturday 2/14/2009	
Landfill Gas Flow to the Engines (KSCF)	1,594	1,629	1,624	1,645	1,675	1,659	1,632	1,620	1,627	1,630	1,639	1,580	1,716	1,660	
Landfill Gas Flow to the Engines (MMBTU HHV)	910	927	923	924	898	888	884	894	877	885	902	884	932	906	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,594	1,629	1,624	1,645	1,675	1,659	1,632	1,620	1,627	1,630	1,639	1,580	1,716	1,660	
Landfill Gas Total Flow (MMBTU HHV)	910	927	923	924	898	888	884	894	877	885	902	884	932	906	
Average Methane Content wet (%)	56.4	56.2	56.2	55.5	53.0	52.9	53.5	54.5	53.3	53.7	54.4	55.3	53.7	53.9	
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	22	24	24	
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	21	24	24	
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
Generator 1 Power Output (kWhr)	19,612	19,334	18,459	18,598	18,379	18,358	18,596	18,512	18,204	18,086	18,441	17,086	18,578	18,218	
Generator 2 Power Output (kWhr)	19,181	18,885	18,074	17,503	17,534	16,851	16,628	16,544	16,483	16,464	16,961	17,932	17,650	16,273	
Generator 3 Power Output (kWhr)	19,665	19,203	18,383	18,575	18,439	18,442	18,520	18,471	18,133	17,999	18,388	16,145	18,499	18,173	
Generator 4 Power Output (kWhr)	13,521	15,378	17,557	17,695	17,676	17,679	17,498	17,447	17,353	17,589	17,925	18,244	18,114	17,726	
Gross Power Output (kWhr)	72,658	73,577	73,292	73,207	72,890	72,128	72,045	71,810	70,971	70,921	72,512	70,168	73,695	71,118	
Net Power Output (kWhr)	71,567	72,479	72,184	72,096	71,733	71,017	70,976	70,691	69,907	69,846	71,443	69,132	72,538	70,056	
Power Sold as metered by NStar, (kWhr)	72,746	72,222	72,492	71,883	71,110	70,895	71,385	71,329	70,904	71,519	71,462	69,758	73,189	70,513	
Offgrid RECs (kWhr)	1,091	1,098	1,108	1,111	1,157	1,111	1,069	1,119	1,064	1,075	1,069	1,036	1,157	1,062	
Calculated Performance Results															
Daily															
Power output (kW average when running)															
Generator 1	817	806	769	775	766	765	775	771	759	754	768	777	774	759	
Generator 2	799	787	753	729	731	702	693	689	687	686	707	747	735	678	
Generator 3	819	800	766	774	768	768	772	770	756	750	766	769	771	757	
Generator 4	563	641	732	737	737	737	729	727	723	733	747	760	755	739	
Power output (kW average over 24-hrs)															
Facility Gross	3,027	3,066	3,054	3,050	3,037	3,005	3,002	2,992	2,957	2,955	3,021	2,924	3,071	2,963	
Facility Net	2,982	3,020	3,008	3,004	2,989	2,959	2,957	2,945	2,913	2,910	2,977	2,881	3,022	2,919	
In-plant load	45	46	46	46	48	46	45	47	44	45	45	43	48	44	
Daily availability factor															
Facility	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	95%	100%	100%	
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	88%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor															
Facility	92%	93%	93%	92%	92%	91%	91%	91%	90%	90%	92%	89%	93%	90%	
Engine 1	99%	98%	93%	94%	93%	93%	94%	93%	92%	91%	93%	94%	94%	92%	
Engine 2	97%	95%	91%	88%	89%	85%	84%	84%	83%	83%	86%	91%	89%	82%	
Engine 3	99%	97%	93%	94%	93%	93%	94%	93%	92%	91%	93%	93%	93%	92%	
Engine 4	68%	78%	89%	89%	89%	89%	88%	88%	88%	89%	91%	92%	91%	90%	
Cumulative by engine															
Engine operating run hours in the month															
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	
Engine 1	24	48	72	96	120	144	168	192	216	240	264	286	310	334	
Engine 2	24	48	72	96	120	144	168	192	216	240	264	288	312	336	
Engine 3	24	48	72	96	120	144	168	192	216	240	264	285	309	333	
Engine 4	24	48	72	96	120	144	168	192	216	240	264	288	312	336	
Engine operating run hours total from 0 hours															
Engine 1	27,548	27,572	27,596	27,620	27,644	27,668	27,692	27,716	27,740	27,764	27,788	27,810	27,834	27,858	
Engine 2	27,414	27,438	27,462	27,486	27,510	27,534	27,558	27,582	27,606	27,630	27,654	27,678	27,702	27,726	
Engine 3	27,036	27,060	27,084	27,108	27,132	27,156	27,180	27,204	27,228	27,252	27,276	27,297	27,321	27,345	
Engine 4	26,915	26,939	26,963	26,987	27,011	27,035	27,059	27,083	27,107	27,131	27,155	27,179	27,203	27,227	
Cumulative availability, %															
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine cumulative gross output, kWhr															
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	
Engine 1	817	1,623	2,392	3,167	3,933	4,698	5,472	6,244	7,002	7,756	8,524	9,301	10,075	10,834	
Engine 2	799	1,586	2,339	3,068	3,799	4,501	5,194	5,883	6,570	7,256	7,963	8,710	9,445	10,123	
Engine 3	819	1,620	2,385	3,159	3,928	4,696	5,468	6,237	6,993	7,743	8,509	9,278	10,049	10,806	
Engine 4	563	1,204	1,936	2,673	3,409	4,146	4,875	5,602	6,325	7,058	7,805	8,565	9,320	10,058	
Cumulative capacity factor, %															
Engine 1	99%	98%	97%	96%	95%	95%	95%	95%	94%	94%	94%	94%	94%	94%	
Engine 2	97%	96%	95%	93%	92%	91%	90%	89%	88%	88%	88%	88%	88%	88%	
Engine 3	99%	98%	96%	96%	95%	95%	95%	95%	94%	94%	94%	94%	94%	94%	
Engine 4	68%	73%	78%	81%	83%	84%	84%	85%	85%	86%	86%	87%	87%	87%	

FEBRUARY 2009

		Sunday 2/1/2009	Monday 2/2/2009	Tuesday 2/3/2009	Wednesday 2/4/2009	Thursday 2/5/2009	Friday 2/6/2009	Saturday 2/7/2009	Sunday 2/8/2009	Monday 2/9/2009	Tuesday 2/10/2009	Wednesday 2/11/2009	Thursday 2/12/2009	Friday 2/13/2009	Saturday 2/14/2009
Cumulative by Facility in month															
	Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344
	Actual cumulative engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,147	1,243	1,339
	Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	99.6%	99.6%	99.6%
	Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800
	Actual cumulative gross output, kWhr	72,658	146,235	219,527	292,734	365,624	437,752	509,797	581,607	652,578	723,499	796,011	866,179	939,874	1,010,992
	Cumulative Capacity Factor	91.7%	92.3%	92.4%	92.4%	92.3%	92.1%	92.0%	91.8%	91.6%	91.4%	91.4%	91.1%	91.3%	91.2%
	Cumulative fuel input, MMBtu HHV	910	1,837	2,760	3,684	4,582	5,470	6,354	7,248	8,125	9,010	9,912	10,796	11,728	12,634
	Cumulative gross output, kWhr	72,658	146,235	219,527	292,734	365,624	437,752	509,797	581,607	652,578	723,499	796,011	866,179	939,874	1,010,992
Heat Rate															
	Daily heat rate, Btu/kWe gross LHV	11,274	11,342	11,337	11,362	11,090	11,083	11,046	11,207	11,124	11,233	11,198	11,341	11,385	11,468
	Daily heat rate, Btu/kWe gross HHV	12,524	12,599	12,593	12,622	12,320	12,311	12,270	12,450	12,357	12,479	12,439	12,598	12,647	12,739
	Cumulative heat rate, Btu/kWe gross LHV	11,274	11,308	11,318	11,329	11,281	11,249	11,220	11,218	11,208	11,210	11,209	11,220	11,233	11,249
	Cumulative heat rate, Btu/kWe gross HHV	12,524	12,562	12,572	12,585	12,532	12,496	12,464	12,462	12,451	12,453	12,452	12,464	12,478	12,497
Cumulative by Facility starting Calendar Year															
	Max cumulative available engine run hours	3,072	3,168	3,264	3,360	3,456	3,552	3,648	3,744	3,840	3,936	4,032	4,128	4,224	4,320
	Actual cumulative engine run hours	2,633	2,729	2,825	2,921	3,017	3,113	3,209	3,305	3,401	3,497	3,593	3,684	3,780	3,876
	Cumulative Availability, %	85.7%	86.1%	86.6%	86.9%	87.3%	87.6%	88.0%	88.3%	88.6%	88.8%	89.1%	89.2%	89.5%	89.7%
	Max cumulative gross output, kWhr	2,534,400	2,613,600	2,692,800	2,772,000	2,851,200	2,930,400	3,009,600	3,088,800	3,168,000	3,247,200	3,326,400	3,405,600	3,484,800	3,564,000
	Actual cumulative gross output, kWhr	2,056,934	2,130,511	2,203,803	2,277,010	2,349,900	2,422,028	2,494,073	2,565,883	2,636,854	2,707,775	2,780,287	2,850,455	2,924,150	2,995,268
	Cumulative Capacity Factor	81.2%	81.5%	81.8%	82.1%	82.4%	82.7%	82.9%	83.1%	83.2%	83.4%	83.6%	83.7%	83.9%	84.0%
	Cumulative fuel input, MMBtu HHV	25,385	26,312	27,235	28,159	29,057	29,945	30,829	31,723	32,600	33,485	34,387	35,271	36,203	37,109
	Cumulative gross output, kWhr	2,056,934	2,130,511	2,203,803	2,277,010	2,349,900	2,422,028	2,494,073	2,565,883	2,636,854	2,707,775	2,780,287	2,850,455	2,924,150	2,995,268
	Cumulative heat rate, Btu/kWe gross LHV	11,110	11,118	11,125	11,132	11,131	11,130	11,127	11,129	11,129	11,132	11,131	11,139	11,145	11,153
	Cumulative heat rate, Btu/kWe gross HHV	12,341	12,350	12,358	12,367	12,365	12,364	12,361	12,363	12,363	12,366	12,368	12,374	12,381	12,389
Service															
	Engine 1												Service		
	Engine 2														
	Engine 3									Monthly Ops meeting			Service		
	Engine 4														
Oil - oil and filter change											District starts				
Service - plugs, air filter, valve inspection and adjustment											well pumping	well pumping	well pumping	well pumping	
NSTAR Power Reports															
	Date	Sunday 2/1/2009	Monday 2/2/2009	Tuesday 2/3/2009	Wednesday 2/4/2009	Thursday 2/5/2009	Friday 2/6/2009	Saturday 2/7/2009	Sunday 2/8/2009	Monday 2/9/2009	Tuesday 2/10/2009	Wednesday 2/11/2009	Thursday 2/12/2009	Friday 2/13/2009	Saturday 2/14/2009
	Hour														
	1	3,022	2,977	3,016	2,982	2,914	2,979	2,969	2,967	2,972	2,921	2,975	2,979	3,124	2,936
	2	3,027	3,004	3,022	2,985	2,908	2,970	2,980	2,974	2,975	2,925	2,980	2,979	3,120	2,934
	3	3,038	3,000	3,016	2,981	2,917	2,978	2,972	2,969	2,976	2,919	2,974	2,978	3,124	2,941
	4	3,027	3,011	3,022	2,988	2,907	2,973	2,977	2,974	2,971	2,926	2,980	2,978	3,120	2,934
	5	3,040	2,999	3,015	2,979	2,916	2,975	2,977	2,969	2,977	2,921	2,975	2,978	3,124	2,936
	6	3,033	3,011	3,021	2,986	2,909	2,975	2,974	2,974	2,974	2,923	2,981	2,978	3,120	2,939
	7	3,039	3,002	3,016	2,982	2,914	2,974	2,979	2,969	2,972	2,925	2,975	2,977	3,124	2,934
	8	3,020	3,018	3,021	2,985	2,909	2,977	2,973	2,974	2,977	2,920	2,980	2,976	3,119	2,939
	9	3,037	3,021	2,987	3,079	3,025	2,920	2,980	2,970	2,968	3,000	2,975	2,420	3,090	2,938
	10	3,031	2,973	2,982	3,137	3,104	2,750	2,974	2,974	2,974	3,005	2,979	2,387	3,030	2,941
	11	3,035	2,931	3,046	3,109	3,104	2,912	2,978	2,975	2,974	3,017	2,978	2,392	3,052	2,940
	12	3,029	2,946	3,103	3,105	2,904	2,913	2,977	2,973	2,973	3,077	2,978	2,434	3,051	2,940
	13	3,036	2,960	3,100	3,055	2,970	2,915	2,972	2,973	2,972	3,078	2,977	2,401	3,052	2,940
	14	3,044	3,067	3,100	3,009	2,975	2,919	2,973	2,973	2,971	3,077	2,977	2,608	3,051	2,940
	15	3,039	3,092	3,102	3,010	2,970	2,992	2,975	2,973	2,972	3,075	2,977	3,152	3,035	2,940
	16	3,043	3,070	3,070	2,995	2,977	2,975	2,970	2,970	2,931	2,992	2,977	3,153	3,000	2,936
	17	3,035	3,017	2,986	3,022	2,970	2,976	2,976	2,972	2,920	2,979	2,978	3,126	2,992	2,940
	18	3,037	3,018	2,974	3,029	2,978	2,971	2,972	2,968	2,926	2,974	2,978	3,125	2,993	2,936
	19	3,029	3,014	2,983	2,907	2,972	2,979	2,974	2,975	2,920	2,980	2,979	3,124	2,995	2,941
	20	3,031	3,018	2,976	2,916	2,975	2,971	2,973	2,969	2,922	2,974	2,978	3,124	2,991	2,936
	21	3,021	3,015	2,985	2,907	2,975	2,976	2,972	2,974	2,924	2,979	2,979	3,121	2,994	2,938
	22	3,031	3,021	2,981	2,913	2,972	2,975	2,975	2,972	2,918	2,976	2,979	3,124	2,994	2,938
	23	3,020	3,016	2,984	2,911	2,976	2,972	2,969	2,971	2,924	2,978	2,975	3,124	2,955	2,935
	24	3,002	3,021	2,984	2,911	2,969	2,978	2,974	2,977	2,921	2,978	2,978	3,120	2,939	2,941
	TOTAL	72,746	72,222	72,492	71,883	71,110	70,895	71,385	71,329	70,904	71,519	71,462	69,758	73,189	70,513
	Cumulative Output Sold, kWhr	72,746	144,968	217,460	289,343	360,453	431,348	502,733	574,062	644,966	716,485	787,947	857,705	930,894	1,001,407
	Transformer and line efficiency	101.6%	99.6%	100.4%	99.7%	99.1%	99.8%	100.6%	100.9%	101.4%	102.4%	100.0%	100.9%	100.9%	100.7%
	Hourly average	3,031	2,889	3,021	2,995	2,963	2,954	2,974	2,972	2,954	2,980	2,978	2,907	3,050	2,938

FEBRUARY 2009																
CNBE Daily Reports Summary Data																
	Sunday 2/15/2009	Monday 2/16/2009	Tuesday 2/17/2009	Wednesday 2/18/2009	Thursday 2/19/2009	Friday 2/20/2009	Saturday 2/21/2009	Sunday 2/22/2009	Monday 2/23/2009	Tuesday 2/24/2009	Wednesday 2/25/2009	Thursday 2/26/2009	Friday 2/27/2009	Saturday 2/28/2009	TOTAL	
Landfill Gas Flow to the Engines (KSCF)	1,680	1,690	1,711	1,711	1,703	1,758	1,666	1,666	1,726	1,743	1,727	1,741	1,778	1,776	47,006	
Landfill Gas Flow to the Engines (MMBTU HHV)	906	911	920	927	935	949	902	902	937	922	887	917	941	945	25,535	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,680	1,690	1,711	1,711	1,703	1,758	1,666	1,666	1,726	1,743	1,727	1,741	1,778	1,776	47,006	
Landfill Gas Total Flow (MMBTU HHV)	906	911	920	927	935	949	902	902	937	922	887	917	941	945	25,535	
Average Methane Content wet (%)	53.3	53.3	53.1	53.5	54.2	53.3	53.5	53.5	53.6	52.3	50.8	52.0	52.3	52.6	53.7	
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	670	
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	672	
Engine 3 Hours	24	24	23	24	24	24	24	24	24	24	24	24	24	24	668	
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	672	
Generator 1 Power Output (kWhr)	18,423	18,534	18,584	18,561	18,492	18,752	17,933	17,933	18,703	18,488	18,263	18,593	19,152	19,067	517,939	
Generator 2 Power Output (kWhr)	16,450	16,364	17,177	18,019	17,906	18,196	17,407	17,407	18,142	17,930	17,704	18,052	18,641	18,544	490,902	
Generator 3 Power Output (kWhr)	18,365	18,476	18,134	18,503	18,539	18,713	17,868	17,868	18,643	18,431	18,225	18,537	19,184	19,144	515,665	
Generator 4 Power Output (kWhr)	17,947	18,067	18,066	18,100	18,082	18,285	17,457	17,457	18,208	18,025	17,787	18,053	18,706	18,616	494,258	
Gross Power Output (kWhr)	71,978	72,228	72,751	74,027	73,856	74,810	71,499	71,499	74,561	73,668	72,776	74,067	76,511	76,198	2,041,421	
Net Power Output (kWhr)	70,903	71,126	71,607	72,900	72,715	73,624	70,452	70,452	73,429	72,504	71,649	72,917	75,308	75,045	2,010,296	
Power Sold as metered by NStar, (kWhr)	70,508	71,109	71,538	72,776	74,087	73,146	70,949	70,988	72,913	72,693	71,648	73,240	75,206	74,721	2,016,929	
Offgrid RECs (kWhr)	1,075	1,102	1,144	1,127	1,141	1,186	1,047	1,047	1,132	1,164	1,127	1,150	1,203	1,153	31,125	
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	768	772	774	773	771	781	747	747	779	770	761	775	798	794		
Generator 2	685	682	716	751	746	758	725	725	756	747	738	752	777	773		
Generator 3	765	770	788	771	772	780	745	745	777	768	759	772	799	798		
Generator 4	748	753	753	754	753	762	727	727	759	751	741	752	779	776		
Power output (kW average over 24-hrs)																
Facility Gross	2,999	3,010	3,031	3,084	3,077	3,117	2,979	2,979	3,107	3,070	3,032	3,086	3,188	3,175		
Facility Net	2,954	2,964	2,984	3,038	3,030	3,068	2,936	2,936	3,060	3,021	2,985	3,038	3,138	3,127		
In-plant load	45	46	48	47	48	49	44	44	47	49	47	48	50	48		
Daily availability factor																
Facility	100%	100%	99%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 3	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Daily capacity factor																
Facility	91%	91%	92%	93%	93%	94%	90%	90%	94%	93%	92%	94%	97%	96%		
Engine 1	93%	94%	94%	94%	93%	95%	91%	91%	94%	93%	92%	94%	97%	96%		
Engine 2	83%	83%	87%	91%	90%	92%	88%	88%	92%	91%	89%	91%	94%	94%		
Engine 3	93%	93%	96%	93%	94%	95%	90%	90%	94%	93%	92%	94%	97%	97%		
Engine 4	91%	91%	91%	91%	91%	92%	88%	88%	92%	91%	90%	91%	94%	94%		
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	360	384	408	432	456	480	504	528	552	576	600	624	648	672		
Engine 1	358	382	406	430	454	478	502	526	550	574	598	622	646	670		
Engine 2	360	384	408	432	456	480	504	528	552	576	600	624	648	672		
Engine 3	357	381	404	428	452	476	500	524	548	572	596	620	644	668		
Engine 4	360	384	408	432	456	480	504	528	552	576	600	624	648	672		
Engine operating run hours total from 0 hours																
Engine 1	27,882	27,906	27,930	27,954	27,978	28,002	28,026	28,050	28,074	28,098	28,122	28,146	28,170	28,194		
Engine 2	27,750	27,774	27,798	27,822	27,846	27,870	27,894	27,918	27,942	27,966	27,990	28,014	28,038	28,062		
Engine 3	27,369	27,393	27,416	27,440	27,464	27,488	27,512	27,536	27,560	27,584	27,608	27,632	27,656	27,680		
Engine 4	27,251	27,275	27,299	27,323	27,347	27,371	27,395	27,419	27,443	27,467	27,491	27,515	27,539	27,563		
Cumulative availability, %																
Engine 1	99%	99%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 3	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%		
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	12,375	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100		
Engine 1	11,602	12,374	13,148	13,922	14,692	15,473	16,221	16,968	17,747	18,517	19,278	20,053	20,851	21,646		
Engine 2	10,809	11,491	12,206	12,957	13,703	14,461	15,187	15,912	16,668	17,415	18,153	18,905	19,682	20,454		
Engine 3	11,571	12,341	13,129	13,900	14,673	15,452	16,197	16,941	17,718	18,486	19,246	20,018	20,817	21,615		
Engine 4	10,806	11,559	12,312	13,066	13,819	14,581	15,309	16,036	16,795	17,546	18,287	19,039	19,818	20,594		
Cumulative capacity factor, %																
Engine 1	94%	94%	94%	94%	94%	94%	94%	93%	94%	94%	93%	93%	94%	94%		
Engine 2	87%	87%	87%	87%	87%	88%	88%	88%	88%	88%	88%	88%	88%	89%		
Engine 3	94%	93%	94%	94%	94%	94%	93%	93%	93%	93%	93%	93%	93%	94%		
Engine 4	87%	88%	88%	88%	88%	88%	88%	88%	89%	89%	89%	89%	89%	89%		

		Sunday 2/15/2009	Monday 2/16/2009	Tuesday 2/17/2009	Wednesday 2/18/2009	Thursday 2/19/2009	Friday 2/20/2009	Saturday 2/21/2009	Sunday 2/22/2009	Monday 2/23/2009	Tuesday 2/24/2009	Wednesday 2/25/2009	Thursday 2/26/2009	Friday 2/27/2009	Saturday 2/28/2009	TOTAL
Cumulative by Facility in month																
	Max cumulative available engine run hours	1,440	1,536	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	
	Actual cumulative engine run hours	1,435	1,531	1,626	1,722	1,818	1,914	2,010	2,106	2,202	2,298	2,394	2,490	2,586	2,682	
	Cumulative Availability, %	99.7%	99.7%	99.6%	99.7%	99.7%	99.7%	99.7%	99.7%	99.7%	99.7%	99.8%	99.8%	99.8%	99.8%	
	Max cumulative gross output, kWhr	1,188,000	1,267,200	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	
	Actual cumulative gross output, kWhr	1,082,970	1,155,198	1,227,949	1,301,976	1,375,832	1,450,642	1,522,141	1,593,640	1,668,201	1,741,869	1,814,645	1,888,712	1,965,223	2,041,421	
	Cumulative Capacity Factor	91.2%	91.2%	91.2%	91.3%	91.4%	91.6%	91.5%	91.5%	91.6%	91.6%	91.6%	91.7%	91.9%	92.1%	
	Cumulative fuel input, MMBtu HHV	13,540	14,451	15,371	16,298	17,233	18,182	19,084	19,986	20,923	21,845	22,732	23,649	24,590	25,535	
	Cumulative gross output, kWhr	1,082,970	1,155,198	1,227,949	1,301,976	1,375,832	1,450,642	1,522,141	1,593,640	1,668,201	1,741,869	1,814,645	1,888,712	1,965,223	2,041,421	
Heat Rate																
	Daily heat rate, Btu/kWe gross LHV	11,331	11,354	11,384	11,273	11,396	11,419	11,356	11,356	11,313	11,267	10,972	11,145	11,071	11,164	
	Daily heat rate, Btu/kWe gross HHV	12,587	12,613	12,646	12,522	12,660	12,685	12,616	12,616	12,567	12,516	12,188	12,381	12,299	12,402	
	Cumulative heat rate, Btu/kWe gross LHV	11,255	11,261	11,268	11,269	11,275	11,283	11,286	11,289	11,291	11,289	11,277	11,272	11,264	11,260	
	Cumulative heat rate, Btu/kWe gross HHV	12,503	12,510	12,518	12,518	12,526	12,534	12,538	12,541	12,542	12,541	12,527	12,521	12,513	12,508	
Cumulative by Facility starting Calendar Year																
	Max cumulative available engine run hours	4,416	4,512	4,608	4,704	4,800	4,896	4,992	5,088	5,184	5,280	5,376	5,472	5,568	5,664	
	Actual cumulative engine run hours	3,972	4,068	4,163	4,259	4,355	4,451	4,547	4,643	4,739	4,835	4,931	5,027	5,123	5,219	
	Cumulative Availability, %	89.9%	90.2%	90.3%	90.5%	90.7%	90.9%	91.1%	91.3%	91.4%	91.6%	91.7%	91.9%	92.0%	92.1%	
	Max cumulative gross output, kWhr	3,643,200	3,722,400	3,801,600	3,880,800	3,960,000	4,039,200	4,118,400	4,197,600	4,276,800	4,356,000	4,435,200	4,514,400	4,593,600	4,672,800	
	Actual cumulative gross output, kWhr	3,067,246	3,139,474	3,212,225	3,286,252	3,360,108	3,434,918	3,506,417	3,577,916	3,652,477	3,726,145	3,798,921	3,872,988	3,949,499	4,025,697	
	Cumulative Capacity Factor	84.2%	84.3%	84.5%	84.7%	84.9%	85.0%	85.1%	85.2%	85.4%	85.5%	85.7%	85.8%	86.0%	86.2%	
	Cumulative fuel input, MMBtu HHV	38,015	38,926	39,846	40,773	41,708	42,657	43,559	44,461	45,398	46,320	47,207	48,124	49,065	50,010	
	Cumulative gross output, kWhr	3,067,246	3,139,474	3,212,225	3,286,252	3,360,108	3,434,918	3,506,417	3,577,916	3,652,477	3,726,145	3,798,921	3,872,988	3,949,499	4,025,697	
	Cumulative heat rate, Btu/kWe gross LHV	11,157	11,161	11,166	11,169	11,174	11,179	11,183	11,186	11,189	11,190	11,186	11,185	11,183	11,183	
	Cumulative heat rate, Btu/kWe gross HHV	12,394	12,399	12,404	12,407	12,413	12,419	12,423	12,427	12,429	12,431	12,426	12,426	12,423	12,423	
Service																
	Engine 1															
	Engine 2															
	Engine 3															
	Engine 4															
	Oil - oil and filter change			well pumping	well pumping	well pumping		well pumping	well pumping	well pumping	well pumping	well pumping	District clears leachate lines			
	Service - plugs, air filter, valve inspection and adjustr															
NSTAR Power Reports																
	Date	Sunday 2/15/2009	Monday 2/16/2009	Tuesday 2/17/2009	Wednesday 2/18/2009	Thursday 2/19/2009	Friday 2/20/2009	Saturday 2/21/2009	Sunday 2/22/2009	Monday 2/23/2009	Tuesday 2/24/2009	Wednesday 2/25/2009	Thursday 2/26/2009	Friday 2/27/2009	Saturday 2/28/2009	TOTAL
	Hour															
	1	2,935	2,934	2,976	2,956	3,075	3,109	2,953	2,954	2,957	3,051	2,993	2,995	3,094	3,114	
	2	2,937	2,940	2,984	2,961	3,069	3,112	2,957	2,960	2,959	3,056	2,995	2,996	3,089	3,113	
	3	2,939	2,935	2,978	2,955	3,075	3,112	2,955	2,954	2,959	3,050	2,990	2,992	3,094	3,114	
	4	2,935	2,936	2,979	2,962	3,069	3,108	2,954	2,959	2,956	3,053	2,998	2,999	3,090	3,114	
	5	2,939	2,940	2,982	2,956	3,075	3,112	2,959	2,956	2,962	3,054	2,994	2,992	3,094	3,114	
	6	2,937	2,934	2,976	2,958	3,070	3,110	2,952	2,956	2,955	3,049	2,996	2,996	3,091	3,115	
	7	2,934	2,939	2,982	2,962	3,077	3,108	2,959	2,957	2,959	3,058	2,999	2,997	3,092	3,115	
	8	2,941	2,939	2,979	2,955	3,070	3,115	2,954	2,955	2,959	3,051	2,991	2,994	3,092	3,115	
	9	2,935	2,937	2,979	3,042	3,100	3,106	2,959	2,960	3,088	3,055	3,015	3,034	3,154	3,110	
	10	2,940	2,940	2,977	3,070	3,110	3,110	2,953	2,960	3,108	3,047	2,955	3,052	3,208	3,115	
	11	2,940	2,982	2,994	3,071	3,110	3,110	2,958	2,955	3,115	3,051	2,955	3,095	3,226	3,113	
	12	2,940	2,984	2,630	3,071	2,941	3,110	2,958	2,959	3,111	3,051	2,955	3,049	3,234	3,114	
	13	2,939	2,984	3,145	3,070	3,019	3,108	2,958	2,960	3,111	3,051	2,956	3,050	3,234	3,114	
	14	2,940	2,978	3,125	3,070	3,109	3,103	2,958	2,955	3,111	3,051	2,949	3,077	3,231	3,114	
	15	2,940	2,983	3,115	3,070	3,110	3,010	2,958	2,960	3,111	3,024	2,960	3,090	3,169	3,114	
	16	2,940	2,984	3,095	3,070	3,111	2,955	2,958	2,957	3,069	2,994	2,990	3,091	3,113	3,115	
	17	2,935	2,978	2,957	3,073	3,114	2,959	2,954	2,959	3,051	2,992	2,993	3,095	3,113	3,115	
	18	2,940	2,981	2,958	3,073	3,114	2,953	2,958	2,961	3,056	2,998	2,997	3,095	3,113	3,110	
	19	2,935	2,981	2,952	3,071	3,109	2,959	2,954	2,957	3,051	2,992	2,993	3,091	3,112	3,115	
	20	2,936	2,978	2,958	3,069	3,114	2,953	2,954	2,960	3,052	2,995	2,994	3,094	3,112	3,110	
	21	2,940	2,983	2,954	3,075	3,109	2,957	2,959	2,957	3,056	2,993	2,996	3,092	3,112	3,115	
	22	2,935	2,978	2,953	3,071	3,114	2,955	2,953	2,960	3,050	2,990	2,993	3,091	3,113	3,109	
	23	2,938	2,979	2,959	3,076	3,109	2,953	2,958	2,957	3,054	2,997	2,999	3,093	3,113	3,113	
	24	2,938	2,982	2,951	3,069	3,114	2,959	2,956	2,960	3,053	2,990	2,992	3,090	3,113	3,111	
	TOTAL	70,508	71,109	71,538	72,776	74,087	73,146	70,949	70,988	72,913	72,693	71,648	73,240	75,206	74,721	
	Cumulative Output Sold, kWhr	1,071,915	1,143,024	1,214,562	1,287,338	1,361,425	1,434,571	1,505,520	1,576,508	1,649,421	1,722,114	1,793,762	1,867,002	1,942,208	2,016,929	
	Transformer and line efficiency	99.4%	100.0%	99.9%	99.8%	101.9%	99.4%	100.7%	100.8%	99.3%	100.3%	100.0%	100.4%	99.9%	99.6%	0.0%
	Hourly average	2,938	2,963	2,981	3,032	3,087	3,048	2,956	2,958	3,038	3,029	2,985	3,052	3,134	3,113	2,997

MARCH 2009

MARCH 2009																
CNBE Daily Reports Summary Data																
	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Daylight savings	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday
	3/1/2009	3/2/2009	3/3/2009	3/4/2009	3/5/2009	3/6/2009	3/7/2009	3/8/2009	3/9/2009	3/10/2009	3/11/2009	3/12/2009	3/13/2009	3/14/2009	3/15/2009	3/16/2009
Landfill Gas Flow to the Engines (KSCF)	1,768	1,768	1,721	1,782	1,767	1,767	1,726	1,691	1,752	1,790	1,752	1,810	1,695	1,840	1,722	1,702
Landfill Gas Flow to the Engines (MMBTU HHV)	941	954	921	937	919	950	929	903	939	941	939	949	883	935	930	895
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,768	1,768	1,721	1,782	1,767	1,767	1,726	1,691	1,752	1,790	1,752	1,810	1,695	1,840	1,722	1,702
Landfill Gas Total Flow (MMBTU HHV)	941	954	921	937	919	950	929	903	939	941	939	949	883	935	930	895
Average Methane Content (%)	52.6	53.3	52.9	51.9	51.4	53.1	53.2	52.8	53.0	52.0	53.0	51.8	51.5	50.2	53.4	52.0
Engine 1 Hours	24	24	24	24	24	24	24	23	24	24	24	24	24	24	24	22
Engine 2 Hours	24	24	22	24	24	24	24	23	24	24	24	24	19	24	24	24
Engine 3 Hours	24	24	24	24	24	24	24	23	24	24	24	24	24	24	24	22
Engine 4 Hours	24	24	23	24	24	24	24	23	24	24	24	24	24	24	24	22
Generator 1 Power Output (kWhr)	18,962	19,113	19,297	19,063	18,878	19,224	18,882	18,374	18,703	18,953	18,898	19,067	19,030	19,008	19,002	17,599
Generator 2 Power Output (kWhr)	18,439	18,614	17,225	18,506	18,213	18,690	18,348	17,878	18,184	18,408	18,353	18,524	13,597	17,478	16,570	18,150
Generator 3 Power Output (kWhr)	18,979	19,181	19,250	19,016	18,786	19,235	18,879	18,389	18,686	18,936	18,848	19,020	18,937	18,982	19,015	17,010
Generator 4 Power Output (kWhr)	18,506	18,675	17,620	18,597	18,329	18,739	18,395	17,894	18,231	18,477	18,420	18,585	18,532	18,262	18,532	16,998
Gross Power Output (kWhr)	75,707	76,320	74,125	75,879	74,893	76,588	75,230	73,196	74,475	75,439	75,236	75,893	70,664	74,106	73,490	70,081
Net Power Output (kWhr)	74,529	75,126	73,007	74,691	73,722	75,387	74,066	72,032	73,294	74,241	74,061	74,666	69,557	72,929	72,377	68,982
Power Sold as metered by NStar, (kWhr)	74,676	74,832	72,781	75,060	74,162	75,609	75,598	72,441	74,838	74,307	74,637	74,269	69,380	72,487	71,892	69,008
Offgrid RECs (kWhr)	1,178	1,194	1,118	1,188	1,171	1,201	1,164	1,164	1,181	1,198	1,175	1,227	1,107	1,177	1,113	1,099
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	790	796	804	794	787	801	787	799	779	790	787	794	793	792	792	800
Generator 2	768	776	783	771	759	779	765	777	758	767	765	772	716	728	690	756
Generator 3	791	799	802	792	783	801	787	800	779	789	785	793	789	791	792	773
Generator 4	771	778	766	775	764	781	766	778	760	770	768	774	772	761	772	773
Power output (kW average over 24-hrs)																
Facility Gross	3,154	3,180	3,089	3,162	3,121	3,191	3,135	3,182	3,103	3,143	3,135	3,162	2,944	3,088	3,062	2,920
Facility Net	3,105	3,130	3,042	3,112	3,072	3,141	3,086	3,132	3,054	3,093	3,086	3,111	2,898	3,039	3,016	2,874
In-plant load	49	50	47	50	49	50	49	51	49	50	49	51	46	49	46	46
Daily availability factor																
Facility	100%	100%	97%	100%	100%	100%	100%	100%	100%	100%	100%	100%	95%	100%	100%	94%
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%
Engine 2	100%	100%	92%	100%	100%	100%	100%	100%	100%	100%	100%	100%	79%	100%	100%	100%
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%
Engine 4	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%
Daily capacity factor																
Facility	96%	96%	94%	96%	95%	97%	95%	96%	94%	95%	95%	96%	89%	94%	93%	88%
Engine 1	96%	97%	97%	96%	95%	97%	95%	97%	94%	96%	95%	96%	96%	96%	96%	97%
Engine 2	93%	94%	95%	93%	92%	94%	93%	94%	92%	93%	93%	94%	87%	88%	84%	92%
Engine 3	96%	97%	97%	96%	95%	97%	95%	97%	94%	96%	95%	96%	96%	96%	96%	94%
Engine 4	93%	94%	93%	94%	93%	95%	93%	94%	92%	93%	93%	94%	94%	92%	94%	94%
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	24	48	72	96	120	144	168	191	215	239	263	287	311	335	359	383
Engine 1	24	48	72	96	120	144	168	191	215	239	263	287	311	335	359	381
Engine 2	24	48	70	94	118	142	166	189	213	237	261	285	304	328	352	376
Engine 3	24	48	72	96	120	144	168	191	215	239	263	287	311	335	359	381
Engine 4	24	48	71	95	119	143	167	190	214	238	262	286	310	334	358	380
Engine operating run hours total from 0 hours																
Engine 1	28,218	28,242	28,266	28,290	28,314	28,338	28,362	28,385	28,409	28,433	28,457	28,481	28,505	28,529	28,553	28,575
Engine 2	28,086	28,110	28,132	28,156	28,180	28,204	28,228	28,251	28,275	28,299	28,323	28,347	28,366	28,390	28,414	28,438
Engine 3	27,704	27,728	27,752	27,776	27,800	27,824	27,848	27,871	27,895	27,919	27,943	27,967	27,991	28,015	28,039	28,061
Engine 4	27,587	27,611	27,634	27,658	27,682	27,706	27,730	27,753	27,777	27,801	27,825	27,849	27,873	27,897	27,921	27,943
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%
Engine 2	100%	100%	97%	98%	98%	99%	99%	99%	99%	99%	99%	99%	98%	98%	98%	98%
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%
Engine 4	100%	100%	99%	99%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%	99%
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200
Engine 1	790	1,586	2,391	3,185	3,971	4,772	5,559	6,358	7,137	7,927	8,714	9,509	10,302	11,094	11,886	12,685
Engine 2	768	1,544	2,327	3,098	3,857	4,636	5,400	6,177	6,935	7,702	8,467	9,239	9,954	10,682	11,373	12,129
Engine 3	791	1,590	2,392	3,184	3,967	4,769	5,555	6,355	7,133	7,922	8,708	9,500	10,289	11,080	11,872	12,646
Engine 4	771	1,549	2,315	3,090	3,854	4,635	5,401	6,179	6,939	7,709	8,476	9,251	10,023	10,784	11,556	12,328
Cumulative capacity factor, %																
Engine 1	96%	96%	97%	97%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%
Engine 2	93%	94%	94%	94%	93%	94%	94%	94%	93%	93%	93%	93%	93%	92%	92%	92%
Engine 3	96%	96%	97%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%
Engine 4	93%	94%	94%	94%	93%	94%	94%	94%	93%	93%	93%	93%	93%	93%	93%	93%

MARCH 2009

		Sunday 3/1/2009	Monday 3/2/2009	Tuesday 3/3/2009	Wednesday 3/4/2009	Thursday 3/5/2009	Friday 3/6/2009	Saturday 3/7/2009	Sunday 3/8/2009	Monday 3/9/2009	Tuesday 3/10/2009	Wednesday 3/11/2009	Thursday 3/12/2009	Friday 3/13/2009	Saturday 3/14/2009	Sunday 3/15/2009	Monday 3/16/2009
Cumulative by Facility in month																	
	Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
	Actual cumulative engine run hours	96	192	285	381	477	573	669	761	857	953	1,049	1,145	1,236	1,332	1,428	1,518
	Cumulative Availability, %	100.0%	100.0%	99.0%	99.2%	99.4%	99.5%	99.6%	99.1%	99.2%	99.3%	99.3%	99.4%	99.0%	99.1%	99.2%	98.8%
	Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	630,300	709,500	788,700	867,900	947,100	1,026,300	1,105,500	1,184,700	1,263,900
	Actual cumulative gross output, kWhr	75,707	152,027	226,152	302,031	376,924	453,512	528,742	601,938	676,413	751,852	827,088	902,981	973,645	1,047,751	1,121,241	1,191,322
	Cumulative Capacity Factor	95.6%	96.0%	95.2%	95.3%	95.2%	95.4%	95.4%	95.5%	95.3%	95.3%	95.3%	95.3%	94.9%	94.8%	94.6%	94.3%
	Cumulative fuel input, MMBtu HHV	941	1,895	2,816	3,753	4,672	5,622	6,551	7,454	8,393	9,334	10,273	11,222	12,105	13,040	13,970	14,865
	Cumulative gross output, kWhr	75,707	152,027	226,152	302,031	376,924	453,512	528,742	601,938	676,413	751,852	827,088	902,981	973,645	1,047,751	1,121,241	1,191,322
Heat Rate																	
	Daily heat rate, Btu/kWe gross LHV	11,189	11,252	11,185	11,116	11,046	11,166	11,116	11,106	11,350	11,229	11,235	11,256	11,249	11,358	11,392	11,496
	Daily heat rate, Btu/kWe gross HHV	12,429	12,500	12,425	12,349	12,271	12,404	12,349	12,337	12,608	12,474	12,481	12,504	12,496	12,617	12,655	12,771
	Cumulative heat rate, Btu/kWe gross LHV	11,189	11,221	11,209	11,186	11,158	11,159	11,153	11,147	11,170	11,176	11,181	11,187	11,192	11,204	11,216	11,232
	Cumulative heat rate, Btu/kWe gross HHV	12,429	12,465	12,452	12,426	12,395	12,397	12,390	12,383	12,408	12,415	12,421	12,428	12,433	12,446	12,459	12,478
Cumulative by Facility starting Calendar Year																	
	Max cumulative available engine run hours	5,760	5,856	5,952	6,048	6,144	6,240	6,336	6,432	6,528	6,624	6,720	6,816	6,912	7,008	7,104	7,200
	Actual cumulative engine run hours	5,315	5,411	5,504	5,600	5,696	5,792	5,888	5,980	6,076	6,172	6,268	6,364	6,455	6,551	6,647	6,737
	Cumulative Availability, %	92.3%	92.4%	92.5%	92.6%	92.7%	92.8%	92.9%	93.0%	93.1%	93.2%	93.3%	93.4%	93.4%	93.5%	93.6%	93.6%
	Max cumulative gross output, kWhr	4,752,000	4,831,200	4,910,400	4,989,600	5,068,800	5,148,000	5,227,200	5,303,100	5,382,300	5,461,500	5,540,700	5,619,900	5,699,100	5,778,300	5,857,500	5,936,700
	Actual cumulative gross output, kWhr	4,101,404	4,177,724	4,251,849	4,327,728	4,402,621	4,479,209	4,554,439	4,627,635	4,702,110	4,777,549	4,852,785	4,928,678	4,999,342	5,073,448	5,146,938	5,217,019
	Cumulative Capacity Factor	86.3%	86.5%	86.6%	86.7%	86.9%	87.0%	87.1%	87.3%	87.4%	87.5%	87.6%	87.7%	87.7%	87.8%	87.9%	87.9%
	Cumulative fuel input, MMBtu HHV	50,951	51,905	52,826	53,763	54,682	55,632	56,561	57,464	58,403	59,344	60,283	61,232	62,115	63,050	63,980	64,875
	Cumulative gross output, kWhr	4,101,404	4,177,724	4,251,849	4,327,728	4,402,621	4,479,209	4,554,439	4,627,635	4,702,110	4,777,549	4,852,785	4,928,678	4,999,342	5,073,448	5,146,938	5,217,019
	Cumulative heat rate, Btu/kWe gross LHV	11,183	11,184	11,184	11,183	11,181	11,180	11,179	11,178	11,181	11,182	11,183	11,184	11,185	11,187	11,190	11,194
	Cumulative heat rate, Btu/kWe gross HHV	12,423	12,424	12,424	12,423	12,420	12,420	12,419	12,418	12,421	12,421	12,422	12,424	12,425	12,427	12,431	12,435
Service																	
	Engine 1																
	Engine 2																
	Engine 3			Montly Ops meeting					Daylight savings								49% CH4,
	Engine 4			Service					lose hour								2.2% O2
Oil - oil and filter change																	
Service - plugs, air filter, valve inspection and adjustment																	
NSTAR Power Reports																	
	Date	3/1/2009	3/2/2009	3/3/2009	3/4/2009	3/5/2009	3/6/2009	3/7/2009	Sunday 3/8/2009	Monday 3/9/2009	Tuesday 3/10/2009	Wednesday 3/11/2009	Thursday 3/12/2009	Friday 3/13/2009	Saturday 3/14/2009	Sunday 3/15/2009	Monday 3/16/2009
	Hour																
	1	3,110	3,109	3,075	3,196	3,069	3,113	3,147	3,150	3,149	3,067	3,111	3,111	3,067	3,036	2,994	2,998
	2	3,113	3,114	3,077	3,190	3,078	3,107	3,151	3,149	3,149	3,074	3,107	3,109	3,072	3,044	2,996	2,993
	3	3,108	3,108	3,074	3,192	3,071	3,113	3,148	3,149	3,149	3,068	3,112	3,112	3,067	3,047	2,992	2,998
	4	3,114	3,116	3,077	3,193	3,076	3,108	3,150	3,151	3,149	3,073	3,111	3,107	3,074	3,052	2,997	2,671
	5	3,108	3,109	3,072	3,188	3,073	3,112	3,151	3,151	3,146	3,068	3,109	3,112	3,067	3,050	2,995	675
	6	3,114	3,113	3,079	3,194	3,075	3,110	3,146	3,152	3,150	3,075	3,112	3,106	3,072	3,048	2,996	1,028
	7	3,108	3,112	3,072	3,187	3,077	3,112	3,152	3,152	3,151	3,069	3,108	3,109	3,071	3,046	2,996	2,784
	8	3,115	3,112	3,080	3,196	3,070	3,112	3,147	3,151	3,147	3,075	3,112	3,109	3,071	3,031	2,995	3,161
	9	3,109	3,116	3,121	3,157	3,071	3,135	3,151	3,149	3,148	3,091	3,109	3,109	3,069	3,028	2,998	3,151
	10	3,115	3,153	3,150	3,148	3,017	3,203	3,149	3,149	3,147	3,109	3,108	3,107	3,069	3,028	2,997	3,138
	11	3,110	3,192	2,685	3,143	3,031	3,205	3,149	3,149	3,145	3,108	3,107	3,107	3,068	3,023	2,996	3,130
	12	3,113	3,186	2,431	3,148	3,108	3,206	3,150	3,149	3,148	3,108	3,107	3,107	3,068	3,028	2,995	3,131
	13	3,111	3,191	2,485	3,132	3,114	3,207	3,148	3,148	3,148	3,107	3,107	3,106	3,068	3,032	2,994	3,014
	14	3,112	3,184	2,469	3,070	3,118	3,207	3,149	3,148	3,144	3,108	3,108	3,107	3,068	3,033	2,994	2,621
	15	3,112	3,190	3,115	3,075	3,119	3,203	3,151	3,149	3,122	3,108	3,108	3,107	2,718	3,032	2,995	3,150
	16	3,110	3,130	3,195	3,069	3,113	3,151	3,149	3,149	3,074	3,109	3,110	3,081	2,379	3,016	2,994	3,153
	17	3,114	3,077	3,188	3,076	3,110	3,153	3,150	3,149	3,070	3,112	3,112	3,073	2,394	2,972	2,995	3,154
	18	3,109	3,071	3,193	3,069	3,111	3,151	3,151	3,149	3,075	3,112	3,112	3,073	2,412	2,976	2,996	3,153
	19	3,116	3,079	3,190	3,077	3,110	3,149	3,152	3,150	3,069	3,112	3,111	3,073	2,407	2,983	2,996	3,153
	20	3,109	3,070	3,190	3,069	3,111	3,152	3,153	3,150	3,074	3,112	3,111	3,067	2,415	2,998	2,997	3,149
	21	3,116	3,078	3,193	3,074	3,112	3,151	3,152	3,150	3,069	3,112	3,112	3,072	2,535	2,997	2,998	3,153
	22	3,108	3,071	3,188	3,073	3,109	3,148	3,151	3,149	3,074	3,112	3,111	3,066	3,057	2,993	2,997	3,149
	23	3,111	3,076	3,195	3,070	3,112	3,151	3,151	3,149	3,068	3,107	3,111	3,071	3,046	2,998	2,997	3,150
	24	3,111	3,075	3,187	3,074	3,107	3,150	3,150	-	3,073	3,111	3,111	3,068	3,046	2,996	2,992	3,151
	TOTAL	74,676	74,832	72,781	75,060	74,162	75,609	75,598	72,441	74,838	74,307	74,637	74,269	69,380	72,487	71,892	69,008
	Cumulative Output Sold, kWhr	74,676	149,508	222,289	297,349	371,511	447,120	522,718	595,159	669,997	744,304	818,941	893,210	962,590	1,035,077	1,106,969	1,175,977
	Transformer and line efficiency	100.2%	99.6%	99.7%	100.5%	100.6%	100.3%	102.1%	100.6%	102.1%	100.1%	100.8%	99.5%	99.7%	99.4%	99.3%	100.0%
	Hourly average	3,112	3,118	3,033	3,128	3,090	3,150	3,150	3,018	3,118	3,096	3,110	3,095	2,891	3,020	2,996	2,875

MARCH 2009

MARCH 2009																
CNBE Daily Reports Summary Data																
	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	
	3/17/2009	3/18/2009	3/19/2009	3/20/2009	3/21/2009	3/22/2009	3/23/2009	3/24/2009	3/25/2009	3/26/2009	3/27/2009	3/28/2009	3/29/2009	3/30/2009	3/31/2009	TOTAL
Landfill Gas Flow to the Engines (KSCF)	1,846	1,847	1,805	1,813	1,764	1,734	1,704	1,812	1,843	1,811	1,732	1,745	1,713	1,697	1,720	54,639
Landfill Gas Flow to the Engines (MMBTU HHV)	968	960	937	931	908	910	905	942	948	948	906	908	920	921	902	28,779
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,846	1,847	1,805	1,813	1,764	1,734	1,704	1,812	1,843	1,811	1,732	1,745	1,713	1,697	1,720	54,639
Landfill Gas Total Flow (MMBTU HHV)	968	960	937	931	908	910	905	942	948	948	906	908	920	921	902	28,779
Average Methane Content (%)	51.8	51.4	51.3	50.7	50.9	51.9	52.5	51.4	50.8	51.7	51.7	51.4	53.1	53.6	51.8	52.0
Engine 1 Hours	24	24	24	24	24	24	22	24	24	24	24	24	24	24	24	739
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	736
Engine 3 Hours	24	24	24	24	24	24	23	24	24	24	24	24	24	24	24	740
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	740
Generator 1 Power Output (kWhr)	19,433	19,220	18,767	18,667	18,254	18,282	17,417	19,034	18,911	18,654	18,156	18,272	18,312	18,249	18,131	579,812
Generator 2 Power Output (kWhr)	18,849	18,681	18,239	18,150	17,761	17,754	18,279	18,426	18,459	18,161	17,670	17,799	17,815	17,733	17,646	556,599
Generator 3 Power Output (kWhr)	19,416	19,234	18,782	18,675	18,267	18,284	17,512	18,716	18,921	18,674	18,187	18,322	18,338	18,248	18,159	578,884
Generator 4 Power Output (kWhr)	18,910	18,715	18,293	18,197	17,807	17,822	18,331	18,487	18,679	18,300	17,691	17,796	17,855	17,773	17,676	565,124
Gross Power Output (kWhr)	76,894	76,387	74,709	74,345	72,721	72,801	72,128	75,289	75,646	74,434	72,364	72,782	72,929	72,644	72,225	2,299,620
Net Power Output (kWhr)	75,644	75,128	73,487	73,102	71,553	71,646	71,015	73,998	74,299	73,135	71,147	71,678	71,827	71,569	71,097	2,262,992
Power Sold as metered by NStar, (kWhr)	75,558	74,828	73,982	72,911	71,818	71,841	70,766	73,601	74,195	72,639	71,753	71,882	71,915	72,091	71,850	2,267,607
Offgrid RECs (kWhr)	1,250	1,259	1,222	1,243	1,168	1,155	1,113	1,291	1,347	1,299	1,217	1,104	1,102	1,075	1,128	36,628
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	810	801	782	778	761	762	792	793	788	777	757		763	760	755	
Generator 2	785	778	760	756	740	740	762	768	769	757	736	742	742	739	735	
Generator 3	809	801	783	778	761	762	761	780	788	778	758	763	764	760	757	
Generator 4	788	780	762	758	742	743	764	770	778	763	737	742	744	741	737	
Power output (kW average over 24-hrs)																
Facility Gross	3,204	3,183	3,113	3,098	3,030	3,033	3,005	3,137	3,152	3,101	3,015	3,033	3,039	3,027	3,009	
Facility Net	3,152	3,130	3,062	3,046	2,981	2,985	2,959	3,083	3,096	3,047	2,964	2,987	2,993	2,982	2,962	
In-plant load	52	52	51	52	49	48	46	54	56	54	51	46	46	45	47	
Daily availability factor																
Facility	100%	100%	100%	100%	100%	100%	97%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																
Facility	97%	96%	94%	94%	92%	92%	91%	95%	96%	94%	91%	92%	92%	92%	91%	
Engine 1	98%	97%	95%	94%	92%	92%	96%	96%	96%	94%	92%	92%	92%	92%	92%	
Engine 2	95%	94%	92%	92%	90%	90%	93%	93%	92%	89%	89%	90%	90%	89%	89%	
Engine 3	98%	97%	95%	94%	92%	92%	92%	95%	96%	94%	92%	93%	93%	92%	92%	
Engine 4	96%	95%	92%	92%	90%	90%	93%	93%	94%	92%	89%	90%	90%	90%	89%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	407	431	455	479	503	527	551	575	599	623	647	671	695	719	743	
Engine 1	405	429	453	477	501	525	547	571	595	619	643	667	691	715	739	
Engine 2	400	424	448	472	496	520	544	568	592	616	640	664	688	712	736	
Engine 3	405	429	453	477	501	525	548	572	596	620	644	668	692	716	740	
Engine 4	404	428	452	476	500	524	548	572	596	620	644	668	692	716	740	
Engine operating run hours total from 0 hours																
Engine 1	28,599	28,623	28,647	28,671	28,695	28,719	28,741	28,765	28,789	28,813	28,837	28,861	28,885	28,909	28,933	
Engine 2	28,462	28,486	28,510	28,534	28,558	28,582	28,606	28,630	28,654	28,678	28,702	28,726	28,750	28,774	28,798	
Engine 3	28,085	28,109	28,133	28,157	28,181	28,205	28,228	28,252	28,276	28,300	28,324	28,348	28,372	28,396	28,420	
Engine 4	27,967	27,991	28,015	28,039	28,063	28,087	28,111	28,135	28,159	28,183	28,207	28,231	28,255	28,279	28,303	
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 2	98%	98%	98%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 3	100%	100%	100%	100%	100%	100%	99%	99%	99%	100%	100%	100%	100%	100%	100%	
Engine 4	99%	99%	99%	99%	99%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575	
Engine 1	13,495	14,296	15,078	15,856	16,616	17,378	18,170	18,963	19,751	20,528	21,285	22,046	22,809	23,569	24,325	
Engine 2	12,914	13,693	14,453	15,209	15,949	16,689	17,450	18,218	18,987	19,744	20,480	21,222	21,964	22,703	23,438	
Engine 3	13,455	14,256	15,039	15,817	16,578	17,340	18,101	18,881	19,669	20,447	21,205	21,969	22,733	23,493	24,250	
Engine 4	13,116	13,896	14,658	15,417	16,158	16,901	17,665	18,435	19,213	19,976	20,713	21,455	22,199	22,939	23,676	
Cumulative capacity factor, %																
Engine 1	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	95%	95%	95%	95%	
Engine 2	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	
Engine 3	96%	96%	96%	96%	96%	96%	95%	95%	95%	95%	95%	95%	95%	95%	95%	
Engine 4	94%	94%	94%	93%	93%	93%	93%	93%	93%	93%	93%	93%	93%	93%	93%	

MARCH 2009

	Tuesday 3/17/2009	Wednesday 3/18/2009	Thursday 3/19/2009	Friday 3/20/2009	Saturday 3/21/2009	Sunday 3/22/2009	Monday 3/23/2009	Tuesday 3/24/2009	Wednesday 3/25/2009	Thursday 3/26/2009	Friday 3/27/2009	Saturday 3/28/2009	Sunday 3/29/2009	Monday 3/30/2009	Tuesday 3/31/2009	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976	
Actual cumulative engine run hours	1,614	1,710	1,806	1,902	1,998	2,094	2,187	2,283	2,379	2,475	2,571	2,667	2,763	2,859	2,955	
Cumulative Availability, %	98.9%	99.0%	99.0%	99.1%	99.1%	99.1%	99.0%	99.1%	99.1%	99.2%	99.2%	99.2%	99.2%	99.3%	99.3%	
Max cumulative gross output, kWhr	1,343,100	1,422,300	1,501,500	1,580,700	1,659,900	1,739,100	1,818,300	1,897,500	1,976,700	2,055,900	2,135,100	2,214,300	2,293,500	2,372,700	2,451,900	
Actual cumulative gross output, kWhr	1,268,216	1,344,603	1,419,312	1,493,657	1,566,378	1,639,179	1,711,307	1,786,596	1,862,242	1,936,676	2,009,040	2,081,822	2,154,751	2,227,395	2,299,620	
Cumulative Capacity Factor	94.4%	94.5%	94.5%	94.5%	94.4%	94.3%	94.1%	94.2%	94.2%	94.2%	94.1%	94.0%	94.0%	93.9%	93.8%	
Cumulative fuel input, MMBtu HHV	15,833	16,793	17,730	18,661	19,569	20,479	21,384	22,326	23,274	24,222	25,128	26,036	26,956	27,877	28,779	
Cumulative gross output, kWhr	1,268,216	1,344,603	1,419,312	1,493,657	1,566,378	1,639,179	1,711,307	1,786,596	1,862,242	1,936,676	2,009,040	2,081,822	2,154,751	2,227,395	2,299,620	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,332	11,313	11,290	11,273	11,240	11,252	11,295	11,263	11,281	11,465	11,271	11,231	11,356	11,413	11,242	
Daily heat rate, Btu/kWe gross HHV	12,589	12,568	12,542	12,523	12,486	12,500	12,547	12,512	12,532	12,736	12,520	12,476	12,615	12,678	12,489	
Cumulative heat rate, Btu/kWe gross LHV	11,238	11,243	11,245	11,247	11,246	11,247	11,249	11,249	11,251	11,259	11,259	11,258	11,261	11,266	11,266	
Cumulative heat rate, Btu/kWe gross HHV	12,484	12,489	12,492	12,493	12,493	12,493	12,496	12,496	12,498	12,507	12,507	12,506	12,510	12,516	12,515	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	7,296	7,392	7,488	7,584	7,680	7,776	7,872	7,968	8,064	8,160	8,256	8,352	8,448	8,544	8,640	
Actual cumulative engine run hours	6,833	6,929	7,025	7,121	7,217	7,313	7,406	7,502	7,598	7,694	7,790	7,886	7,982	8,078	8,174	
Cumulative Availability, %	93.7%	93.7%	93.8%	93.9%	94.0%	94.0%	94.1%	94.2%	94.2%	94.3%	94.4%	94.4%	94.5%	94.5%	94.6%	
Max cumulative gross output, kWhr	6,015,900	6,095,100	6,174,300	6,253,500	6,332,700	6,411,900	6,491,100	6,570,300	6,649,500	6,728,700	6,807,900	6,887,100	6,966,300	7,045,500	7,124,700	
Actual cumulative gross output, kWhr	5,293,913	5,370,300	5,445,009	5,519,354	5,592,075	5,664,876	5,737,004	5,812,293	5,887,939	5,962,373	6,034,737	6,107,519	6,180,448	6,253,092	6,325,317	
Cumulative Capacity Factor	88.0%	88.1%	88.2%	88.3%	88.3%	88.3%	88.4%	88.5%	88.5%	88.6%	88.6%	88.7%	88.7%	88.8%	88.8%	
Cumulative fuel input, MMBtu HHV	65,843	66,803	67,740	68,671	69,579	70,489	71,394	72,336	73,284	74,232	75,138	76,046	76,966	77,887	78,789	
Cumulative gross output, kWhr	5,293,913	5,370,300	5,445,009	5,519,354	5,592,075	5,664,876	5,737,004	5,812,293	5,887,939	5,962,373	6,034,737	6,107,519	6,180,448	6,253,092	6,325,317	
Cumulative heat rate, Btu/kWe gross LHV	11,196	11,198	11,199	11,200	11,201	11,201	11,202	11,203	11,204	11,208	11,208	11,209	11,210	11,213	11,213	
Cumulative heat rate, Btu/kWe gross HHV	12,437	12,439	12,441	12,442	12,442	12,443	12,444	12,445	12,446	12,450	12,451	12,451	12,453	12,456	12,456	
Service																
Engine 1							Service									
Engine 2																
Engine 3							Service									
Engine 4								Calibration								
Oil - oil and filter change							Change out	Tedlar bag sample								
Service - plugs, air filter, valve inspection and adjust							crankcase filters									
NSTAR Power Reports																
Date	3/17/2009	3/18/2009	3/19/2009	3/20/2009	3/21/2009	3/22/2009	3/23/2009	3/24/2009	3/25/2009	3/26/2009	3/27/2009	3/28/2009	3/29/2009	3/30/2009	3/31/2009	TOTAL
Hour																
1	3,149	3,147	3,110	3,064	2,991	2,993	2,992	3,080	3,065	3,095	2,987	2,996	2,995	2,994	2,993	
2	3,150	3,145	3,111	3,071	2,991	2,993	2,987	3,074	3,065	3,099	2,993	2,996	2,996	2,999	2,998	
3	3,149	3,145	3,110	3,065	2,994	2,996	2,998	3,081	3,069	3,096	2,989	2,992	2,996	2,998	2,998	
4	3,148	3,145	3,109	3,071	2,990	2,990	2,991	3,077	3,062	3,097	2,985	2,997	2,996	2,999	2,993	
5	3,152	3,146	3,111	3,065	2,995	2,996	2,995	3,078	3,070	3,102	2,991	2,998	2,995	2,999	2,999	
6	3,147	3,144	3,112	3,069	2,993	2,990	2,995	3,079	3,063	3,094	2,983	2,997	2,996	2,995	2,994	
7	3,153	3,145	3,110	3,067	2,991	2,995	2,992	3,077	3,068	3,102	2,989	2,994	2,996	2,999	2,999	
8	3,146	3,145	3,109	3,067	2,995	2,993	2,999	3,082	3,065	3,098	2,987	2,998	2,995	2,999	2,998	
9	3,149	3,099	3,080	3,068	2,990	2,995	3,056	3,065	3,069	3,028	2,983	2,997	2,998	2,997	2,993	
10	3,147	3,087	3,067	3,066	2,994	2,991	2,909	3,070	3,104	2,994	2,986	2,996	2,994	3,015	2,990	
11	3,147	3,086	3,067	3,067	2,993	2,994	2,079	2,858	3,132	2,985	2,988	2,994	2,997	3,032	2,989	
12	3,146	3,087	3,066	3,066	2,993	2,995	1,788	3,120	3,126	2,986	2,982	2,993	2,997	3,033	2,989	
13	3,145	3,101	3,067	3,066	2,992	2,995	2,898	3,126	3,126	2,986	2,987	2,993	2,997	3,031	2,988	
14	3,146	3,107	3,067	3,066	2,991	2,994	3,168	3,096	3,126	2,987	2,986	2,994	2,997	3,029	2,989	
15	3,146	3,106	3,067	3,050	2,992	2,994	3,165	3,065	3,121	2,987	2,988	2,994	2,997	3,010	2,989	
16	3,148	3,108	3,066	2,993	2,993	2,995	3,110	3,061	3,094	2,989	2,993	2,994	2,997	2,995	2,992	
17	3,149	3,111	3,072	2,993	2,993	2,995	3,083	3,068	3,098	2,991	2,994	2,994	2,996	2,996	2,994	
18	3,151	3,111	3,072	2,989	2,994	2,995	3,083	3,060	3,096	2,986	2,994	2,995	2,996	2,996	2,995	
19	3,151	3,111	3,066	2,993	2,992	2,990	3,080	3,064	3,097	2,990	2,994	2,995	2,996	2,996	2,995	
20	3,151	3,111	3,071	2,989	2,991	2,996	3,083	3,060	3,090	2,986	2,995	2,995	2,997	2,996	2,995	
21	3,151	3,111	3,066	2,989	2,990	2,990	3,077	3,062	3,096	2,987	2,995	2,995	2,998	2,996	2,995	
22	3,144	3,110	3,070	2,994	2,996	2,996	3,083	3,068	3,099	2,992	2,995	2,996	2,998	2,996	2,995	
23	3,148	3,110	3,065	2,989	2,989	2,988	3,077	3,063	3,094	2,987	2,994	2,995	2,998	2,993	2,995	
24	3,145	3,110	3,071	2,994	2,995	2,992	3,078	3,067	3,100	2,995	2,995	2,994	2,998	2,998	2,995	
TOTAL	75,558	74,828	73,982	72,911	71,818	71,841	70,766	73,601	74,195	72,639	71,753	71,882	71,915	72,091	71,850	
Cumulative Output Sold, kWhr	1,251,535	1,326,363	1,400,345	1,473,256	1,545,074	1,616,915	1,687,681	1,761,282	1,835,477	1,908,116	1,979,869	2,051,751	2,123,666	2,195,757	2,267,607	
Transformer and line efficiency	99.9%	99.6%	100.7%	99.7%	100.4%	100.3%	99.6%	99.5%	99.9%	100.9%	100.9%	100.3%	100.1%	100.7%	101.1%	0.0%
Hourly average	3,148	3,118	3,083	3,038	2,992	2,993	2,949	3,067	3,091	3,027	2,990	2,995	2,996	3,004	2,994	3,048

APRIL 2009																	
CNBE Daily Reports Summary Data																	
	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	
	4/1/2009	4/2/2009	4/3/2009	4/4/2009	4/5/2009	4/6/2009	4/7/2009	4/8/2009	4/9/2009	4/10/2009	4/11/2009	4/12/2009	4/13/2009	4/14/2009	4/15/2009	4/16/2009	
Landfill Gas Flow to the Engines (KSCF)	1,754	1,720	1,675	1,696	1,744	1,744	1,597	1,317	1,279	1,309	1,348	1,321	1,312	1,305	1,322	1,341	
Landfill Gas Flow to the Engines (MMBTU HHV)	913	911	913	922	925	953	885	760	727	745	765	755	751	738	752	749	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	378	334	420	383	387	390	360	330	298	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	190	180	212	205	211	218	201	185	170	
Landfill Gas Total Flow (KSCF)	1,754	1,720	1,675	1,696	1,744	1,744	1,597	1,694	1,613	1,730	1,731	1,707	1,702	1,665	1,652	1,640	
Landfill Gas Total Flow (MMBTU HHV)	913	911	913	922	925	953	885	950	907	957	970	966	969	939	937	919	
Average Methane Content (%)	51.4	52.3	53.9	53.7	52.4	54.0	54.7	55.4	55.6	54.7	55.4	55.9	56.2	55.8	56.1	55.4	
Engine 1 Hours	24	24	24	24	24	25	24	24	24	24	24	24	24	24	24	24	
Engine 2 Hours	24	24	24	24	24	25	22	24	24	24	24	24	24	24	24	24	
Engine 3 Hours	24	24	24	24	24	25	24	24	24	24	24	24	24	24	24	24	
Engine 4 Hours	24	24	24	24	24	20	18	-	-	-	-	-	-	-	-	-	
Generator 1 Power Output (kWhr)	18,349	18,193	18,194	18,259	18,537	19,892	18,814	19,884	19,028	19,306	19,521	19,636	19,647	19,651	19,474	19,380	
Generator 2 Power Output (kWhr)	17,832	17,685	17,683	17,803	18,089	19,382	16,141	18,728	18,211	18,646	18,753	18,864	18,741	18,658	18,734	18,668	
Generator 3 Power Output (kWhr)	18,318	18,182	18,192	18,334	18,594	19,817	18,868	19,705	18,839	19,170	19,332	19,445	19,418	19,423	19,472	19,506	
Generator 4 Power Output (kWhr)	17,894	17,720	17,735	17,808	18,071	15,257	13,167	-	-	-	-	-	-	-	-	-	
Gross Power Output (kWhr)	73,025	72,463	72,480	72,775	73,864	74,927	67,567	58,820	56,445	57,451	58,037	58,354	58,419	58,432	57,992	57,790	
Net Power Output (kWhr)	71,876	71,301	71,341	71,679	72,736	73,797	66,508	58,121	55,687	56,653	57,253	57,605	57,634	57,640	57,187	56,939	
Power Sold as metered by NStar, (kWhr)	71,843	71,257	71,688	72,390	72,351	70,168	67,195	58,246	56,202	57,283	57,515	57,533	57,476	57,446	57,618	57,691	
Offgrid RECs (kWhr)	1,149	1,162	1,139	1,096	1,128	1,130	1,059	699	758	798	784	749	785	792	805	851	
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	765	758	758	761	772	796	784	829	793	804	813	818	819	819	811	808	
Generator 2	743	737	737	742	754	775	734	780	777	777	781	786	781	777	781	778	
Generator 3	763	758	758	764	775	793	786	821	785	799	806	810	809	809	811	813	
Generator 4	746	738	739	742	753	763	732	-	-	-	-	-	-	-	-	-	
Power output (kW average over 24-hrs)																	
Facility Gross	3,043	3,019	3,020	3,032	3,078	3,122	2,815	2,451	2,352	2,394	2,418	2,431	2,434	2,435	2,416	2,408	
Facility Net	2,995	2,971	2,973	2,987	3,031	3,075	2,771	2,422	2,320	2,361	2,386	2,400	2,401	2,402	2,383	2,372	
In-plant load	48	48	47	46	47	47	44	29	32	33	33	31	33	33	34	35	
Daily availability factor																	
Facility	100%	100%	100%	100%	100%	99%	92%	75%	75%	75%	75%	75%	75%	75%	75%	75%	
Engine 1	100%	100%	100%	100%	100%	104%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	104%	92%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	104%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	83%	75%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
Daily capacity factor																	
Facility	92%	91%	92%	92%	93%	95%	85%	74%	71%	73%	73%	74%	74%	74%	73%	73%	
Engine 1	93%	92%	92%	92%	94%	96%	95%	100%	99%	98%	99%	99%	99%	99%	98%	98%	
Engine 2	90%	89%	89%	90%	91%	94%	89%	95%	92%	94%	95%	95%	95%	94%	95%	94%	
Engine 3	93%	92%	92%	93%	94%	96%	95%	100%	95%	97%	98%	98%	98%	98%	98%	99%	
Engine 4	90%	89%	90%	90%	91%	92%	89%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	
Engine 1	24	48	72	96	120	145	169	193	217	241	265	289	313	337	361	385	
Engine 2	24	48	72	96	120	145	167	191	215	239	263	287	311	335	359	383	
Engine 3	24	48	72	96	120	145	169	193	217	241	265	289	313	337	361	385	
Engine 4	24	48	72	96	120	140	158	158	158	158	158	158	158	158	158	158	
Engine operating run hours total from 0 hours																	
Engine 1	28,957	28,981	29,005	29,029	29,053	29,078	29,102	29,126	29,150	29,174	29,198	29,222	29,246	29,270	29,294	29,318	
Engine 2	28,822	28,846	28,870	28,894	28,918	28,943	28,965	28,989	29,013	29,037	29,061	29,085	29,109	29,133	29,157	29,181	
Engine 3	28,444	28,468	28,492	28,516	28,540	28,565	28,589	28,613	28,637	28,661	28,685	28,709	28,733	28,757	28,781	28,805	
Engine 4	28,327	28,351	28,375	28,399	28,423	28,443	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	
Cumulative availability, %																	
Engine 1	100%	100%	100%	100%	100%	101%	101%	101%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	101%	99%	99%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	101%	101%	101%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	97%	94%	82%	73%	66%	60%	55%	51%	47%	44%	41%	
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200	
Engine 1	765	1,523	2,281	3,041	3,814	4,610	5,393	6,222	7,015	7,819	8,633	9,451	10,269	11,088	11,900	12,707	
Engine 2	743	1,480	2,217	2,958	3,712	4,487	5,221	6,001	6,760	7,537	8,319	9,105	9,885	10,663	11,443	12,221	
Engine 3	763	1,521	2,279	3,043	3,817	4,610	5,396	6,217	7,002	7,801	8,607	9,417	10,226	11,035	11,847	12,659	
Engine 4	746	1,484	2,223	2,965	3,718	4,481	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	
Cumulative capacity factor, %																	
Engine 1	93%	92%	92%	92%	92%	93%	93%	94%	94%	95%	95%	95%	96%	96%	96%	96%	
Engine 2	90%	90%	90%	90%	90%	91%	90%	91%	91%	91%	92%	92%	92%	92%	92%	93%	
Engine 3	93%	92%	92%	92%	93%	93%	93%	94%	94%	95%	95%	95%	96%	96%	96%	96%	
Engine 4	90%	90%	90%	90%	90%	91%	90%	79%	70%	63%	57%	53%	49%	45%	42%	39%	

APRIL 2009

		Wednesday 4/1/2009	Thursday 4/2/2009	Friday 4/3/2009	Saturday 4/4/2009	Sunday 4/5/2009	Monday 4/6/2009	Tuesday 4/7/2009	Wednesday 4/8/2009	Thursday 4/9/2009	Friday 4/10/2009	Saturday 4/11/2009	Sunday 4/12/2009	Monday 4/13/2009	Tuesday 4/14/2009	Wednesday 4/15/2009	Thursday 4/16/2009
Cumulative by Facility in month																	
Max cumulative available engine run hours		96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
Actual cumulative engine run hours		96	192	288	384	480	575	663	735	807	879	951	1,023	1,095	1,167	1,239	1,311
Cumulative Availability, %		100.0%	100.0%	100.0%	100.0%	100.0%	99.8%	98.7%	95.7%	93.4%	91.6%	90.1%	88.8%	87.7%	86.8%	86.0%	85.4%
Max cumulative gross output, kWhr		79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200
Actual cumulative gross output, kWhr		73,025	145,488	217,968	290,743	364,607	439,534	507,101	565,921	622,366	679,817	737,854	796,208	854,627	913,059	971,051	1,028,841
Cumulative Capacity Factor		92.2%	91.8%	91.7%	91.8%	92.1%	92.5%	91.5%	89.3%	87.3%	85.8%	84.7%	83.8%	83.0%	82.3%	81.7%	81.2%
Cumulative fuel input, MMBtu HHV		913	1,824	2,737	3,659	4,584	5,537	6,422	7,182	7,909	8,654	9,419	10,174	10,925	11,663	12,415	13,164
Cumulative gross output, kWhr		73,025	145,488	217,968	290,743	364,607	439,534	507,101	565,921	622,366	679,817	737,854	796,208	854,627	913,059	971,051	1,028,841
Heat Rate																	
Daily heat rate, Btu/kWe gross LHV		11,255	11,317	11,339	11,405	11,267	11,450	11,791	11,631	11,594	11,673	11,866	11,647	11,572	11,370	11,673	11,667
Daily heat rate, Btu/kWe gross HHV		12,503	12,572	12,597	12,669	12,517	12,719	13,098	12,921	12,880	12,968	13,181	12,938	12,855	12,630	12,967	12,961
Cumulative heat rate, Btu/kWe gross LHV		11,255	11,286	11,304	11,329	11,317	11,339	11,399	11,423	11,439	11,459	11,491	11,502	11,507	11,498	11,509	11,518
Cumulative heat rate, Btu/kWe gross HHV		12,503	12,537	12,557	12,585	12,571	12,596	12,663	12,690	12,707	12,729	12,765	12,777	12,783	12,773	12,785	12,795
Cumulative by Facility starting Calendar Year																	
Max cumulative available engine run hours		8,736	8,832	8,928	9,024	9,120	9,216	9,312	9,408	9,504	9,600	9,696	9,792	9,888	9,984	10,080	10,176
Actual cumulative engine run hours		8,270	8,366	8,462	8,558	8,654	8,749	8,837	8,909	8,981	9,053	9,125	9,197	9,269	9,341	9,413	9,485
Cumulative Availability, %		94.7%	94.7%	94.8%	94.8%	94.9%	94.9%	94.9%	94.7%	94.5%	94.3%	94.1%	93.9%	93.7%	93.6%	93.4%	93.2%
Max cumulative gross output, kWhr		7,203,900	7,283,100	7,362,300	7,441,500	7,520,700	7,599,900	7,679,100	7,758,300	7,837,500	7,916,700	7,995,900	8,075,100	8,154,300	8,233,500	8,312,700	8,391,900
Actual cumulative gross output, kWhr		6,398,342	6,470,805	6,543,285	6,616,060	6,689,924	6,764,851	6,832,418	6,891,238	6,947,683	7,005,134	7,063,171	7,121,525	7,179,944	7,238,376	7,296,368	7,354,158
Cumulative Capacity Factor		88.8%	88.8%	88.9%	88.9%	89.0%	89.0%	89.0%	88.8%	88.6%	88.5%	88.3%	88.2%	88.1%	87.9%	87.8%	87.6%
Cumulative fuel input, MMBtu HHV		79,702	80,613	81,526	82,448	83,373	84,326	85,211	85,971	86,698	87,443	88,208	88,963	89,714	90,452	91,204	91,953
Cumulative gross output, kWhr		6,398,342	6,470,805	6,543,285	6,616,060	6,689,924	6,764,851	6,832,418	6,891,238	6,947,683	7,005,134	7,063,171	7,121,525	7,179,944	7,238,376	7,296,368	7,354,158
Cumulative heat rate, Btu/kWe gross LHV		11,213	11,215	11,216	11,218	11,219	11,221	11,227	11,230	11,233	11,234	11,242	11,245	11,248	11,249	11,252	11,256
Cumulative heat rate, Btu/kWe gross HHV		12,457	12,458	12,459	12,462	12,462	12,465	12,472	12,475	12,479	12,483	12,488	12,492	12,495	12,496	12,500	12,503
Service																	
Engine 1							Capacity test 2 to 6 PM.										
Engine 2								Service									
Engine 3																	
Engine 4							Repair radiator motor	Service					CNAInsurance	CarterCAT			
Oil - oil and filter change								E4 Connecting rod failure							CNAInsurance eng.		
Service - plugs, air filter, valve inspection and adjustment															Enginuity		
NSTAR Power Reports																	
Date		Wednesday 4/1/2009	Thursday 4/2/2009	Friday 4/3/2009	Saturday 4/4/2009	Sunday 4/5/2009	Monday 4/6/2009	Tuesday 4/7/2009	Wednesday 4/8/2009	Thursday 4/9/2009	Friday 4/10/2009	Saturday 4/11/2009	Sunday 4/12/2009	Monday 4/13/2009	Tuesday 4/14/2009	Wednesday 4/15/2009	Thursday 4/16/2009
Hour																	
1		2,996	2,994	2,956	3,016	3,018	3,015	3,072	2,430	2,428	2,378	2,394	2,398	2,398	2,397	2,395	2,410
2		2,992	2,994	2,956	3,016	3,018	3,015	3,073	2,430	2,428	2,378	2,394	2,398	2,397	2,397	2,394	2,409
3		2,996	2,990	2,956	3,015	3,018	3,015	3,072	2,430	2,427	2,378	2,394	2,398	2,397	2,397	2,395	2,408
4		2,993	2,993	2,956	3,016	3,017	3,015	3,072	2,431	2,428	2,379	2,394	2,398	2,398	2,397	2,395	2,408
5		2,997	2,994	2,957	3,017	3,018	3,016	3,072	2,430	2,428	2,379	2,394	2,398	2,397	2,398	2,397	2,408
6		2,993	2,994	2,957	3,017	3,019	3,016	3,072	2,430	2,427	2,379	2,394	2,398	2,397	2,397	2,397	2,409
7		2,998	2,994	2,957	3,017	3,018	3,018	3,072	2,430	2,427	2,378	2,394	2,398	2,398	2,398	2,398	2,410
8		2,992	2,994	2,957	3,017	3,017	3,017	3,072	2,431	2,426	2,378	2,395	2,399	2,398	2,397	2,398	2,409
9		2,996	2,991	2,958	3,016	3,016	2,373	2,648	2,428	2,420	2,375	2,395	2,399	2,397	2,393	2,392	2,405
10		2,991	2,957	2,969	3,017	3,013	2,326	2,427	2,423	2,419	2,390	2,395	2,398	2,394	2,388	2,389	2,401
11		2,991	2,952	2,970	3,015	3,012	2,400	2,398	2,424	1,486	2,390	2,396	2,396	2,392	2,389	2,388	2,398
12		2,991	2,952	2,980	3,014	3,012	2,404	2,706	2,424	2,368	2,389	2,398	2,394	2,390	2,402	2,398	2,398
13		2,991	2,952	3,003	3,015	3,013	2,404	3,183	2,423	2,368	2,389	2,397	2,394	2,389	2,388	2,405	2,397
14		2,991	2,951	3,014	3,015	3,010	2,786	3,158	2,423	1,974	2,390	2,398	2,394	2,389	2,388	2,404	2,397
15		2,991	2,952	3,014	3,015	3,012	3,232	3,003	2,423	2,371	2,391	2,398	2,395	2,389	2,389	2,403	2,397
16		2,993	2,955	3,015	3,015	3,013	3,229	2,939	2,425	2,372	2,391	2,398	2,394	2,391	2,390	2,402	2,399
17		2,995	2,956	3,014	3,016	3,013	3,227	2,955	2,425	2,374	2,394	2,398	2,394	2,392	2,390	2,405	2,403
18		2,994	2,956	3,014	3,017	3,013	3,226	3,057	2,426	2,375	2,394	2,399	2,398	2,394	2,395	2,408	2,403
19		2,996	2,956	3,013	3,016	3,014	3,089	3,071	2,425	2,375	2,393	2,399	2,399	2,395	2,408	2,403	2,403
20		2,991	2,956	3,013	3,017	3,014	3,067	2,256	2,426	2,375	2,394	2,398	2,398	2,396	2,394	2,407	2,404
21		2,996	2,956	3,015	3,018	3,014	3,070	1,888	2,427	2,375	2,394	2,399	2,399	2,395	2,394	2,409	2,405
22		2,994	2,956	3,014	3,018	3,012	3,069	2,080	2,427	2,376	2,394	2,398	2,398	2,398	2,395	2,408	2,404
23		2,993	2,956	3,015	3,017	3,013	3,069	2,420	2,428	2,377	2,394	2,398	2,399	2,397	2,396	2,410	2,403
24		2,992	2,956	3,015	3,018	3,014	3,070	2,429	2,427	2,378	2,394	2,398	2,398	2,397	2,395	2,409	2,403
TOTAL		71,843	71,257	71,688	72,390	72,351	70,168	67,195	58,246	56,202	57,283	57,515	57,533	57,476	57,446	57,618	57,691
Cumulative Output Sold, kWhr		71,843	143,100	214,788	287,178	359,529	429,697	496,892	555,138	611,340	668,623	726,138	783,671	841,147	898,593	956,211	1,013,902
Transformer and line efficiency		100.0%	99.9%	100.5%	101.0%	99.5%	95.1%	101.0%	100.2%	100.9%	101.1%	100.5%	99.9%	99.7%	99.7%	100.8%	101.3%
Hourly average		2,993	2,969	2,987	3,016	3,015	2,924	2,800	2,427	2,342	2,387	2,396	2,397	2,395	2,394	2,401	2,404

APRIL 2009																
CNBE Daily Reports Summary Data																
	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday		
	4/17/2009	4/18/2009	4/19/2009	4/20/2009	4/21/2009	4/22/2009	4/23/2009	4/24/2009	4/25/2009	4/26/2009	4/27/2009	4/28/2009	4/29/2009	4/30/2009	TOTAL	
Landfill Gas Flow to the Engines (KSCF)	1,353	1,319	1,305	1,271	1,217	1,273	1,293	1,308	1,298	1,283	1,300	1,265	1,287	1,299	41,858	Engine methane, %
Landfill Gas Flow to the Engines (MMBTU HHV)	763	736	726	715	694	733	732	738	738	722	728	719	721	728	23,357	55.14
Landfill Gas Flow to the Flare (KSCF)	266	285	304	323	341	360	379	397	416	435	441	436	431	382	7,663	Flare methane, %
Landfill Gas Flow to the Flare (MMBTU HHV)	154	164	175	186	197	207	218	228	239	250	253	251	249	224	4,295	55.38
Landfill Gas Total Flow (KSCF)	1,620	1,605	1,609	1,594	1,558	1,633	1,672	1,706	1,714	1,718	1,740	1,700	1,718	1,681	50,333	
Landfill Gas Total Flow (MMBTU HHV)	917	900	901	901	891	940	950	966	977	972	981	970	970	952	28,124	
Average Methane Content (%)	55.9	55.5	55.3	55.8	56.5	56.9	56.1	56.0	56.3	55.9	55.7	56.4	55.8	56.0	55.2	
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	721	
Engine 2 Hours	24	24	24	24	20	24	24	24	24	24	24	24	24	24	715	
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	23	24	24	720	
Engine 4 Hours	-	-	-	-	-	-	-	-	-	-	-	-	-	-	158	
Generator 1 Power Output (kWhr)	19,592	19,482	18,953	17,912	19,482	19,461	19,496	19,596	19,451	19,497	19,578	19,543	19,291	19,578	576,677	
Generator 2 Power Output (kWhr)	18,871	18,710	18,236	17,442	15,964	19,034	19,045	19,188	19,045	19,111	19,293	19,234	18,840	19,293	553,924	
Generator 3 Power Output (kWhr)	19,711	19,553	19,494	19,572	19,544	19,515	19,476	19,498	19,341	19,410	19,521	18,695	19,030	19,521	576,496	
Generator 4 Power Output (kWhr)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	117,652	
Gross Power Output (kWhr)	58,445	58,137	57,021	55,316	55,220	58,397	58,487	58,452	57,961	58,240	58,707	57,801	57,573	58,707	1,837,305	
Net Power Output (kWhr)	57,518	57,212	56,159	54,484	54,357	57,563	57,655	57,576	57,085	57,203	57,806	56,824	56,678	57,806	1,809,883	
Power Sold as metered by NStar, (kWhr)	57,594	57,603	56,726	54,761	54,815	58,061	57,923	57,775	57,765	57,635	57,672	56,883	57,614	57,990	1,814,719	
Offgrid RECs (kWhr)	927	925	862	832	863	834	832	876	876	1,037	901	977	895	901	27,422	
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	816	812	790	746	812	811	812	817	810	812	816	814	804	816		
Generator 2	786	780	760	727	798	793	794	800	794	796	804	801	785	804		
Generator 3	821	815	812	816	814	813	812	812	806	809	813	813	793	813		
Generator 4	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Power output (kW average over 24-hrs)																
Facility Gross	2,435	2,422	2,376	2,305	2,301	2,433	2,437	2,436	2,415	2,427	2,446	2,408	2,399	2,446		
Facility Net	2,397	2,384	2,340	2,270	2,265	2,398	2,402	2,399	2,379	2,383	2,409	2,368	2,362	2,409		
In-plant load	39	39	36	35	36	35	35	37	37	43	38	41	37	38		
Daily availability factor																
Facility	75%	75%	75%	75%	71%	75%	75%	75%	75%	75%	75%	74%	75%	75%		
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	100%	100%	100%	83%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%	100%	100%		
Engine 4	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%		
Daily capacity factor																
Facility	74%	73%	72%	70%	70%	74%	74%	74%	73%	74%	74%	73%	73%	74%		
Engine 1	99%	98%	96%	90%	98%	98%	98%	99%	98%	98%	99%	99%	99%	99%		
Engine 2	95%	94%	92%	88%	97%	96%	96%	97%	96%	97%	97%	97%	95%	97%		
Engine 3	100%	99%	98%	99%	98%	99%	98%	98%	98%	98%	99%	99%	96%	99%		
Engine 4	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%		
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	408	432	456	480	504	528	552	576	600	624	648	672	696	720		
Engine 1	409	433	457	481	505	529	553	577	601	625	649	673	697	721		
Engine 2	407	431	455	479	499	523	547	571	595	619	643	667	691	715		
Engine 3	409	433	457	481	505	529	553	577	601	625	649	672	696	720		
Engine 4	158	158	158	158	158	158	158	158	158	158	158	158	158	158		
Engine operating run hours total from 0 hours																
Engine 1	29,342	29,366	29,390	29,414	29,438	29,462	29,486	29,510	29,534	29,558	29,582	29,606	29,630	29,654		
Engine 2	29,205	29,229	29,253	29,277	29,297	29,321	29,345	29,369	29,393	29,417	29,441	29,465	29,489	29,513		
Engine 3	28,829	28,853	28,877	28,901	28,925	28,949	28,973	28,997	29,021	29,045	29,069	29,092	29,116	29,140		
Engine 4	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461	28,461		
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%		
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 4	39%	37%	35%	33%	31%	30%	29%	27%	26%	25%	24%	24%	23%	22%		
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750		
Engine 1	13,523	14,335	15,125	15,871	16,683	17,494	18,306	19,123	19,933	20,745	21,561	22,376	23,179	23,995		
Engine 2	13,008	13,787	14,547	15,274	16,072	16,865	17,659	18,458	19,252	20,048	20,852	21,653	22,438	23,242		
Engine 3	13,481	14,295	15,108	15,923	16,737	17,550	18,362	19,174	19,980	20,789	21,602	22,415	23,208	24,021		
Engine 4	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212	5,212		
Cumulative capacity factor, %																
Engine 1	96%	97%	96%	96%	96%	96%	96%	97%	97%	97%	97%	97%	97%	97%		
Engine 2	93%	93%	93%	93%	93%	93%	93%	93%	93%	93%	94%	94%	94%	94%		
Engine 3	96%	96%	96%	97%	97%	97%	97%	97%	97%	97%	97%	97%	97%	97%		
Engine 4	37%	35%	33%	32%	30%	29%	27%	26%	25%	24%	23%	23%	22%	21%		

	Friday 4/17/2009	Saturday 4/18/2009	Sunday 4/19/2009	Monday 4/20/2009	Tuesday 4/21/2009	Wednesday 4/22/2009	Thursday 4/23/2009	Friday 4/24/2009	Saturday 4/25/2009	Sunday 4/26/2009	Monday 4/27/2009	Tuesday 4/28/2009	Wednesday 4/29/2009	Thursday 4/30/2009	TOTAL	
Cumulative by Facility in month																
Max cumulative available engine run hours	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880		
Actual cumulative engine run hours	1,383	1,455	1,527	1,599	1,667	1,739	1,811	1,883	1,955	2,027	2,099	2,170	2,242	2,314		
Cumulative Availability, %	84.7%	84.2%	83.7%	83.3%	82.7%	82.3%	82.0%	81.7%	81.5%	81.2%	81.0%	80.7%	80.5%	80.3%		
Max cumulative gross output, kWhr	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000		
Actual cumulative gross output, kWhr	1,087,286	1,145,423	1,202,444	1,257,760	1,312,980	1,371,377	1,429,864	1,488,316	1,546,277	1,604,517	1,663,224	1,721,025	1,778,598	1,837,305		
Cumulative Capacity Factor	80.8%	80.3%	79.9%	79.4%	78.9%	78.7%	78.5%	78.3%	78.1%	77.9%	77.8%	77.6%	77.4%	77.3%		
Cumulative fuel input, MMBtu HHV	13,927	14,663	15,389	16,104	16,798	17,531	18,263	19,001	19,739	20,461	21,189	21,908	22,629	23,357		
Cumulative gross output, kWhr	1,087,286	1,145,423	1,202,444	1,257,760	1,312,980	1,371,377	1,429,864	1,488,316	1,546,277	1,604,517	1,663,224	1,721,025	1,778,598	1,837,305		
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,752	11,396	11,461	11,636	11,314	11,299	11,267	11,366	11,462	11,160	11,163	11,198	11,273	11,163		
Daily heat rate, Btu/kWe gross HHV	13,055	12,660	12,732	12,926	12,568	12,552	12,516	12,626	12,733	12,397	12,401	12,439	12,523	12,401		
Cumulative heat rate, Btu/kWe gross LHV	11,530	11,523	11,520	11,526	11,517	11,507	11,498	11,492	11,491	11,479	11,468	11,459	11,453	11,444		
Cumulative heat rate, Btu/kWe gross HHV	12,809	12,801	12,798	12,803	12,793	12,783	12,772	12,766	12,765	12,752	12,739	12,729	12,723	12,712		
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	10,272	10,368	10,464	10,560	10,656	10,752	10,848	10,944	11,040	11,136	11,232	11,328	11,424	11,520		
Actual cumulative engine run hours	9,557	9,629	9,701	9,773	9,841	9,913	9,985	10,057	10,129	10,201	10,273	10,344	10,416	10,488		
Cumulative Availability, %	93.0%	92.9%	92.7%	92.5%	92.4%	92.2%	92.0%	91.9%	91.7%	91.6%	91.5%	91.3%	91.2%	91.0%		
Max cumulative gross output, kWhr	8,471,100	8,550,300	8,629,500	8,708,700	8,787,900	8,867,100	8,946,300	9,025,500	9,104,700	9,183,900	9,263,100	9,342,300	9,421,500	9,500,700		
Actual cumulative gross output, kWhr	7,412,603	7,470,740	7,527,761	7,583,077	7,638,297	7,696,694	7,755,181	7,813,633	7,871,594	7,929,834	7,988,541	8,046,342	8,103,915	8,162,622		
Cumulative Capacity Factor	87.5%	87.4%	87.2%	87.1%	86.9%	86.8%	86.7%	86.6%	86.5%	86.3%	86.2%	86.1%	86.0%	85.9%		
Cumulative fuel input, MMBtu HHV	92,716	93,452	94,178	94,893	95,587	96,320	97,052	97,790	98,528	99,250	99,978	100,697	101,418	102,146		
Cumulative gross output, kWhr	7,412,603	7,470,740	7,527,761	7,583,077	7,638,297	7,696,694	7,755,181	7,813,633	7,871,594	7,929,834	7,988,541	8,046,342	8,103,915	8,162,622		
Cumulative heat rate, Btu/kWe gross LHV	11,260	11,261	11,261	11,265	11,265	11,265	11,266	11,266	11,267	11,266	11,266	11,266	11,266	11,265		
Cumulative heat rate, Btu/kWe gross HHV	12,508	12,509	12,511	12,514	12,514	12,514	12,514	12,515	12,517	12,516	12,515	12,515	12,515	12,514		
Service																
Engine 1																
Engine 2																
Engine 3				Head replacement												
Engine 4				torched valve												
Oil - oil and filter change	E4 shipped to			CarterCAT		PZ travel to							CarterCAT	CarterCAT		
	Carter CAT			starts rebuild E4		Carter CAT							complete E4	ship E4		
Service - plugs, air filter, valve inspection and adjustm																
NSTAR Power Reports																
Date	Friday 4/17/2009	Saturday 4/18/2009	Sunday 4/19/2009	Monday 4/20/2009	Tuesday 4/21/2009	Wednesday 4/22/2009	Thursday 4/23/2009	Friday 4/24/2009	Saturday 4/25/2009	Sunday 4/26/2009	Monday 4/27/2009	Tuesday 4/28/2009	Wednesday 4/29/2009	Thursday 4/30/2009	TOTAL	
Hour																
1	2,403	2,401	2,401	2,196	2,412	2,418	2,422	2,411	2,410	2,408	2,404	2,406	2,401	2,406		
2	2,403	2,402	2,402	2,196	2,412	2,418	2,423	2,411	2,411	2,410	2,405	2,407	2,402	2,406		
3	2,402	2,402	2,402	2,195	2,413	2,419	2,423	2,412	2,409	2,409	2,406	2,407	2,402	2,408		
4	2,402	2,402	2,402	2,195	2,414	2,419	2,422	2,412	2,409	2,407	2,406	2,407	2,402	2,409		
5	2,402	2,403	2,402	2,195	2,412	2,420	2,422	2,412	2,410	2,406	2,407	2,407	2,402	2,409		
6	2,402	2,402	2,402	2,195	2,412	2,421	2,419	2,412	2,409	2,406	2,410	2,407	2,402	2,409		
7	2,403	2,403	2,403	2,197	2,412	2,422	2,416	2,413	2,409	2,405	2,410	2,407	2,403	2,410		
8	2,403	2,402	2,402	2,196	2,412	2,422	2,420	2,412	2,409	2,405	2,408	2,404	2,404	2,409		
9	2,400	2,401	2,403	2,194	1,752	2,418	2,420	2,406	2,409	2,402	2,403	2,396	2,401	2,400		
10	2,398	2,398	2,402	2,194	1,609	2,415	2,417	2,404	2,407	2,400	2,399	1,780	2,399	2,408		
11	2,396	2,398	2,401	2,192	1,605	2,414	2,415	2,402	2,406	2,399	2,398	2,305	2,398	2,423		
12	2,394	2,397	2,400	2,192	1,623	2,414	2,413	2,402	2,404	2,397	2,398	2,392	2,399	2,421		
13	2,394	2,398	2,400	2,192	2,336	2,415	2,404	2,401	2,403	2,395	2,398	2,390	2,398	2,421		
14	2,394	2,398	2,400	2,193	2,414	2,416	2,404	2,401	2,404	2,392	2,397	2,392	2,396	2,420		
15	2,394	2,396	2,399	2,326	2,414	2,416	2,404	2,401	2,403	2,393	2,397	2,393	2,397	2,420		
16	2,395	2,398	2,400	2,414	2,417	2,419	2,406	2,404	2,404	2,394	2,398	2,394	2,397	2,420		
17	2,399	2,399	2,400	2,414	2,418	2,421	2,408	2,405	2,404	2,395	2,401	2,397	2,399	2,424		
18	2,401	2,399	2,401	2,414	2,418	2,422	2,408	2,405	2,405	2,396	2,402	2,398	2,400	2,423		
19	2,401	2,401	2,401	2,412	2,418	2,422	2,408	2,406	2,406	2,400	2,401	2,398	2,401	2,424		
20	2,402	2,401	2,320	2,412	2,418	2,422	2,408	2,407	2,406	2,401	2,402	2,398	2,400	2,424		
21	2,401	2,401	2,196	2,412	2,420	2,422	2,410	2,408	2,406	2,404	2,403	2,399	2,402	2,424		
22	2,402	2,400	2,195	2,412	2,418	2,422	2,410	2,409	2,407	2,404	2,406	2,399	2,402	2,424		
23	2,401	2,400	2,196	2,411	2,418	2,422	2,410	2,410	2,407	2,403	2,406	2,400	2,402	2,424		
24	2,402	2,401	2,196	2,412	2,418	2,422	2,411	2,409	2,408	2,404	2,407	2,400	2,405	2,424		
TOTAL	57,594	57,603	56,726	54,761	54,815	58,061	57,923	57,775	57,765	57,635	57,672	56,883	57,614	57,990		
Cumulative Output Sold, kWhr	1,071,496	1,129,099	1,185,825	1,240,586	1,295,401	1,353,462	1,411,385	1,469,160	1,526,925	1,584,560	1,642,232	1,699,115	1,756,729	1,814,719		
Transformer and line efficiency	100.1%	100.7%	101.0%	100.5%	100.8%	100.9%	100.5%	100.3%	101.2%	100.8%	99.8%	100.1%	101.7%	100.3%	0.0%	
Hourly average	2,400	2,400	2,364	2,282	2,284	2,419	2,413	2,407	2,407	2,401	2,403	2,370	2,401	2,416	2,520	

MAY 2009 CNBE Daily Reports Summary Data																
	Friday 5/1/2009	Saturday 5/2/2009	Sunday 5/3/2009	Monday 5/4/2009	Tuesday 5/5/2009	Wednesday 5/6/2009	Thursday 5/7/2009	Friday 5/8/2009	Saturday 5/9/2009	Sunday 5/10/2009	Monday 5/11/2009	Tuesday 5/12/2009	Wednesday 5/13/2009	Thursday 5/14/2009	Friday 5/15/2009	Saturday 5/16/2009
Landfill Gas Flow to the Engines (KSCF)	1,320	1,340	1,326	1,326	1,351	1,385	1,489	1,579	1,544	1,553	1,380	1,324	1,339	1,329	1,290	1,313
Landfill Gas Flow to the Engines (MMBTU HHV)	738	744	724	725	745	784	865	906	875	880	785	749	747	740	718	734
Landfill Gas Flow to the Flare (KSCF)	382	383	384	386	387	323	194	-	-	-	307	274	305	305	305	305
Landfill Gas Flow to the Flare (MMBTU HHV)	224	224	225	226	227	180	108	-	-	-	181	159	175	175	175	175
Landfill Gas Total Flow (KSCF)	1,702	1,723	1,710	1,712	1,739	1,708	1,683	1,579	1,544	1,553	1,687	1,598	1,644	1,634	1,595	1,618
Landfill Gas Total Flow (MMBTU HHV)	962	968	949	951	972	964	973	906	875	880	966	908	922	915	893	909
Average Methane Content (%)	55.8	55.5	54.9	54.9	55.2	55.7	57.1	56.7	56.0	56.0	56.6	56.2	55.4	55.3	55.3	55.5
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	7	-	18	24	24	24
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	-	9	24
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	15	-
Engine 4 Hours	-	-	-	-	-	9	24	24	24	24	24	24	24	24	24	24
Generator 1 Power Output (kWhr)	19,336	19,523	19,544	19,577	19,272	19,276	19,158	19,003	17,038	16,896	5,039	19	13,895	19,657	19,335	19,552
Generator 2 Power Output (kWhr)	19,155	19,333	17,586	18,059	19,387	19,326	18,938	18,661	16,603	16,402	18,339	19,386	5,767	-	7,044	19,005
Generator 3 Power Output (kWhr)	19,478	19,700	19,762	19,617	19,446	19,431	19,153	18,881	18,040	18,450	19,214	19,817	19,819	19,930	11,870	-
Generator 4 Power Output (kWhr)	-	-	-	-	-	3,407	10,676	15,749	17,882	18,297	18,872	19,317	19,362	19,330	19,073	19,347
Gross Power Output (kWhr)	58,367	58,965	57,333	57,702	58,469	61,759	68,492	72,807	69,986	70,542	61,738	58,721	59,086	59,145	57,578	58,221
Net Power Output (kWhr)	57,412	57,964	56,408	56,705	57,430	60,693	67,359	71,523	68,791	69,328	60,664	57,731	57,938	58,058	56,483	57,106
Power Sold as metered by NStar, (kWhr)	58,236	58,230	56,552	56,768	57,591	61,209	68,936	72,426	70,615	69,492	61,373	58,060	57,965	58,129	56,911	57,269
Offgrid RECs (kWhr)	955	1,001	925	997	1,039	1,066	1,133	1,284	1,195	1,214	1,074	990	1,148	1,087	1,095	1,115
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	806	813	814	816	803	803	798	792	710	704	720	-	772	819	806	815
Generator 2	798	806	733	752	808	805	789	778	692	683	764	808	240	-	783	792
Generator 3	812	821	823	817	810	810	798	787	752	769	801	826	826	830	791	-
Generator 4	-	-	-	-	-	379	445	656	745	762	786	805	807	805	795	806
Power output (kW average over 24-hrs)																
Facility Gross	2,432	2,457	2,389	2,404	2,436	2,573	2,854	3,034	2,916	2,939	2,572	2,447	2,462	2,464	2,399	2,426
Facility Net	2,392	2,415	2,350	2,363	2,393	2,529	2,807	2,980	2,866	2,889	2,528	2,405	2,414	2,419	2,353	2,379
In-plant load	40	42	39	42	43	44	47	54	50	51	45	41	48	45	46	46
Daily availability factor																
Facility	75%	75%	75%	75%	75%	84%	100%	100%	100%	100%	82%	75%	94%	75%	75%	75%
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	29%	0%	75%	100%	100%	100%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	0%	38%	100%
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	63%	0%
Engine 4	0%	0%	0%	0%	0%	38%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Daily capacity factor																
Facility	74%	74%	72%	73%	74%	78%	86%	92%	88%	89%	78%	74%	75%	75%	73%	74%
Engine 1	98%	99%	99%	99%	97%	97%	97%	96%	86%	85%	87%	0%	94%	99%	98%	99%
Engine 2	97%	98%	89%	91%	98%	98%	96%	94%	84%	83%	93%	98%	29%	0%	95%	96%
Engine 3	98%	99%	100%	99%	98%	98%	97%	95%	91%	93%	97%	100%	100%	101%	96%	0%
Engine 4	0%	0%	0%	0%	0%	46%	54%	80%	90%	92%	95%	98%	98%	98%	96%	98%
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384
Engine 1	24	48	72	96	120	144	168	192	216	240	247	265	289	313	337	337
Engine 2	24	48	72	96	120	144	168	192	216	240	264	288	312	312	321	345
Engine 3	24	48	72	96	120	144	168	192	216	240	264	288	312	336	351	351
Engine 4	0	0	0	0	0	9	33	57	81	105	129	153	177	201	225	249
Engine operating run hours total from 0 hours																
Engine 1	29,678	29,702	29,726	29,750	29,774	29,798	29,822	29,846	29,870	29,894	29,901	29,901	29,919	29,943	29,967	29,991
Engine 2	29,537	29,561	29,585	29,609	29,633	29,657	29,681	29,705	29,729	29,753	29,777	29,801	29,825	29,825	29,834	29,858
Engine 3	29,164	29,188	29,212	29,236	29,260	29,284	29,308	29,332	29,356	29,380	29,404	29,428	29,452	29,476	29,491	29,491
Engine 4	28,461	28,461	28,461	28,461	28,461	28,470	28,494	28,518	28,542	28,566	28,590	28,614	28,638	28,662	28,686	28,710
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	94%	86%	85%	86%	87%	88%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	93%	89%	90%
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	98%	91%
Engine 4	0%	0%	0%	0%	0%	6%	20%	30%	38%	44%	49%	53%	57%	60%	63%	65%
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200
Engine 1	806	1,619	2,433	3,249	4,062	4,855	5,654	6,445	7,155	7,859	8,579	9,351	10,170	10,976	11,790	11,790
Engine 2	798	1,604	2,336	3,089	3,897	4,702	5,491	6,269	6,960	7,644	8,408	9,216	9,456	9,456	10,239	11,030
Engine 3	812	1,632	2,456	3,273	4,083	4,893	5,691	6,478	7,230	7,998	8,799	9,625	10,450	11,281	12,072	12,072
Engine 4	-	-	-	-	-	379	823	1,480	2,225	2,987	3,773	4,578	5,385	6,190	6,985	7,791
Cumulative capacity factor, %																
Engine 1	98%	98%	98%	98%	98%	98%	98%	98%	96%	95%	95%	87%	87%	88%	89%	89%
Engine 2	97%	97%	94%	94%	94%	95%	95%	94%	94%	93%	93%	88%	88%	82%	83%	84%
Engine 3	98%	99%	99%	99%	99%	99%	99%	98%	97%	97%	97%	97%	97%	98%	98%	91%
Engine 4	0%	0%	0%	0%	0%	8%	14%	22%	30%	36%	42%	46%	50%	54%	56%	59%

MAY 2009

	Friday 5/1/2009	Saturday 5/2/2009	Sunday 5/3/2009	Monday 5/4/2009	Tuesday 5/5/2009	Wednesday 5/6/2009	Thursday 5/7/2009	Friday 5/8/2009	Saturday 5/9/2009	Sunday 5/10/2009	Monday 5/11/2009	Tuesday 5/12/2009	Wednesday 5/13/2009	Thursday 5/14/2009	Friday 5/15/2009	Saturday 5/16/2009
Cumulative by Facility in month																
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
Actual cumulative engine run hours	72	144	216	288	360	441	537	633	729	825	904	976	1,066	1,138	1,210	1,282
Cumulative Availability, %	75.0%	75.0%	75.0%	75.0%	75.0%	76.6%	79.9%	82.4%	84.4%	85.9%	85.6%	84.7%	85.4%	84.7%	84.0%	83.5%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200
Actual cumulative gross output, kWhr	58,367	117,332	174,665	232,367	290,836	352,595	421,087	493,894	563,880	634,422	696,160	754,881	813,967	873,112	930,690	988,911
Cumulative Capacity Factor	73.7%	74.1%	73.5%	73.3%	73.4%	74.2%	76.0%	78.0%	79.1%	80.1%	79.9%	79.4%	79.1%	78.7%	78.3%	78.0%
Cumulative fuel input, MMBtu HHV	738	1,482	2,206	2,931	3,676	4,460	5,325	6,231	7,106	7,986	8,771	9,520	10,267	11,007	11,725	12,459
Cumulative gross output, kWhr	58,367	117,332	174,665	232,367	290,836	352,595	421,087	493,894	563,880	634,422	696,160	754,881	813,967	873,112	930,690	988,911
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,382	11,358	11,368	11,311	11,470	11,428	11,369	11,202	11,255	11,230	11,446	11,482	11,381	11,263	11,226	11,349
Daily heat rate, Btu/kWe gross HHV	12,644	12,618	12,628	12,565	12,742	12,695	12,629	12,444	12,503	12,475	12,715	12,755	12,643	12,512	12,470	12,607
Cumulative heat rate, Btu/kWe gross LHV	11,382	11,370	11,369	11,355	11,378	11,387	11,384	11,357	11,344	11,332	11,342	11,353	11,355	11,348	11,341	11,341
Cumulative heat rate, Btu/kWe gross HHV	12,644	12,631	12,630	12,614	12,639	12,649	12,646	12,616	12,602	12,588	12,599	12,611	12,614	12,607	12,598	12,599
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	11,616	11,712	11,808	11,904	12,000	12,096	12,192	12,288	12,384	12,480	12,576	12,672	12,768	12,864	12,960	13,056
Actual cumulative engine run hours	10,560	10,632	10,704	10,776	10,848	10,929	11,025	11,121	11,217	11,313	11,392	11,464	11,554	11,626	11,698	11,770
Cumulative Availability, %	90.9%	90.8%	90.7%	90.5%	90.4%	90.4%	90.4%	90.5%	90.6%	90.6%	90.6%	90.5%	90.5%	90.4%	90.3%	90.2%
Max cumulative gross output, kWhr	9,579,900	9,659,100	9,738,300	9,817,500	9,896,700	9,975,900	10,055,100	10,134,300	10,213,500	10,292,700	10,371,900	10,451,100	10,530,300	10,609,500	10,688,700	10,767,900
Actual cumulative gross output, kWhr	8,220,989	8,279,954	8,337,287	8,394,989	8,453,458	8,515,217	8,583,709	8,656,516	8,726,502	8,797,044	8,868,782	8,917,503	8,976,589	9,035,734	9,093,312	9,151,533
Cumulative Capacity Factor	85.8%	85.7%	85.6%	85.5%	85.4%	85.4%	85.4%	85.4%	85.4%	85.5%	85.4%	85.3%	85.2%	85.2%	85.1%	85.0%
Cumulative fuel input, MMBtu HHV	102,884	103,628	104,352	105,077	105,822	106,606	107,471	108,377	109,252	110,132	110,917	111,666	112,413	113,153	113,871	114,605
Cumulative gross output, kWhr	8,220,989	8,279,954	8,337,287	8,394,989	8,453,458	8,515,217	8,583,709	8,656,516	8,726,502	8,797,044	8,868,782	8,917,503	8,976,589	9,035,734	9,093,312	9,151,533
Cumulative heat rate, Btu/kWe gross LHV	11,266	11,266	11,267	11,267	11,269	11,270	11,271	11,270	11,270	11,270	11,271	11,272	11,273	11,273	11,273	11,273
Cumulative heat rate, Btu/kWe gross HHV	12,515	12,515	12,516	12,517	12,518	12,519	12,520	12,520	12,520	12,520	12,521	12,522	12,523	12,523	12,522	12,523
Service																
Engine 1											Top End	Top end	Restart			
Engine 2													Top End (piston/liners add)	Restart		
Engine 3							Monthly Ops Meeting							Top End	Top end	
Engine 4		Return of Engine		Mechanical	Electrical	CarterCAT restart	load 500kW	Adjust wastegate					Replaced coalescing filter.	Coalescing filter dP = 6 inch WG		
Oil - oil and filter change						low load - 400kW	Full load									
Service - plugs, air filter, valve inspection and adjustment																
NSTAR Power Reports																
Date	Friday 5/1/2009	Saturday 5/2/2009	Sunday 5/3/2009	Monday 5/4/2009	Tuesday 5/5/2009	Wednesday 5/6/2009	Thursday 5/7/2009	Friday 5/8/2009	Saturday 5/9/2009	Sunday 5/10/2009	Monday 5/11/2009	Tuesday 5/12/2009	Wednesday 5/13/2009	Thursday 5/14/2009	Friday 5/15/2009	Saturday 5/16/2009
Hour																
1	2,424	2,427	2,432	2,309	2,413	2,417	2,813	2,908	3,043	2,897	2,897	2,429	2,408	2,425	2,424	2,391
2	2,425	2,428	2,432	2,308	2,413	2,417	2,814	2,908	3,043	2,898	2,898	2,429	2,409	2,425	2,424	2,392
3	2,426	2,427	2,433	2,310	2,412	2,417	2,814	2,908	3,043	2,897	2,898	2,428	2,408	2,425	2,424	2,391
4	2,426	2,428	2,433	2,311	2,413	2,417	2,814	2,908	3,042	2,898	2,899	2,429	2,408	2,425	2,424	2,391
5	2,427	2,428	2,432	2,311	2,413	2,418	2,813	2,908	3,044	2,898	2,899	2,430	2,408	2,426	2,424	2,391
6	2,427	2,428	2,432	2,311	2,413	2,417	2,814	2,909	3,043	2,898	2,899	2,430	2,409	2,427	2,424	2,392
7	2,427	2,428	2,431	2,310	2,414	2,418	2,813	2,910	3,044	2,897	2,899	2,430	2,446	2,427	2,425	2,392
8	2,428	2,428	2,432	2,311	2,415	2,418	2,811	2,907	2,983	2,897	2,475	2,428	2,428	2,426	2,424	2,391
9	2,427	2,424	2,432	2,306	2,078	2,416	2,855	2,902	2,898	2,896	2,392	2,432	2,407	2,421	2,421	2,386
10	2,424	2,423	2,348	2,304	2,404	2,414	2,904	3,116	2,898	2,895	2,411	2,430	2,403	2,416	2,415	2,382
11	2,424	2,423	2,306	2,335	2,411	2,414	2,903	3,167	2,898	2,894	2,409	2,425	2,401	2,417	2,407	2,379
12	2,424	2,421	2,306	2,409	2,410	2,415	2,902	3,166	2,896	2,894	2,407	2,414	2,408	2,420	2,405	2,379
13	2,425	2,424	2,306	2,407	2,412	2,415	2,902	3,165	2,894	2,894	2,407	2,412	2,412	2,419	1,929	2,380
14	2,425	2,424	2,306	2,407	2,412	2,241	2,901	3,164	2,894	2,893	2,406	2,415	2,412	2,419	2,404	2,380
15	2,424	2,424	2,306	2,408	2,411	2,352	2,901	3,110	2,895	2,893	2,404	2,415	2,411	2,418	2,224	2,379
16	2,428	2,424	2,307	2,407	2,415	2,710	2,902	3,040	2,894	2,892	2,402	2,409	2,412	2,416	2,222	2,381
17	2,428	2,424	2,310	2,412	2,416	2,808	2,906	3,039	2,895	2,893	2,401	2,408	2,413	2,419	2,374	2,382
18	2,429	2,425	2,309	2,413	2,417	2,811	2,908	3,039	2,895	2,894	2,406	2,407	2,416	2,419	2,381	2,383
19	2,429	2,426	2,310	2,413	2,417	2,812	2,907	3,040	2,895	2,895	2,420	2,415	2,422	2,419	2,386	2,384
20	2,428	2,427	2,310	2,414	2,417	2,812	2,908	3,041	2,895	2,895	2,428	2,413	2,424	2,424	2,388	2,389
21	2,428	2,428	2,310	2,414	2,416	2,812	2,908	3,042	2,895	2,896	2,429	2,408	2,424	2,424	2,390	2,390
22	2,428	2,429	2,310	2,412	2,416	2,812	2,908	3,043	2,896	2,895	2,429	2,408	2,425	2,424	2,390	2,388
23	2,428	2,430	2,310	2,413	2,416	2,813	2,907	3,043	2,896	2,896	2,429	2,408	2,425	2,424	2,391	2,388
24	2,427	2,432	2,309	2,413	2,417	2,813	2,908	3,043	2,896	2,897	2,429	2,408	2,426	2,424	2,391	2,388
TOTAL	58,236	58,230	56,552	56,768	57,591	61,209	68,936	72,426	70,615	69,492	61,373	58,060	57,965	58,129	56,911	57,269
Cumulative Output Sold, kWhr	58,236	116,466	173,018	229,786	287,377	348,586	417,522	489,948	560,563	630,055	691,428	749,488	807,453	865,582	922,493	979,762
Transformer and line efficiency	101.4%	100.5%	100.3%	100.1%	100.3%	100.9%	102.3%	101.3%	102.7%	100.2%	101.2%	100.6%	100.0%	100.1%	100.8%	100.3%
Hourly average	2,427	2,426	2,356	2,365	2,400	2,550	2,872	3,018	2,942	2,896	2,557	2,419	2,415	2,422	2,371	2,386

MAY 2009																		
CNBE Daily Reports Summary Data																		
	Sunday 5/17/2009	Monday 5/18/2009	Tuesday 5/19/2009	Wednesday 5/20/2009	Thursday 5/21/2009	Friday 5/22/2009	Saturday 5/23/2009	Sunday 5/24/2009	Monday 5/25/2009	Tuesday 5/26/2009	Wednesday 5/27/2009	Thursday 5/28/2009	Friday 5/29/2009	Saturday 5/30/2009	Sunday 5/31/2009	TOTAL		
Landfill Gas Flow to the Engines (KSCF)	1,455	1,598	1,586	1,577	1,638	1,654	1,718	1,672	1,645	1,343	1,528	1,761	1,725	1,727	1,531	46,345	Engine methane, %	
Landfill Gas Flow to the Engines (MMBTU HHV)	811	-	-	-	-	910	937	919	904	756	850	956	944	930	832	25,750	54.90	
Landfill Gas Flow to the Flare (KSCF)	305	-	-	-	-	-	-	-	-	137	239	-	-	-	-	4,921	Flare methane, %	
Landfill Gas Flow to the Flare (MMBTU HHV)	175	-	-	-	-	-	-	-	-	79	139	-	-	-	-	2,845	57.13	
Landfill Gas Total Flow (KSCF)	1,760	1,598	1,586	1,577	1,638	1,654	1,718	1,672	1,645	1,480	1,767	1,761	1,725	1,727	1,531	51,265		
Landfill Gas Total Flow (MMBTU HHV)	986	880	878	882	902	910	937	919	904	835	989	956	944	930	832	28,595		
Average Methane Content (%)	55.4	54.4	54.7	55.3	54.4	54.4	53.9	54.3	54.3	55.7	55.3	53.7	54.1	53.2	53.7	55.1		
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	697		
Engine 2 Hours	24	23	24	24	24	24	24	24	24	24	24	24	24	24	24	704		
Engine 3 Hours	11	23	24	24	24	24	24	24	24	24	24	24	24	24	12	685		
Engine 4 Hours	24	23	24	24	24	24	24	24	24	3	12	24	24	24	24	575		
Generator 1 Power Output (kWhr)	19,015	18,424	18,799	19,020	18,785	18,405	18,528	18,502	17,388	18,666	19,560	19,617	19,178	19,095	19,334	548,436		
Generator 2 Power Output (kWhr)	18,468	17,413	18,243	18,440	18,168	17,810	17,558	16,319	16,463	18,140	18,986	19,076	18,617	18,527	18,771	523,990		
Generator 3 Power Output (kWhr)	8,378	18,355	18,727	18,956	18,680	18,346	18,470	18,436	18,629	18,776	19,304	19,356	19,123	19,071	9,149	544,364		
Generator 4 Power Output (kWhr)	18,681	14,858	14,249	14,806	16,534	17,485	17,834	17,822	17,967	2,217	6,652	14,338	14,708	15,203	16,826	401,492		
Gross Power Output (kWhr)	64,943	69,563	70,708	71,888	72,757	72,680	73,194	71,874	71,123	58,234	65,048	73,022	72,226	72,515	64,542	2,033,228		
Net Power Output (kWhr)	63,780	68,397	69,532	70,574	71,273	71,141	71,717	70,406	69,673	57,224	63,821	71,575	70,761	70,981	63,265	1,995,713		
Power Sold as metered by NStar, (kWhr)	63,930	68,829	69,447	70,899	70,953	71,243	71,790	70,587	69,323	57,951	64,009	71,043	70,556	70,883	63,740	2,004,945		
Offgrid RECs (kWhr)	1,163	1,166	1,176	1,314	1,484	1,539	1,477	1,468	1,450	1,010	1,227	1,447	1,465	1,534	1,277	37,515		
Calculated Performance Results																		
Daily																		
Power output (kW average when running)																		
Generator 1	792	768	783	793	783	767	772	771	725	778	815	817	799	796	806			
Generator 2	770	757	760	768	757	742	732	680	686	756	791	795	776	772	782			
Generator 3	762	798	780	790	778	764	770	768	776	782	804	807	797	795	762			
Generator 4	778	646	594	617	689	729	743	743	749	739	554	597	613	633	701			
Power output (kW average over 24-hrs)																		
Facility Gross	2,706	2,898	2,946	2,995	3,032	3,028	3,050	2,995	2,963	2,426	2,710	3,043	3,009	3,021	2,689			
Facility Net	2,658	2,850	2,897	2,941	2,970	2,964	2,988	2,934	2,903	2,384	2,659	2,982	2,948	2,958	2,636			
In-plant load	48	49	49	55	62	64	62	61	60	42	51	60	61	64	53			
Daily availability factor																		
Facility	86%	97%	100%	100%	100%	100%	100%	100%	100%	78%	88%	100%	100%	100%	88%			
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%			
Engine 2	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%			
Engine 3	46%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	50%			
Engine 4	100%	96%	100%	100%	100%	100%	100%	100%	100%	13%	50%	100%	100%	100%	100%			
Daily capacity factor																		
Facility	82%	88%	89%	91%	92%	92%	92%	91%	90%	74%	82%	92%	91%	92%	81%			
Engine 1	96%	93%	95%	96%	95%	93%	94%	93%	88%	94%	99%	99%	97%	96%	98%			
Engine 2	93%	92%	92%	93%	92%	90%	89%	82%	83%	92%	96%	96%	94%	94%	95%			
Engine 3	92%	97%	95%	96%	94%	93%	93%	93%	94%	95%	97%	98%	97%	96%	92%			
Engine 4	94%	78%	72%	75%	84%	88%	90%	90%	91%	90%	67%	72%	74%	77%	85%			
Cumulative by engine																		
Engine operating run hours in the month																		
Max Cumulative Available, hours	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744			
Engine 1	361	385	409	433	457	481	505	529	553	577	601	625	649	673	697			
Engine 2	369	392	416	440	464	488	512	536	560	584	608	632	656	680	704			
Engine 3	362	385	409	433	457	481	505	529	553	577	601	625	649	673	685			
Engine 4	273	296	320	344	368	392	416	440	464	467	479	503	527	551	575			
Engine operating run hours total from 0 hours																		
Engine 1	30,015	30,039	30,063	30,087	30,111	30,135	30,159	30,183	30,207	30,231	30,255	30,279	30,303	30,327	30,351			
Engine 2	29,882	29,905	29,929	29,953	29,977	30,001	30,025	30,049	30,073	30,097	30,121	30,145	30,169	30,193	30,217			
Engine 3	29,502	29,525	29,549	29,573	29,597	29,621	29,645	29,669	29,693	29,717	29,741	29,765	29,789	29,813	29,825			
Engine 4	28,734	28,757	28,781	28,805	28,829	28,853	28,877	28,901	28,925	28,928	28,940	28,964	28,988	29,012	29,036			
Cumulative availability, %																		
Engine 1	88%	89%	90%	90%	91%	91%	91%	92%	92%	92%	93%	93%	93%	93%	94%			
Engine 2	90%	91%	91%	92%	92%	92%	93%	93%	93%	94%	94%	94%	94%	94%	95%			
Engine 3	89%	89%	90%	90%	91%	91%	91%	92%	92%	92%	93%	93%	93%	93%	92%			
Engine 4	67%	69%	70%	72%	73%	74%	75%	76%	77%	75%	74%	75%	76%	77%	77%			
Engine cumulative gross output, kWhr																		
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575			
Engine 1	12,583	13,350	14,134	14,926	15,709	16,476	17,248	18,019	18,743	19,521	20,336	21,153	21,952	22,748	23,554			
Engine 2	11,800	12,557	13,317	14,086	14,843	15,585	16,316	16,996	17,682	18,438	19,229	20,024	20,800	21,572	22,354			
Engine 3	12,834	13,632	14,412	15,202	15,980	16,745	17,514	18,282	19,059	19,841	20,645	21,452	22,249	23,043	23,806			
Engine 4	8,570	9,216	9,809	10,426	11,115	11,844	12,587	13,329	14,078	14,817	15,371	15,969	16,582	17,215	17,916			
Cumulative capacity factor, %																		
Engine 1	90%	90%	90%	90%	91%	91%	91%	91%	91%	91%	91%	92%	92%	92%	92%			
Engine 2	84%	85%	85%	85%	86%	86%	86%	86%	86%	86%	86%	87%	87%	87%	87%			
Engine 3	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	93%	93%	93%	93%	93%			
Engine 4	61%	62%	63%	63%	64%	65%	66%	67%	68%	69%	69%	69%	69%	70%	70%			

		Sunday 5/17/2009	Monday 5/18/2009	Tuesday 5/19/2009	Wednesday 5/20/2009	Thursday 5/21/2009	Friday 5/22/2009	Saturday 5/23/2009	Sunday 5/24/2009	Monday 5/25/2009	Tuesday 5/26/2009	Wednesday 5/27/2009	Thursday 5/28/2009	Friday 5/29/2009	Saturday 5/30/2009	Sunday 5/31/2009	TOTAL
Cumulative by Facility in mont																	
Max cumulative available engine run hours		1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976	
Actual cumulative engine run hours		1,365	1,458	1,554	1,650	1,746	1,842	1,938	2,034	2,130	2,205	2,289	2,385	2,481	2,577	2,661	
Cumulative Availability, %		83.6%	84.4%	85.2%	85.9%	86.6%	87.2%	87.8%	88.3%	88.8%	88.3%	88.3%	88.7%	89.1%	89.5%	89.4%	
Max cumulative gross output, kWhr		1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200	
Actual cumulative gross output, kWhr		1,053,854	1,123,417	1,194,125	1,266,013	1,338,770	1,411,450	1,484,644	1,556,518	1,627,641	1,685,875	1,750,923	1,823,945	1,896,171	1,968,686	2,033,228	
Cumulative Capacity Factor		78.3%	78.8%	79.4%	79.9%	80.5%	81.0%	81.5%	81.9%	82.2%	81.9%	81.9%	82.2%	82.6%	82.9%	82.8%	
Cumulative fuel input, MMBtu HHV		13,270	14,150	15,028	15,910	16,812	17,722	18,659	19,578	20,482	21,238	22,088	23,044	23,988	24,918	25,750	
Cumulative gross output, kWhr		1,053,854	1,123,417	1,194,125	1,266,013	1,338,770	1,411,450	1,484,644	1,556,518	1,627,641	1,685,875	1,750,923	1,823,945	1,896,171	1,968,686	2,033,228	
Heat Rate																	
Daily heat rate, Btu/kWe gross LHV		11,242	11,388	11,178	11,045	11,160	11,271	11,524	11,510	11,442	11,686	11,763	11,785	11,766	11,545	11,604	
Daily heat rate, Btu/kWe gross HHV		12,488	12,650	12,417	12,269	12,397	12,521	12,802	12,786	12,710	12,982	13,067	13,092	13,070	12,825	12,891	
Cumulative heat rate, Btu/kWe gross LHV		11,335	11,338	11,329	11,313	11,304	11,303	11,314	11,323	11,328	11,340	11,356	11,373	11,388	11,394	11,401	
Cumulative heat rate, Btu/kWe gross HHV		12,592	12,596	12,585	12,567	12,558	12,556	12,568	12,578	12,584	12,598	12,615	12,634	12,651	12,657	12,665	
Cumulative by Facility starting Calendar Yea																	
Max cumulative available engine run hours		13,152	13,248	13,344	13,440	13,536	13,632	13,728	13,824	13,920	14,016	14,112	14,208	14,304	14,400	14,496	
Actual cumulative engine run hours		11,853	11,946	12,042	12,138	12,234	12,330	12,426	12,522	12,618	12,693	12,777	12,873	12,969	13,065	13,149	
Cumulative Availability, %		90.1%	90.2%	90.2%	90.3%	90.4%	90.4%	90.5%	90.6%	90.6%	90.6%	90.5%	90.6%	90.7%	90.7%	90.7%	
Max cumulative gross output, kWhr		10,847,100	10,926,300	11,005,500	11,084,700	11,163,900	11,243,100	11,322,300	11,401,500	11,480,700	11,559,900	11,639,100	11,718,300	11,797,500	11,876,700	11,955,900	
Actual cumulative gross output, kWhr		9,216,476	9,286,039	9,356,747	9,428,635	9,501,392	9,574,072	9,647,266	9,719,140	9,790,263	9,848,497	9,913,545	9,986,567	10,058,793	10,131,308	10,195,850	
Cumulative Capacity Factor		85.0%	85.0%	85.0%	85.1%	85.1%	85.2%	85.2%	85.2%	85.3%	85.2%	85.2%	85.2%	85.3%	85.3%	85.3%	
Cumulative fuel input, MMBtu HHV		115,416	116,296	117,174	118,056	118,958	119,868	120,805	121,724	122,628	123,384	124,234	125,190	126,134	127,064	127,896	
Cumulative gross output, kWhr		9,216,476	9,286,039	9,356,747	9,428,635	9,501,392	9,574,072	9,647,266	9,719,140	9,790,263	9,848,497	9,913,545	9,986,567	10,058,793	10,131,308	10,195,850	
Cumulative heat rate, Btu/kWe gross LHV		11,273	11,274	11,273	11,271	11,270	11,270	11,272	11,274	11,275	11,278	11,281	11,285	11,288	11,290	11,292	
Cumulative heat rate, Btu/kWe gross HHV		12,523	12,524	12,523	12,521	12,520	12,520	12,522	12,524	12,525	12,528	12,532	12,536	12,540	12,542	12,544	
Service																	
Engine 1																	
Engine 2																	
Engine 3			Restart														
Engine 4																	
Oil - oil and filter change				PP tune 1/2	Coalescing filter dP = 12 inch WG						Turbo failed	Replace turbo (under warranty)				Proact failure, short	
Service - plugs, air filter, valve inspection and adjustments				Stage 1	PP tune 1/2						Burnt harness	Fixed harness					
NSTAR Power Reports																	
Date		Sunday 5/17/2009	Monday 5/18/2009	Tuesday 5/19/2009	Wednesday 5/20/2009	Thursday 5/21/2009	Friday 5/22/2009	Saturday 5/23/2009	Sunday 5/24/2009	Monday 5/25/2009	Tuesday 5/26/2009	Wednesday 5/27/2009	Thursday 5/28/2009	Friday 5/29/2009	Saturday 5/30/2009	Sunday 5/31/2009	TOTAL
Hour																	
1		2,387	3,002	2,887	2,903	3,006	3,024	3,004	2,943	2,941	2,872	2,357	3,011	2,884	2,956	2,957	
2		2,387	3,002	2,887	2,904	3,007	3,024	3,004	2,944	2,941	2,871	2,357	3,011	2,883	2,954	2,957	
3		2,387	3,002	2,887	2,903	3,007	3,025	3,003	2,943	2,940	2,767	2,357	3,010	2,884	2,952	2,957	
4		2,388	3,002	2,887	2,903	3,007	3,024	3,003	2,944	2,938	2,159	2,357	3,010	2,883	2,954	2,958	
5		2,389	3,003	2,888	2,903	3,007	3,024	3,003	2,944	2,941	2,377	2,357	3,010	2,884	2,953	2,957	
6		2,389	3,004	2,888	2,904	3,008	3,024	3,004	2,943	2,940	2,394	2,358	3,010	2,885	2,954	2,959	
7		2,389	3,003	2,888	2,903	3,007	3,023	3,006	2,943	2,876	2,394	2,358	3,013	2,885	2,953	2,957	
8		2,389	3,000	2,888	2,902	3,002	3,020	3,004	2,940	2,871	2,393	2,358	3,011	2,885	2,953	2,954	
9		2,389	2,688	2,887	2,907	3,021	3,013	3,005	2,942	2,872	2,337	2,356	3,005	2,974	2,954	2,951	
10		2,385	2,378	2,885	2,908	3,017	2,971	3,005	2,942	2,872	2,362	2,364	3,006	3,010	2,955	2,951	
11		2,384	2,596	2,884	2,925	2,917	2,734	3,005	2,941	2,871	2,361	2,363	3,006	3,010	2,951	2,949	
12		2,385	2,520	2,889	2,953	2,906	2,425	3,003	2,941	2,870	2,361	2,364	3,002	3,010	2,950	2,608	
13		2,765	2,883	2,897	2,974	2,730	2,906	3,004	2,937	2,869	2,361	2,620	3,000	2,991	2,950	2,196	
14		2,489	2,884	2,898	2,998	2,336	2,982	3,003	2,940	2,869	2,361	2,949	2,999	2,958	2,952	2,237	
15		3,003	2,883	2,897	2,998	2,784	2,993	3,002	2,939	2,869	2,361	3,023	2,994	2,948	2,952	2,413	
16		3,005	2,883	2,898	2,997	3,004	3,002	3,002	2,938	2,869	2,360	3,020	2,882	2,958	2,952	2,416	
17		3,004	2,885	2,898	2,999	3,022	3,002	3,002	2,940	2,869	2,360	3,013	2,882	2,957	2,952	2,417	
18		3,003	2,887	2,900	3,000	3,023	3,003	3,002	2,941	2,870	2,358	3,012	2,882	2,955	2,953	2,417	
19		3,003	2,888	2,901	3,002	3,023	3,003	3,002	2,940	2,871	2,357	3,012	2,884	2,953	2,953	2,418	
20		3,003	2,888	2,902	3,002	3,025	3,004	2,958	2,939	2,873	2,357	3,011	2,884	2,953	2,954	2,420	
21		3,002	2,887	2,902	3,002	3,025	3,005	2,942	2,941	2,874	2,357	3,011	2,883	2,952	2,956	2,420	
22		3,002	2,887	2,903	3,002	3,023	3,004	2,941	2,941	2,873	2,357	3,011	2,883	2,951	2,956	2,422	
23		3,001	2,887	2,903	3,003	3,023	3,004	2,942	2,941	2,871	2,357	3,010	2,882	2,950	2,957	2,424	
24		3,002	2,887	2,903	3,004	3,023	3,004	2,941	2,940	2,873	2,357	3,011	2,883	2,953	2,957	2,425	
TOTAL		63,930	68,829	69,447	70,899	70,953	71,243	71,790	70,587	69,323	57,591	64,009	71,043	70,556	70,883	63,740	
Cumulative Output Sold, kWhr		1,043,692	1,112,521	1,181,968	1,252,867	1,323,820	1,395,063	1,466,853	1,537,440	1,606,763	1,664,714	1,728,723	1,799,766	1,870,322	1,941,205	2,004,945	
Transformer and line efficiency		100.2%	100.6%	99.9%	100.5%	99.6%	100.1%	100.1%	100.3%	99.5%	101.3%	100.3%	99.3%	99.7%	99.9%	100.8%	0.0%
Hourly average		2,664	2,868	2,994	2,954	2,956	2,968	2,991	2,941	2,888	2,415	2,667	2,960	2,940	2,953	2,656	2,696

JUNE 2009														
CNBE Daily Reports Summary Data														
	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
	6/1/2009	6/2/2009	6/3/2009	6/4/2009	6/5/2009	6/6/2009	6/7/2009	6/8/2009	6/9/2009	6/10/2009	6/11/2009	6/12/2009	6/13/2009	6/14/2009
Landfill Gas Flow to the Engines (KSCF)	1,493	1,766	1,797	1,790	1,786	1,685	1,630	1,663	1,670	1,714	1,731	1,694	1,666	1,702
Landfill Gas Flow to the Engines (MMBTU HHV)	841	943	938	929	928	912	886	903	905	927	927	934	915	937
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,493	1,766	1,797	1,790	1,786	1,685	1,630	1,663	1,670	1,714	1,731	1,694	1,666	1,702
Landfill Gas Total Flow (MMBTU HHV)	841	943	938	929	928	912	886	903	905	927	927	934	915	937
Average Methane Content (%)	55.7	52.8	51.6	51.3	51.4	53.5	53.7	53.6	53.6	53.4	52.9	54.5	54.3	54.4
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 3 Hours	10	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	23	24	24
Generator 1 Power Output (kWhr)	19,384	18,658	18,408	18,211	17,994	17,132	16,908	17,250	17,223	17,801	17,808	18,093	17,465	18,120
Generator 2 Power Output (kWhr)	18,827	18,111	17,866	17,238	17,467	16,641	16,435	16,622	16,688	17,263	17,293	17,454	16,295	16,421
Generator 3 Power Output (kWhr)	8,189	18,638	18,401	18,196	17,957	17,812	17,888	17,820	17,504	17,804	17,782	18,479	18,114	18,128
Generator 4 Power Output (kWhr)	18,469	18,116	17,887	17,697	17,482	17,336	17,374	17,289	16,995	17,277	17,295	16,434	17,574	17,618
Gross Power Output (kWhr)	65,251	74,073	73,071	71,935	71,481	69,476	69,185	69,566	69,006	70,741	70,780	71,069	70,020	70,880
Net Power Output (kWhr)	64,058	72,467	71,443	70,332	69,930	68,034	67,682	68,030	67,565	69,217	69,207	69,542	68,557	69,453
Power Sold as metered by NStar, (kWhr)	64,707	72,743	71,440	70,325	69,934	68,121	67,564	67,876	68,415	69,375	69,857	69,513	69,145	69,361
Offgrid RECs (kWhr)	1,193	1,606	1,628	1,603	1,551	1,442	1,503	1,536	1,441	1,524	1,573	1,527	1,463	1,427
Calculated Performance Results														
Daily														
Power output (kW average when running)														
Generator 1	808	777	767	759	750	714	705	719	718	742	742	754	728	755
Generator 2	784	755	744	718	728	693	685	693	695	719	721	727	679	684
Generator 3	819	777	767	758	748	742	745	743	729	742	741	770	755	755
Generator 4	770	755	745	737	728	722	724	720	708	720	721	715	732	734
Power output (kW average over 24-hrs)														
Facility Gross	2,719	3,086	3,045	2,997	2,978	2,895	2,883	2,899	2,875	2,948	2,949	2,961	2,918	2,953
Facility Net	2,669	3,019	2,977	2,931	2,914	2,835	2,820	2,835	2,815	2,884	2,884	2,898	2,857	2,894
In-plant load	50	67	68	67	65	60	63	64	60	64	66	64	61	59
Daily availability factor														
Facility	85%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	100%	100%
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	42%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%	100%	100%
Daily capacity factor														
Facility	82%	94%	92%	91%	90%	88%	87%	88%	87%	89%	89%	90%	88%	89%
Engine 1	98%	94%	93%	92%	91%	87%	85%	87%	87%	90%	90%	91%	88%	92%
Engine 2	95%	91%	90%	87%	88%	84%	83%	84%	84%	87%	87%	88%	82%	83%
Engine 3	99%	94%	93%	92%	91%	90%	90%	90%	88%	90%	90%	93%	91%	92%
Engine 4	93%	91%	90%	89%	88%	88%	88%	87%	86%	87%	87%	88%	89%	89%
Cumulative by engine														
Engine operating run hours in the month														
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336
Engine 1	24	48	72	96	120	144	168	192	216	240	264	288	312	336
Engine 2	24	48	72	96	120	144	168	192	216	240	264	288	312	336
Engine 3	10	34	58	82	106	130	154	178	202	226	250	274	298	322
Engine 4	24	48	72	96	120	144	168	192	216	240	264	287	311	335
Engine operating run hours total from 0 hours														
Engine 1	30,375	30,399	30,423	30,447	30,471	30,495	30,519	30,543	30,567	30,591	30,615	30,639	30,663	30,687
Engine 2	30,241	30,265	30,289	30,313	30,337	30,361	30,385	30,409	30,433	30,457	30,481	30,505	30,529	30,553
Engine 3	29,835	29,859	29,883	29,907	29,931	29,955	29,979	30,003	30,027	30,051	30,075	30,099	30,123	30,147
Engine 4	29,060	29,084	29,108	29,132	29,156	29,180	29,204	29,228	29,252	29,276	29,300	29,323	29,347	29,371
Cumulative availability, %														
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	42%	71%	81%	85%	88%	90%	92%	93%	94%	94%	95%	95%	96%	96%
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine cumulative gross output, kWhr														
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550
Engine 1	808	1,585	2,352	3,111	3,861	4,574	5,279	5,998	6,715	7,457	8,199	8,953	9,681	10,436
Engine 2	784	1,539	2,284	3,002	3,730	4,423	5,108	5,800	6,496	7,215	7,935	8,663	9,342	10,026
Engine 3	819	1,595	2,362	3,120	3,869	4,611	5,356	6,099	6,828	7,570	8,311	9,081	9,835	10,591
Engine 4	770	1,524	2,270	3,007	3,735	4,458	5,182	5,902	6,610	7,330	8,051	8,765	9,497	10,232
Cumulative capacity factor, %														
Engine 1	98%	96%	95%	94%	94%	92%	91%	91%	90%	90%	90%	90%	90%	90%
Engine 2	95%	93%	92%	91%	90%	89%	88%	88%	87%	87%	87%	88%	87%	87%
Engine 3	99%	97%	95%	95%	94%	93%	93%	92%	92%	92%	92%	92%	92%	92%
Engine 4	93%	92%	92%	91%	91%	90%	90%	89%	89%	89%	89%	89%	89%	89%

	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
	6/1/2009	6/2/2009	6/3/2009	6/4/2009	6/5/2009	6/6/2009	6/7/2009	6/8/2009	6/9/2009	6/10/2009	6/11/2009	6/12/2009	6/13/2009	6/14/2009
Cumulative by Facility in month														
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344
Actual cumulative engine run hours	82	178	274	370	466	562	658	754	850	946	1,042	1,137	1,233	1,329
Cumulative Availability, %	85.4%	92.7%	95.1%	96.4%	97.1%	97.6%	97.9%	98.2%	98.4%	98.5%	98.7%	98.7%	98.8%	98.9%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800
Actual cumulative gross output, kWhr	65,251	139,324	212,395	284,330	355,811	425,287	494,472	564,038	633,044	703,785	774,565	845,634	915,654	986,534
Cumulative Capacity Factor	82.4%	88.0%	89.4%	89.8%	89.9%	89.5%	89.2%	89.0%	88.8%	88.9%	88.9%	89.0%	88.9%	89.0%
Cumulative fuel input, MMBtu HHV	841	1,784	2,722	3,651	4,579	5,491	6,377	7,280	8,185	9,112	10,039	10,973	11,888	12,825
Cumulative gross output, kWhr	65,251	139,324	212,395	284,330	355,811	425,287	494,472	564,038	633,044	703,785	774,565	845,634	915,654	986,534
Heat Rate														
Daily heat rate, Btu/kWe gross LHV	11,602	11,460	11,556	11,626	11,687	11,817	11,528	11,685	11,806	11,796	11,790	11,831	11,764	11,900
Daily heat rate, Btu/kWe gross HHV	12,889	12,731	12,837	12,914	12,982	13,127	12,806	12,980	13,115	13,104	13,097	13,142	13,068	13,220
Cumulative heat rate, Btu/kWe gross LHV	11,602	11,527	11,537	11,559	11,585	11,623	11,609	11,619	11,639	11,655	11,667	11,681	11,687	11,703
Cumulative heat rate, Btu/kWe gross HHV	12,889	12,805	12,816	12,841	12,869	12,911	12,897	12,907	12,930	12,947	12,961	12,976	12,983	13,000
Cumulative by Facility starting Calendar Year														
Max cumulative available engine run hours	14,592	14,688	14,784	14,880	14,976	15,072	15,168	15,264	15,360	15,456	15,552	15,648	15,744	15,840
Actual cumulative engine run hours	13,231	13,327	13,423	13,519	13,615	13,711	13,807	13,903	13,999	14,095	14,191	14,286	14,382	14,478
Cumulative Availability, %	90.7%	90.7%	90.8%	90.9%	90.9%	91.0%	91.0%	91.1%	91.1%	91.2%	91.2%	91.3%	91.3%	91.4%
Max cumulative gross output, kWhr	12,035,100	12,114,300	12,193,500	12,272,700	12,351,900	12,431,100	12,510,300	12,589,500	12,668,700	12,747,900	12,827,100	12,906,300	12,985,500	13,064,700
Actual cumulative gross output, kWhr	10,261,101	10,335,174	10,408,245	10,480,180	10,551,661	10,621,137	10,690,322	10,759,888	10,828,894	10,899,635	10,970,415	11,041,484	11,111,504	11,182,384
Cumulative Capacity Factor	85.3%	85.3%	85.4%	85.4%	85.4%	85.4%	85.5%	85.5%	85.5%	85.5%	85.5%	85.6%	85.6%	85.6%
Cumulative fuel input, MMBtu HHV	128,737	129,680	130,618	131,547	132,475	133,387	134,273	135,176	136,081	137,008	137,935	138,869	139,784	140,721
Cumulative gross output, kWhr	10,261,101	10,335,174	10,408,245	10,480,180	10,551,661	10,621,137	10,690,322	10,759,888	10,828,894	10,899,635	10,970,415	11,041,484	11,111,504	11,182,384
Cumulative heat rate, Btu/kWe gross LHV	11,294	11,295	11,297	11,299	11,302	11,305	11,307	11,309	11,312	11,315	11,318	11,322	11,325	11,328
Cumulative heat rate, Btu/kWe gross HHV	12,546	12,547	12,549	12,552	12,555	12,559	12,560	12,563	12,566	12,570	12,573	12,577	12,580	12,584
Service														
Engine 1														
Engine 2														
Engine 3														
Engine 4														
Oil - oil and filter change														
Service - plugs, air filter, valve inspection and adjustment														
NSTAR Power Reports														
Date	6/1/2009	6/2/2009	6/3/2009	6/4/2009	6/5/2009	6/6/2009	6/7/2009	6/8/2009	6/9/2009	6/10/2009	6/11/2009	6/12/2009	6/13/2009	6/14/2009
Hour														
1	2,426	3,055	3,011	2,958	2,951	2,896	2,819	2,817	2,807	2,868	2,912	2,914	2,868	2,890
2	2,427	3,054	3,012	2,914	2,951	2,897	2,818	2,816	2,808	2,868	2,912	2,914	2,869	2,890
3	2,428	3,054	3,011	2,914	2,952	2,897	2,818	2,816	2,809	2,867	2,912	2,915	2,869	2,887
4	2,428	3,055	3,011	2,915	2,951	2,897	2,818	2,817	2,808	2,867	2,912	2,914	2,870	2,891
5	2,429	3,054	3,011	2,915	2,951	2,897	2,818	2,817	2,808	2,868	2,912	2,914	2,870	2,891
6	2,431	3,054	3,013	2,915	2,953	2,897	2,818	2,816	2,810	2,869	2,914	2,912	2,870	2,891
7	2,430	3,053	3,013	2,915	2,952	2,850	2,819	2,819	2,809	2,868	2,913	2,912	2,866	2,892
8	2,428	3,050	3,010	2,916	2,951	2,820	2,817	2,819	2,808	2,867	2,912	2,912	2,869	2,892
9	2,418	3,046	2,992	2,918	2,915	2,819	2,815	2,835	2,823	2,872	2,909	2,933	2,869	2,891
10	2,401	3,046	2,926	2,909	2,890	2,818	2,814	2,836	2,875	2,888	2,909	2,474	2,905	2,891
11	2,117	3,045	2,924	2,908	2,887	2,818	2,814	2,845	2,882	2,881	2,909	2,448	2,889	2,892
12	2,386	3,045	2,932	2,906	2,887	2,817	2,813	2,844	2,883	2,891	2,907	3,078	2,885	2,891
13	2,385	3,044	2,944	2,910	2,888	2,817	2,813	2,840	2,890	2,899	2,907	3,085	2,886	2,890
14	2,718	3,010	2,944	2,926	2,890	2,816	2,813	2,873	2,902	2,899	2,906	3,003	2,886	2,889
15	3,225	3,006	2,958	2,938	2,893	2,814	2,812	2,863	2,885	2,899	2,905	2,995	2,886	2,889
16	3,188	3,006	2,967	2,947	2,895	2,815	2,812	2,867	2,868	2,907	2,908	2,992	2,886	2,889
17	3,054	3,007	2,968	2,948	2,896	2,815	2,812	2,870	2,868	2,912	2,910	2,992	2,886	2,889
18	3,054	3,007	2,970	2,949	2,897	2,815	2,814	2,831	2,868	2,912	2,911	2,991	2,887	2,889
19	3,055	3,007	2,970	2,949	2,898	2,817	2,814	2,804	2,868	2,912	2,911	2,877	2,886	2,888
20	3,056	3,007	2,970	2,951	2,898	2,817	2,815	2,805	2,867	2,913	2,912	2,867	2,888	2,888
21	3,057	3,008	2,971	2,951	2,897	2,817	2,815	2,807	2,868	2,912	2,912	2,867	2,889	2,891
22	3,056	3,010	2,971	2,951	2,897	2,818	2,812	2,807	2,867	2,912	2,913	2,868	2,887	2,889
23	3,055	3,010	2,970	2,951	2,897	2,818	2,816	2,805	2,867	2,912	2,914	2,868	2,889	2,890
24	3,055	3,010	2,971	2,951	2,897	2,819	2,815	2,807	2,867	2,912	2,915	2,868	2,890	2,891
TOTAL	64,707	72,743	71,440	70,325	69,934	68,121	67,564	67,876	68,415	69,375	69,857	69,513	69,145	69,361
Cumulative Output Sold, kWhr	64,707	137,450	208,890	279,215	349,149	417,270	484,834	552,710	621,125	690,500	760,357	829,870	899,015	968,376
Transformer and line efficiency	101.0%	100.4%	100.0%	100.0%	100.0%	100.1%	99.8%	99.8%	101.3%	100.2%	100.9%	100.0%	100.9%	99.9%
Hourly average	2,696	3,031	2,977	2,930	2,914	2,838	2,815	2,828	2,851	2,891	2,911	2,896	2,881	2,890

JUNE 2009																	
CNBE Daily Reports Summary Data																	
	Monday 6/15/2009	Tuesday 6/16/2009	Wednesday 6/17/2009	Thursday 6/18/2009	Friday 6/19/2009	Saturday 6/20/2009	Sunday 6/21/2009	Monday 6/22/2009	Tuesday 6/23/2009	Wednesday 6/24/2009	Thursday 6/25/2009	Friday 6/26/2009	Saturday 6/27/2009	Sunday 6/28/2009	Monday 6/29/2009	Tuesday 6/30/2009	TOTAL
Landfill Gas Flow to the Engines (KSCF)	1,684	1,769	1,660	1,709	1,704	1,691	1,706	1,746	1,562	1,746	1,776	1,777	1,742	1,710	1,734	1,761	51,262
Landfill Gas Flow to the Engines (MMBTU HHV)	917	939	896	956	949	949	958	977	895	977	986	983	960	958	970	960	28,055
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,684	1,769	1,660	1,709	1,704	1,691	1,706	1,746	1,562	1,746	1,776	1,777	1,742	1,710	1,734	1,761	51,262
Landfill Gas Total Flow (MMBTU HHV)	917	939	896	956	949	949	958	977	895	977	986	983	960	958	970	960	28,055
Average Methane Content (%)	53.8	52.4	53.3	55.3	55.0	55.5	55.5	55.3	56.6	55.3	54.9	54.7	54.5	55.4	55.3	53.9	54.1
Engine 1 Hours	24	24	21	24	24	24	24	24	24	24	24	24	24	24	24	24	717
Engine 2 Hours	24	24	24	24	24	24	24	24	18	24	24	24	24	24	24	24	714
Engine 3 Hours	24	24	24	24	24	25	24	24	21	24	24	24	24	24	24	24	704
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	719
Generator 1 Power Output (kWhr)	17,707	17,893	15,180	18,472	18,738	18,539	18,606	18,916	19,322	18,992	19,201	19,258	18,980	19,031	19,108	18,917	547,315
Generator 2 Power Output (kWhr)	16,507	17,251	16,888	17,933	18,200	17,997	18,082	18,360	12,646	18,465	18,653	18,711	18,230	16,373	17,805	18,382	521,104
Generator 3 Power Output (kWhr)	17,707	18,485	18,144	18,808	19,006	18,912	18,986	19,243	17,094	19,283	19,542	19,620	19,282	19,322	19,326	19,310	544,782
Generator 4 Power Output (kWhr)	17,213	17,978	17,918	18,294	18,452	18,333	18,432	18,683	18,940	18,698	18,915	18,975	18,633	18,695	18,699	18,675	540,376
Gross Power Output (kWhr)	69,664	72,170	68,640	74,014	74,937	74,305	74,659	75,718	68,384	75,954	76,891	77,098	75,656	74,018	75,480	75,819	2,169,941
Net Power Output (kWhr)	68,248	70,684	67,215	72,554	73,420	72,821	73,183	74,229	67,089	74,470	75,318	75,502	74,083	72,525	73,944	74,214	2,125,016
Power Sold as metered by NStar, (kWhr)	69,114	70,648	67,162	73,199	74,337	73,542	73,557	74,786	67,172	75,203	75,569	75,444	74,450	72,646	74,708	74,875	2,134,788
Offgrid RECs (kWhr)	1,416	1,486	1,425	1,460	1,517	1,484	1,476	1,489	1,295	1,484	1,573	1,596	1,573	1,493	1,536	1,605	44,925
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	738	746	723	770	781	772	775	788	805	791	800	802	791	793	796	788	
Generator 2	688	719	704	747	758	750	753	765	703	769	777	780	760	682	742	766	
Generator 3	738	770	756	784	792	756	791	802	814	803	814	818	803	805	805	805	
Generator 4	717	749	747	762	769	764	768	778	789	779	788	791	776	779	779	778	
Power output (kW average over 24-hrs)																	
Facility Gross	2,903	3,007	2,860	3,084	3,122	3,096	3,111	3,155	2,849	3,165	3,204	3,212	3,152	3,084	3,145	3,159	
Facility Net	2,844	2,945	2,801	3,023	3,059	3,034	3,049	3,093	2,795	3,103	3,138	3,146	3,087	3,022	3,081	3,092	
In-plant load	59	62	59	61	63	62	62	62	54	62	66	67	66	62	64	67	
Daily availability factor																	
Facility	100%	100%	97%	100%	100%	101%	100%	100%	91%	100%	100%	100%	100%	100%	100%	100%	
Engine 1	100%	100%	88%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	75%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	104%	100%	100%	88%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																	
Facility	88%	91%	87%	93%	95%	94%	94%	96%	86%	96%	97%	97%	96%	93%	95%	96%	
Engine 1	89%	90%	88%	93%	95%	94%	94%	96%	98%	96%	97%	97%	96%	96%	97%	96%	
Engine 2	83%	87%	85%	91%	92%	91%	91%	93%	85%	93%	94%	95%	92%	83%	90%	93%	
Engine 3	89%	93%	92%	95%	96%	92%	96%	97%	99%	97%	99%	99%	97%	98%	98%	98%	
Engine 4	87%	91%	90%	92%	93%	93%	93%	94%	96%	94%	96%	96%	94%	94%	94%	94%	
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	360	384	408	432	456	480	504	528	552	576	600	624	648	672	696	720	
Engine 1	360	384	405	429	453	477	501	525	549	573	597	621	645	669	693	717	
Engine 2	360	384	408	432	456	480	504	528	546	570	594	618	642	666	690	714	
Engine 3	346	370	394	418	442	467	491	515	536	560	584	608	632	656	680	704	
Engine 4	359	383	407	431	455	479	503	527	551	575	599	623	647	671	695	719	
Engine operating run hours total from 0 hours																	
Engine 1	30,711	30,735	30,756	30,780	30,804	30,828	30,852	30,876	30,900	30,924	30,948	30,972	30,996	31,020	31,044	31,068	
Engine 2	30,577	30,601	30,625	30,649	30,673	30,697	30,721	30,745	30,763	30,787	30,811	30,835	30,859	30,883	30,907	30,931	
Engine 3	30,171	30,195	30,219	30,243	30,267	30,292	30,316	30,340	30,361	30,385	30,409	30,433	30,457	30,481	30,505	30,529	
Engine 4	29,395	29,419	29,443	29,467	29,491	29,515	29,539	29,563	29,587	29,611	29,635	29,659	29,683	29,707	29,731	29,755	
Cumulative availability, %																	
Engine 1	100%	100%	99%	99%	99%	99%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 3	96%	96%	97%	97%	97%	97%	97%	98%	97%	97%	97%	97%	98%	98%	98%	98%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	12,375	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	
Engine 1	11,173	11,919	12,642	13,411	14,192	14,965	15,740	16,528	17,333	18,125	18,925	19,727	20,518	21,311	22,107	22,895	
Engine 2	10,714	11,432	12,136	12,883	13,642	14,392	15,145	15,910	16,613	17,382	18,159	18,939	19,698	20,381	21,122	21,888	
Engine 3	11,328	12,099	12,855	13,638	14,430	15,187	15,978	16,780	17,594	18,397	19,211	20,029	20,832	21,637	22,443	23,247	
Engine 4	10,949	11,698	12,444	13,207	13,976	14,739	15,507	16,286	17,075	17,854	18,642	19,433	20,209	20,988	21,767	22,545	
Cumulative capacity factor, %																	
Engine 1	90%	90%	90%	90%	91%	91%	91%	91%	91%	92%	92%	92%	92%	92%	92%	93%	
Engine 2	87%	87%	87%	87%	87%	87%	87%	88%	88%	88%	88%	88%	88%	88%	88%	88%	
Engine 3	92%	92%	92%	92%	92%	92%	92%	92%	93%	93%	93%	93%	94%	94%	94%	94%	
Engine 4	88%	89%	89%	89%	89%	89%	89%	89%	90%	90%	90%	91%	91%	91%	91%	91%	

		Monday 6/15/2009	Tuesday 6/16/2009	Wednesday 6/17/2009	Thursday 6/18/2009	Friday 6/19/2009	Saturday 6/20/2009	Sunday 6/21/2009	Monday 6/22/2009	Tuesday 6/23/2009	Wednesday 6/24/2009	Thursday 6/25/2009	Friday 6/26/2009	Saturday 6/27/2009	Sunday 6/28/2009	Monday 6/29/2009	Tuesday 6/30/2009	TOTAL
Cumulative by Facility in month																		
Max cumulative available engine run hours		1,440	1,536	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	
Actual cumulative engine run hours		1,425	1,521	1,614	1,710	1,806	1,903	1,999	2,095	2,182	2,278	2,374	2,470	2,566	2,662	2,758	2,854	
Cumulative Availability, %		99.0%	99.0%	98.9%	99.0%	99.0%	99.1%	99.2%	99.2%	98.8%	98.9%	98.9%	99.0%	99.0%	99.0%	99.1%	99.1%	
Max cumulative gross output, kWhr		1,188,000	1,267,200	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	
Actual cumulative gross output, kWhr		1,056,198	1,128,368	1,197,008	1,271,022	1,345,959	1,420,264	1,494,923	1,570,641	1,639,025	1,714,979	1,791,870	1,868,968	1,944,624	2,018,642	2,094,122	2,169,941	
Cumulative Capacity Factor		88.9%	89.0%	88.9%	89.2%	89.4%	89.7%	89.9%	90.1%	90.0%	90.2%	90.5%	90.8%	90.9%	91.0%	91.2%	91.3%	
Cumulative fuel input, MMBtu HHV		13,742	14,681	15,577	16,533	17,482	18,431	19,389	20,366	21,261	22,238	23,224	24,207	25,167	26,125	27,095	28,055	
Cumulative gross output, kWhr		1,056,198	1,128,368	1,197,008	1,271,022	1,345,959	1,420,264	1,494,923	1,570,641	1,639,025	1,714,979	1,791,870	1,868,968	1,944,624	2,018,642	2,094,122	2,169,941	
Heat Rate																		
Daily heat rate, Btu/kWe gross LHV		11,849	11,712	11,751	11,627	11,400	11,497	11,551	11,615	11,782	11,579	11,544	11,478	11,423	11,651	11,569	11,398	
Daily heat rate, Btu/kWe gross HHV		13,163	13,011	13,054	12,916	12,664	12,772	12,832	12,903	13,088	12,863	12,823	12,750	12,689	12,943	12,851	12,662	
Cumulative heat rate, Btu/kWe gross LHV		11,712	11,712	11,715	11,709	11,692	11,682	11,675	11,673	11,677	11,673	11,667	11,659	11,650	11,650	11,647	11,639	
Cumulative heat rate, Btu/kWe gross HHV		13,011	13,011	13,013	13,008	12,989	12,977	12,970	12,967	12,972	12,967	12,961	12,952	12,942	12,942	12,939	12,929	
Cumulative by Facility starting Calendar Year																		
Max cumulative available engine run hours		15,936	16,032	16,128	16,224	16,320	16,416	16,512	16,608	16,704	16,800	16,896	16,992	17,088	17,184	17,280	17,376	
Actual cumulative engine run hours		14,574	14,670	14,763	14,859	14,955	15,052	15,148	15,244	15,331	15,427	15,523	15,619	15,715	15,811	15,907	16,003	
Cumulative Availability, %		91.5%	91.5%	91.5%	91.6%	91.6%	91.7%	91.7%	91.8%	91.8%	91.8%	91.9%	91.9%	92.0%	92.0%	92.1%	92.1%	
Max cumulative gross output, kWhr		13,143,900	13,223,100	13,302,300	13,381,500	13,460,700	13,539,900	13,619,100	13,698,300	13,777,500	13,856,700	13,935,900	14,015,100	14,094,300	14,173,500	14,252,700	14,331,900	
Actual cumulative gross output, kWhr		11,252,048	11,324,218	11,392,858	11,466,872	11,541,809	11,616,114	11,690,773	11,766,491	11,834,875	11,910,829	11,987,720	12,064,818	12,140,474	12,214,492	12,289,972	12,365,791	
Cumulative Capacity Factor		85.6%	85.6%	85.6%	85.7%	85.7%	85.8%	85.8%	85.9%	85.9%	86.0%	86.0%	86.1%	86.1%	86.2%	86.2%	86.3%	
Cumulative fuel input, MMBtu HHV		141,638	142,577	143,473	144,429	145,378	146,327	147,285	148,262	149,157	150,134	151,120	152,103	153,063	154,021	154,991	155,951	
Cumulative gross output, kWhr		11,252,048	11,324,218	11,392,858	11,466,872	11,541,809	11,616,114	11,690,773	11,766,491	11,834,875	11,910,829	11,987,720	12,064,818	12,140,474	12,214,492	12,289,972	12,365,791	
Cumulative heat rate, Btu/kWe gross LHV		11,331	11,334	11,336	11,338	11,339	11,340	11,341	11,343	11,345	11,347	11,348	11,349	11,349	11,351	11,353	11,353	
Cumulative heat rate, Btu/kWe gross HHV		12,588	12,590	12,593	12,595	12,596	12,597	12,598	12,600	12,603	12,605	12,606	12,607	12,608	12,610	12,611	12,611	
Service																		
Engine 1																		
Engine 2																		
Engine 3																		
Engine 4																		
Oil - oil and filter change		District gas tie in of horizontal headers on west side.																
Service - plugs, air filter, valve inspection and adjust																		
NSTAR Power Reports																		
Date		6/15/2009	6/16/2009	6/17/2009	6/18/2009	6/19/2009	6/20/2009	6/21/2009	6/22/2009	6/23/2009	6/24/2009	6/25/2009	6/26/2009	6/27/2009	6/28/2009	6/29/2009	6/30/2009	TOTAL
Hour																		
1		2,892	2,904	2,992	3,028	3,064	3,065	3,064	3,064	3,105	3,115	3,113	3,134	3,112	3,026	3,027	3,112	
2		2,892	2,905	2,943	3,029	3,064	3,067	3,066	3,065	3,105	3,115	3,114	3,135	3,112	3,026	3,028	3,113	
3		2,892	2,873	2,943	3,028	3,065	3,066	3,065	3,064	3,105	3,115	3,114	3,134	3,114	3,026	3,027	3,112	
4		2,891	2,851	2,945	3,027	3,064	3,065	3,065	3,065	3,105	3,114	3,113	3,134	3,114	3,027	3,028	3,111	
5		2,889	2,851	2,944	3,028	3,064	3,066	3,065	3,065	3,105	3,116	3,113	3,134	3,113	3,027	3,027	3,112	
6		2,893	2,852	2,945	3,028	3,064	3,065	3,065	3,066	3,106	3,115	3,114	3,133	3,113	3,028	3,028	3,113	
7		2,892	2,852	2,943	3,026	3,065	3,066	3,066	3,066	3,106	3,117	3,113	3,132	3,112	3,027	3,027	3,112	
8		2,893	2,852	2,942	3,026	3,066	3,065	3,066	3,066	3,106	3,115	3,113	3,132	3,112	3,028	3,028	3,112	
9		2,885	2,907	2,750	3,044	3,094	3,065	3,067	3,082	2,789	3,092	3,182	3,180	3,111	3,028	3,112	3,109	
10		2,883	2,952	2,393	3,061	3,186	3,065	3,067	3,205	2,422	3,153	3,216	3,215	3,110	3,028	3,227	3,106	
11		2,581	2,958	2,398	3,061	3,186	3,064	3,066	3,210	2,423	3,195	3,224	3,214	3,110	3,028	3,226	3,136	
12		2,579	2,986	1,683	3,059	3,219	3,063	3,065	3,206	2,423	3,205	3,221	3,213	3,108	3,027	3,225	3,167	
13		2,811	2,989	1,826	3,059	3,226	3,063	3,064	3,208	2,423	3,212	3,215	3,212	3,108	3,026	3,225	3,201	
14		2,979	2,988	2,295	3,059	3,225	3,062	3,064	3,209	2,339	3,211	3,214	3,213	3,108	3,026	3,225	3,197	
15		2,944	2,989	2,999	3,059	3,110	3,062	3,064	3,204	1,606	3,205	3,211	3,135	3,108	3,026	3,222	3,199	
16		2,945	2,990	3,020	3,059	3,064	3,063	3,064	3,104	1,659	3,110	3,130	3,110	3,108	3,027	3,147	3,142	
17		2,953	2,992	3,022	3,064	3,063	3,063	3,065	3,106	2,428	3,112	3,129	3,108	3,109	3,027	3,107	3,087	
18		2,955	2,992	3,024	3,066	3,064	3,063	3,065	3,106	3,117	3,112	3,130	3,109	3,110	3,027	3,109	3,089	
19		2,944	2,993	3,024	3,065	3,063	3,064	3,065	3,104	3,119	3,112	3,130	3,111	3,111	3,027	3,109	3,090	
20		2,905	2,994	3,025	3,065	3,064	3,065	3,065	3,105	3,118	3,112	3,131	3,111	3,111	3,027	3,111	3,091	
21		2,905	2,995	3,025	3,065	3,064	3,063	3,065	3,105	3,117	3,113	3,132	3,111	3,112	3,026	3,111	3,091	
22		2,904	2,994	3,027	3,065	3,065	3,065	3,063	3,104	3,116	3,113	3,132	3,110	3,073	3,027	3,112	3,091	
23		2,903	2,994	3,027	3,115	3,064	3,063	3,063	3,103	3,115	3,112	3,132	3,112	3,026	3,027	3,110	3,091	
24		2,904	2,995	3,027	3,064	3,064	3,064	3,063	3,104	3,115	3,112	3,133	3,112	3,025	3,027	3,110	3,091	
TOTAL		69,114	70,648	67,162	73,199	74,337	73,542	73,557	74,786	67,172	75,203	75,569	75,444	74,450	72,646	74,708	74,875	
Cumulative Output Sold, kWhr		1,037,490	1,108,138	1,175,300	1,248,499	1,322,836	1,396,378	1,469,935	1,544,721	1,611,893	1,687,096	1,762,665	1,838,109	1,912,559	1,985,205	2,059,913	2,134,788	
Transformer and line efficiency		101.3%	99.9%	99.9%	100.9%	101.2%	101.0%	100.5%	100.8%	100.1%	101.0%	100.3%	99.9%	100.5%	100.2%	101.0%	100.9%	0.0%
Hourly average		2,880	2,944	2,798	3,050	3,097	3,064	3,065	3,116	2,799	3,133	3,149	3,144	3,102	3,027	3,113	3,120	2,965

SECOND HALF 2008

Compilation of the field data logs recording the total landfill gas volumes and methane content readings for the identified reporting periods

JULY 2008																		
CNBE Daily Reports Summary Data																		
	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday		
	7/1/2008	7/2/2008	7/3/2008	7/4/2008	7/5/2008	7/6/2008	7/7/2008	7/8/2008	7/9/2008	7/10/2008	7/11/2008	7/12/2008	7/13/2008	7/14/2008	7/15/2008	7/16/2008		
Landfill Gas Flow to the Engines (KSCF)	1,585	1,509	1,579	1,646	1,575	1,563	1,568	1,560	1,618	1,509	1,591	1,596	1,608	1,615	1,620	1,392		
Landfill Gas Flow to the Engines (MMBTU HHV)	835	792	823	853	823	809	812	806	835	783	821	819	829	843	845	736		
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Landfill Gas Total Flow (KSCF)	1,585	1,509	1,579	1,646	1,575	1,563	1,568	1,560	1,618	1,509	1,591	1,596	1,608	1,615	1,620	1,392		
Landfill Gas Total Flow (MMBTU HHV)	835	792	823	853	823	809	812	806	835	783	821	819	829	843	845	736		
Average Methane Content wet (%)	52.1	51.9	51.5	51.2	51.6	51.2	51.2	51.1	51.0	51.3	51.0	50.7	50.9	51.6	51.6	52.3		
Engine 1 Hours	24	24	24	24	24	24	24	24	24	23	24	24	24	24	24	15		
Engine 2 Hours	24	22	24	24	22	24	24	24	24	24	24	24	24	24	24	24		
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24		
Engine 4 Hours	24	22	24	24	24	23	24	24	24	24	24	24	24	24	24	20		
Generator 1 Power Output (kWhr)	18,464	17,996	17,331	17,513	16,879	16,890	16,821	16,712	17,023	14,468	14,448	14,431	14,466	16,450	16,225	8,931		
Generator 2 Power Output (kWhr)	14,209	13,851	16,892	17,082	15,111	16,447	16,435	16,322	16,622	15,973	17,056	17,082	17,137	17,000	16,825	16,797		
Generator 3 Power Output (kWhr)	18,484	17,963	17,376	17,585	16,840	16,796	17,103	17,249	17,569	16,631	18,085	18,027	18,100	18,050	17,543	18,570		
Generator 4 Power Output (kWhr)	17,676	15,783	16,815	16,987	16,402	16,386	16,157	16,672	17,110	16,649	17,590	17,526	17,647	17,600	17,457	14,140		
Gross Power Output (kWhr)	68,833	65,593	68,414	69,167	65,232	66,518	66,516	66,955	68,324	63,720	67,179	67,066	67,350	69,100	68,050	58,438		
Net Power Output (kWhr)	67,025	63,816	66,429	67,206	63,455	64,659	64,574	64,974	66,302	61,842	65,227	65,068	65,300	66,988	66,040	56,645		
Power Sold as metered by NStar, (kWhr)	67,175	65,005	67,674	67,659	65,131	65,489	65,505	66,128	66,587	64,066	65,844	65,844	65,844	66,854	68,017	58,680		
Offgrid RECs (kWhr)	1,808	1,777	1,985	1,961	1,777	1,859	1,942	1,981	2,022	1,878	1,952	1,998	2,050	2,112	2,010	1,793		
Calculated Performance Results																		
Daily																		
Power output (kW average when running)																		
Generator 1	769	750	722	730	703	704	701	696	709	629	602	601	603	685	676	595		
Generator 2	592	630	704	712	687	685	685	680	693	666	711	712	714	708	701	700		
Generator 3	770	748	724	733	702	700	713	719	732	693	754	751	754	752	731	774		
Generator 4	736	717	701	708	683	712	673	695	713	694	733	730	735	733	727	707		
Power output (kW average over 24-hrs)																		
Facility Gross	2,868	2,733	2,851	2,882	2,718	2,772	2,772	2,790	2,847	2,655	2,799	2,794	2,806	2,879	2,835	2,435		
Facility Net	2,793	2,659	2,768	2,800	2,644	2,694	2,691	2,707	2,763	2,577	2,718	2,711	2,721	2,791	2,752	2,360		
In-plant load	75	74	83	82	74	77	81	83	84	78	81	83	85	88	84	75		
Daily availability factor																		
Facility	100%	96%	100%	100%	98%	99%	100%	100%	100%	99%	100%	100%	100%	100%	100%	86%		
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	63%		
Engine 2	100%	92%	100%	100%	92%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 4	100%	92%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	83%		
Daily capacity factor																		
Facility	87%	83%	86%	87%	82%	84%	84%	85%	86%	80%	85%	85%	85%	87%	86%	74%		
Engine 1	93%	91%	88%	88%	85%	85%	85%	84%	86%	76%	73%	73%	73%	83%	82%	72%		
Engine 2	72%	76%	85%	86%	83%	83%	83%	82%	84%	81%	86%	86%	87%	86%	85%	85%		
Engine 3	93%	91%	88%	89%	85%	85%	86%	87%	89%	84%	91%	91%	91%	91%	89%	94%		
Engine 4	89%	87%	85%	86%	83%	86%	82%	84%	86%	84%	89%	89%	89%	89%	88%	86%		
Cumulative by engine																		
Engine operating run hours in the month																		
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384		
Engine 1	24	48	72	96	120	144	168	192	216	239	263	287	311	335	359	374		
Engine 2	24	46	70	94	116	140	164	188	212	236	260	284	308	332	356	380		
Engine 3	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384		
Engine 4	24	46	70	94	118	141	165	189	213	237	261	285	309	333	357	377		
Engine operating run hours total from 0 hours																		
Engine 1	22,494	22,518	22,542	22,566	22,590	22,614	22,638	22,662	22,686	22,709	22,733	22,757	22,781	22,805	22,829	22,844		
Engine 2	22,351	22,373	22,397	22,421	22,443	22,467	22,491	22,515	22,539	22,563	22,587	22,611	22,635	22,659	22,683	22,707		
Engine 3	21,951	21,975	21,999	22,023	22,047	22,071	22,095	22,119	22,143	22,167	22,191	22,215	22,239	22,263	22,287	22,311		
Engine 4	22,222	22,244	22,268	22,292	22,316	22,339	22,363	22,387	22,411	22,435	22,459	22,483	22,507	22,531	22,555	22,575		
Cumulative availability, %																		
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	97%		
Engine 2	100%	96%	97%	98%	97%	97%	98%	98%	98%	98%	98%	99%	99%	99%	99%	99%		
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 4	100%	96%	97%	98%	98%	98%	98%	98%	99%	99%	99%	99%	99%	99%	99%	98%		
Engine cumulative gross output, kWhr																		
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200		
Engine 1	769	1,519	2,241	2,971	3,674	4,378	5,079	5,775	6,484	7,114	7,716	8,317	8,920	9,605	10,281	10,876		
Engine 2	592	1,222	1,925	2,671	3,324	4,009	4,694	5,374	6,067	6,732	7,443	8,155	8,869	9,577	10,278	10,978		
Engine 3	770	1,519	2,243	2,975	3,677	4,377	5,089	5,808	6,540	7,233	7,987	8,738	9,492	10,244	10,975	11,749		
Engine 4	736	1,454	2,155	2,862	3,546	4,258	4,931	5,626	6,339	7,033	7,766	8,496	9,231	9,964	10,692	11,399		
Cumulative capacity factor, %																		
Engine 1	93%	92%	91%	90%	89%	88%	88%	88%	87%	86%	85%	84%	83%	83%	83%	82%		
Engine 2	72%	74%	78%	80%	81%	82%	81%	81%	82%	82%	83%	83%	83%	83%	83%	83%		
Engine 3	93%	92%	91%	90%	89%	88%	88%	88%	88%	88%	88%	88%	88%	89%	89%	89%		
Engine 4	89%	88%	87%	87%	86%	86%	85%	85%	85%	85%	86%	86%	86%	86%	86%	86%		

	Tuesday 7/1/2008	Wednesday 7/2/2008	Thursday 7/3/2008	Friday 7/4/2008	Saturday 7/5/2008	Sunday 7/6/2008	Monday 7/7/2008	Tuesday 7/8/2008	Wednesday 7/9/2008	Thursday 7/10/2008	Friday 7/11/2008	Saturday 7/12/2008	Sunday 7/13/2008	Monday 7/14/2008	Tuesday 7/15/2008	Wednesday 7/16/2008
Cumulative by Facility in month																
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
Actual cumulative engine run hours	96	188	284	380	474	569	665	761	857	952	1,048	1,144	1,240	1,336	1,432	1,515
Cumulative Availability, %	100.0%	97.9%	98.6%	99.0%	98.8%	98.8%	99.0%	99.1%	99.2%	99.2%	99.2%	99.3%	99.4%	99.4%	99.4%	98.6%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200
Actual cumulative gross output, kWhr	68,833	134,426	202,840	272,007	337,239	403,757	470,273	537,228	605,552	669,272	736,451	803,517	870,867	939,967	1,008,017	1,066,455
Cumulative Capacity Factor	86.9%	84.9%	85.4%	85.9%	85.2%	85.0%	84.8%	84.8%	85.0%	84.5%	84.5%	84.5%	84.6%	84.8%	84.8%	84.2%
Cumulative fuel input, MMBtu HHV	835	1,627	2,450	3,303	4,126	4,935	5,747	6,553	7,388	8,171	8,992	9,811	10,640	11,483	12,328	13,064
Cumulative gross output, kWhr	68,833	134,426	202,840	272,007	337,239	403,757	470,273	537,228	605,552	669,272	736,451	803,517	870,867	939,967	1,008,017	1,066,455
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	10,923	10,872	10,824	11,101	11,352	10,952	10,992	10,841	10,996	11,061	11,001	10,993	11,077	10,987	11,182	11,340
Daily heat rate, Btu/kWe gross HHV	12,134	12,077	12,024	12,331	12,611	12,166	12,210	12,043	12,215	12,287	12,220	12,212	12,305	12,205	12,422	12,597
Cumulative heat rate, Btu/kWe gross LHV	10,923	10,898	10,873	10,931	11,012	11,002	11,001	10,981	10,983	10,990	10,991	10,991	10,998	10,997	11,010	11,028
Cumulative heat rate, Btu/kWe gross HHV	12,134	12,106	12,079	12,143	12,233	12,222	12,221	12,198	12,200	12,209	12,210	12,210	12,217	12,216	12,230	12,250
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	17,564	17,660	17,756	17,852	17,948	18,044	18,140	18,236	18,332	18,428	18,524	18,620	18,716	18,812	18,908	19,004
Actual cumulative engine run hours	16,401	16,493	16,589	16,685	16,779	16,874	16,970	17,066	17,162	17,257	17,353	17,449	17,545	17,641	17,737	17,820
Cumulative Availability, %	93.4%	93.4%	93.4%	93.5%	93.5%	93.5%	93.6%	93.6%	93.6%	93.6%	93.7%	93.7%	93.7%	93.8%	93.8%	93.8%
Max cumulative gross output, kWhr	14,490,300	14,569,500	14,648,700	14,727,900	14,807,100	14,886,300	14,965,500	15,044,700	15,123,900	15,203,100	15,282,300	15,361,500	15,440,700	15,519,900	15,599,100	15,678,300
Actual cumulative gross output, kWhr	12,127,181	12,192,774	12,261,188	12,330,355	12,395,587	12,462,105	12,528,621	12,595,576	12,663,900	12,727,620	12,794,799	12,861,865	12,929,215	12,998,315	13,066,365	13,124,803
Cumulative Capacity Factor	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.8%	83.8%	83.7%
Cumulative fuel input, MMBtu HHV	149,482	150,274	151,097	151,950	152,773	153,582	154,394	155,200	156,035	156,818	157,639	158,458	159,287	160,130	160,975	161,711
Cumulative gross output, kWhr	12,127,181	12,192,774	12,261,188	12,330,355	12,395,587	12,462,105	12,528,621	12,595,576	12,663,900	12,727,620	12,794,799	12,861,865	12,929,215	12,998,315	13,066,365	13,124,803
Cumulative heat rate, Btu/kWe gross LHV	11,096	11,095	11,093	11,093	11,095	11,094	11,093	11,092	11,092	11,091	11,091	11,090	11,090	11,090	11,090	11,091
Cumulative heat rate, Btu/kWe gross HHV	12,326	12,325	12,323	12,323	12,325	12,324	12,323	12,322	12,321	12,321	12,321	12,320	12,320	12,319	12,320	12,321
Service																
Engine 1																Gen excitation
Engine 2			Engine													loss
Engine 3			services					Operations								
Engine 4			Switch blower					Meeting	NStar meter	District 6" temporary fix or leak.						EGS-01 alarm
Oil - oil and filter change			Fix blower bearing						Replaced							
Service - plugs, air filter, valve inspection and adjustment														NStar meter error		
NSTAR Power Reports																
Date	7/1/2008	7/2/2008	7/3/2008	7/4/2008	7/5/2008	7/6/2008	7/7/2008	7/8/2008	7/9/2008	7/10/2008	7/11/2008	7/12/2008	7/13/2008	7/14/2008	7/15/2008	7/16/2008
Hour																
1	2,809	2,804	2,824	2,819	2,814	2,730	2,712	2,745	2,774	2,769	2,744	2,744	2,744	2,786	2,843	2,836
2	2,810	2,800	2,824	2,819	2,814	2,730	2,712	2,740	2,774	2,769	2,744	2,744	2,744	2,786	2,844	2,835
3	2,812	2,800	2,819	2,824	2,814	2,730	2,718	2,740	2,774	2,769	2,744	2,744	2,744	2,786	2,844	2,835
4	2,800	2,800	2,819	2,829	2,814	2,730	2,712	2,740	2,774	2,769	2,744	2,744	2,744	2,786	2,844	2,835
5	2,809	2,800	2,819	2,829	2,814	2,730	2,712	2,740	2,774	2,769	2,744	2,744	2,744	2,786	2,844	2,835
6	2,805	2,800	2,819	2,829	2,814	2,730	2,715	2,740	2,774	2,769	2,744	2,744	2,744	2,786	2,843	2,836
7	2,804	2,800	2,819	2,829	2,814	2,730	2,712	2,740	2,774	2,769	2,744	2,744	2,744	2,786	2,842	2,833
8	2,815	2,800	2,819	2,829	2,295	2,730	2,712	2,740	2,774	2,769	2,744	2,744	2,744	2,786	2,837	2,791
9	2,721	2,410	2,819	2,829	2,262	2,730	2,712	2,740	2,774	2,639	2,744	2,744	2,744	2,786	2,836	2,514
10	2,794	2,425	2,819	2,819	2,725	2,715	2,712	2,754	2,774	1,148	2,744	2,744	2,744	2,786	2,832	2,646
11	2,811	2,425	2,819	2,814	2,725	2,725	2,712	2,754	2,774	2,445	2,744	2,744	2,744	2,786	2,831	2,467
12	2,798	1,996	2,819	2,814	2,725	2,730	2,735	2,754	2,774	2,745	2,744	2,744	2,744	2,786	2,827	2,388
13	2,798	2,415	2,819	2,814	2,725	2,730	2,735	2,754	2,774	2,745	2,744	2,744	2,744	2,786	2,823	2,658
14	2,786	2,633	2,819	2,814	2,725	2,730	2,735	2,754	2,774	2,745	2,744	2,744	2,744	2,786	2,821	2,701
15	2,781	2,829	2,819	2,814	2,725	2,730	2,735	2,754	2,774	2,745	2,744	2,744	2,744	2,786	2,823	2,709
16	2,786	2,829	2,819	2,814	2,725	2,730	2,745	2,754	2,774	2,745	2,744	2,744	2,744	2,786	2,825	2,704
17	2,803	2,829	2,819	2,814	2,725	2,730	2,745	2,768	2,774	2,745	2,744	2,744	2,744	2,786	2,825	2,539
18	2,802	2,829	2,819	2,814	2,725	2,730	2,745	2,768	2,774	2,745	2,744	2,744	2,744	2,786	2,827	1,567
19	2,798	2,829	2,819	2,814	2,725	2,730	2,745	2,768	2,774	2,745	2,744	2,744	2,744	2,786	2,831	1,880
20	2,811	2,829	2,819	2,814	2,725	2,730	2,745	2,768	2,774	2,745	2,744	2,744	2,744	2,786	2,834	2,392
21	2,808	2,829	2,819	2,814	2,725	2,730	2,745	2,768	2,774	2,745	2,744	2,744	2,744	2,786	2,836	2,095
22	2,799	2,829	2,819	2,814	2,725	2,730	2,774	2,781	2,774	2,745	2,744	2,744	2,744	2,786	2,835	1,595
23	2,807	2,829	2,819	2,814	2,725	2,730	2,745	2,781	2,774	2,745	2,744	2,744	2,744	2,786	2,835	1,595
24	2,800	2,829	2,819	2,814	2,730	2,730	2,745	2,781	2,774	2,745	2,744	2,744	2,744	2,786	2,835	1,594
TOTAL	67,175	65,005	67,674	67,659	65,131	65,489	65,505	66,128	66,587	64,066	65,844	65,844	65,844	66,854	68,017	58,680
Cumulative Output Sold, kWhr	67,175	132,180	199,854	267,514	332,645	398,134	463,639	529,767	596,354	660,420	726,264	792,108	857,952	924,806	992,823	1,051,503

JULY 2008																
CNBE Daily Reports Summary Data																
	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	
	7/17/2008	7/18/2008	7/19/2008	7/20/2008	7/21/2008	7/22/2008	7/23/2008	7/24/2008	7/25/2008	7/26/2008	7/27/2008	7/28/2008	7/29/2008	7/30/2008	7/31/2008	TOTAL
Landfill Gas Flow to the Engines (KSCF)	1,238	1,474	1,539	1,566	1,460	1,612	1,577	1,493	1,515	1,483	1,615	1,500	1,559	1,457	1,534	47,756
Landfill Gas Flow to the Engines (MMBTU HHV)	685	798	818	823	776	820	803	797	818	812	878	823	849	807	836	25,207
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,238	1,474	1,539	1,566	1,460	1,612	1,577	1,493	1,515	1,483	1,615	1,500	1,559	1,457	1,534	47,756
Landfill Gas Total Flow (MMBTU HHV)	685	798	818	823	776	820	803	797	818	812	878	823	849	807	836	25,207
Average Methane Content wet (%)	54.7	53.5	52.5	51.9	52.5	50.3	50.3	52.7	53.4	54.1	54.3	54.9	54.5	55.4	54.5	52.2
Engine 1 Hours	16	24	24	24	20	24	24	24	24	24	24	24	24	23	24	721
Engine 2 Hours	24	24	24	24	24	24	23	24	24	24	24	24	24	24	24	739
Engine 3 Hours	24	24	24	24	21	24	24	24	24	24	24	24	24	24	24	741
Engine 4 Hours	13	20	24	24	24	24	24	17	24	18	24	23	22	18	22	698
Generator 1 Power Output (kWhr)	8,843	14,702	14,260	13,710	13,388	17,959	17,704	17,658	16,988	18,779	19,809	18,986	20,481	18,170	18,405	504,887
Generator 2 Power Output (kWhr)	18,519	18,780	19,199	19,418	18,423	17,534	15,514	17,332	16,541	18,323	19,307	18,508	19,970	19,248	17,981	535,439
Generator 3 Power Output (kWhr)	18,925	19,532	20,026	20,032	15,692	17,904	17,612	18,028	17,508	18,837	19,418	18,659	19,405	19,084	18,233	560,863
Generator 4 Power Output (kWhr)	9,804	12,969	14,098	14,073	15,635	17,107	15,574	11,886	16,299	9,915	10,682	9,820	9,482	7,717	11,283	454,941
Gross Power Output (kWhr)	56,091	65,983	67,583	67,232	63,138	70,504	66,404	64,904	67,336	65,854	69,216	65,973	69,337	64,219	65,902	2,056,131
Net Power Output (kWhr)	54,437	63,990	65,430	65,096	61,162	68,173	64,246	62,930	65,358	63,916	67,128	63,996	67,293	62,335	63,777	1,994,817
Power Sold as metered by NStar, (kWhr)	55,254	64,055	65,803	65,523	62,488	68,408	64,983	62,970	68,054	64,048	68,168	67,698	66,066	63,431	64,955	2,023,407
Offgrid RECs (kWhr)	1,654	1,993	2,153	2,136	1,976	2,331	2,158	1,974	1,978	1,938	2,088	1,977	2,044	1,884	2,125	61,314
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	553	613	594	571	669	748	738	736	708	782	825	791	853	790	767	
Generator 2	772	783	800	809	768	731	675	722	689	763	804	771	832	802	749	
Generator 3	789	814	834	835	747	746	734	751	739	785	809	777	809	795	760	
Generator 4	754	648	587	586	651	713	649	699	679	551	445	427	431	429	513	
Power output (kW average over 24-hrs)																
Facility Gross	2,337	2,749	2,816	2,801	2,631	2,938	2,767	2,704	2,806	2,744	2,884	2,749	2,889	2,676	2,746	
Facility Net	2,268	2,666	2,726	2,712	2,548	2,841	2,677	2,622	2,723	2,663	2,797	2,667	2,804	2,597	2,657	
In-plant load	69	83	90	89	82	97	90	82	82	81	87	82	85	79	89	
Daily availability factor																
Facility	80%	96%	100%	100%	93%	100%	99%	93%	100%	94%	100%	99%	98%	93%	98%	
Engine 1	67%	100%	100%	100%	83%	100%	100%	100%	100%	100%	100%	100%	100%	96%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	88%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	54%	83%	100%	100%	100%	100%	100%	71%	100%	75%	100%	96%	92%	75%	92%	
Daily capacity factor																
Facility	71%	83%	85%	85%	80%	89%	84%	82%	85%	83%	87%	83%	88%	81%	83%	
Engine 1	67%	74%	72%	69%	81%	91%	89%	89%	95%	100%	96%	103%	96%	93%	93%	
Engine 2	94%	95%	97%	98%	93%	89%	82%	88%	84%	93%	98%	93%	101%	97%	91%	
Engine 3	96%	99%	101%	101%	91%	90%	89%	91%	88%	95%	98%	94%	98%	96%	92%	
Engine 4	91%	79%	71%	71%	79%	86%	79%	85%	82%	67%	54%	52%	52%	52%	62%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744	
Engine 1	390	414	438	462	482	506	530	554	578	602	626	650	674	697	721	
Engine 2	404	428	452	476	500	524	547	571	595	619	643	667	691	715	739	
Engine 3	408	432	456	480	501	525	549	573	597	621	645	669	693	717	741	
Engine 4	390	410	434	458	482	506	530	547	571	589	613	636	658	676	698	
Engine operating run hours total from 0 hours																
Engine 1	22,860	22,884	22,908	22,932	22,952	22,976	23,000	23,024	23,048	23,072	23,096	23,120	23,144	23,167	23,191	
Engine 2	22,731	22,755	22,779	22,803	22,827	22,851	22,874	22,898	22,922	22,946	22,970	22,994	23,018	23,042	23,066	
Engine 3	22,335	22,359	22,383	22,407	22,428	22,452	22,476	22,500	22,524	22,548	22,572	22,596	22,620	22,644	22,668	
Engine 4	22,588	22,608	22,632	22,656	22,680	22,704	22,728	22,745	22,769	22,787	22,811	22,834	22,856	22,874	22,896	
Cumulative availability, %																
Engine 1	96%	96%	96%	96%	96%	96%	96%	96%	96%	96%	97%	97%	97%	97%	97%	
Engine 2	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 3	100%	100%	100%	100%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	96%	95%	95%	95%	96%	96%	96%	95%	95%	94%	95%	95%	95%	94%	94%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575	
Engine 1	11,429	12,042	12,636	13,207	13,876	14,625	15,362	16,098	16,806	17,588	18,414	19,205	20,058	20,848	21,615	
Engine 2	11,750	12,532	13,332	14,141	14,909	15,639	16,314	17,036	17,725	18,489	19,293	20,064	20,897	21,699	22,448	
Engine 3	12,537	13,351	14,186	15,020	15,767	16,513	17,247	17,998	18,728	19,513	20,322	21,099	21,908	22,703	23,463	
Engine 4	12,153	12,801	13,389	13,975	14,627	15,339	15,988	16,688	17,367	17,918	18,363	18,790	19,221	19,649	20,162	
Cumulative capacity factor, %																
Engine 1	81%	81%	81%	80%	80%	81%	81%	81%	81%	82%	83%	83%	84%	84%	85%	
Engine 2	84%	84%	85%	86%	86%	86%	86%	86%	86%	86%	87%	87%	87%	88%	88%	
Engine 3	89%	90%	90%	91%	91%	91%	91%	91%	91%	91%	91%	91%	92%	92%	92%	
Engine 4	87%	86%	85%	85%	84%	85%	84%	84%	84%	84%	82%	81%	80%	79%	79%	

	Thursday 7/17/2008	Friday 7/18/2008	Saturday 7/19/2008	Sunday 7/20/2008	Monday 7/21/2008	Tuesday 7/22/2008	Wednesday 7/23/2008	Thursday 7/24/2008	Friday 7/25/2008	Saturday 7/26/2008	Sunday 7/27/2008	Monday 7/28/2008	Tuesday 7/29/2008	Wednesday 7/30/2008	Thursday 7/31/2008	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976	
Actual cumulative engine run hours	1,592	1,684	1,780	1,876	1,965	2,061	2,156	2,245	2,341	2,431	2,527	2,622	2,716	2,805	2,899	
Cumulative Availability, %	97.5%	97.5%	97.6%	97.7%	97.5%	97.6%	97.6%	97.4%	97.5%	97.4%	97.5%	97.5%	97.6%	97.4%	97.4%	
Max cumulative gross output, kWhr	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200	
Actual cumulative gross output, kWhr	1,122,546	1,188,529	1,256,112	1,323,344	1,386,482	1,456,986	1,523,390	1,588,294	1,655,630	1,721,484	1,790,700	1,856,673	1,926,010	1,990,229	2,056,131	
Cumulative Capacity Factor	83.4%	83.4%	83.5%	83.5%	83.4%	83.6%	83.6%	83.6%	83.6%	83.6%	83.7%	83.7%	83.9%	83.8%	83.7%	
Cumulative fuel input, MMBtu HHV	13,750	14,547	15,365	16,188	16,964	17,784	18,588	19,384	20,202	21,015	21,892	22,715	23,564	24,371	25,207	
Cumulative gross output, kWhr	1,122,546	1,188,529	1,256,112	1,323,344	1,386,482	1,456,986	1,523,390	1,588,294	1,655,630	1,721,484	1,790,700	1,856,673	1,926,010	1,990,229	2,056,131	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,000	10,881	10,896	11,018	11,065	10,469	10,891	11,048	10,936	11,102	11,412	11,228	11,025	11,316	11,414	
Daily heat rate, Btu/kWe gross HHV	12,220	12,087	12,104	12,240	12,292	11,630	12,099	12,273	12,148	12,333	12,678	12,473	12,248	12,571	12,679	
Cumulative heat rate, Btu/kWe gross LHV	11,026	11,018	11,012	11,012	11,014	10,988	10,984	10,986	10,984	10,989	11,005	11,013	11,014	11,023	11,036	
Cumulative heat rate, Btu/kWe gross HHV	12,249	12,240	12,232	12,233	12,236	12,206	12,202	12,204	12,202	12,207	12,225	12,234	12,235	12,246	12,259	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	19,100	19,196	19,292	19,388	19,484	19,580	19,676	19,772	19,868	19,964	20,060	20,156	20,252	20,348	20,444	
Actual cumulative engine run hours	17,897	17,989	18,085	18,181	18,270	18,366	18,461	18,550	18,646	18,736	18,832	18,927	19,021	19,110	19,204	
Cumulative Availability, %	93.7%	93.7%	93.7%	93.8%	93.8%	93.8%	93.8%	93.8%	93.8%	93.8%	93.9%	93.9%	93.9%	93.9%	93.9%	
Max cumulative gross output, kWhr	15,757,500	15,836,700	15,915,900	15,995,100	16,074,300	16,153,500	16,232,700	16,311,900	16,391,100	16,470,300	16,549,500	16,628,700	16,707,900	16,787,100	16,866,300	
Actual cumulative gross output, kWhr	13,180,894	13,246,877	13,314,460	13,381,692	13,444,830	13,515,334	13,581,738	13,646,642	13,713,978	13,779,832	13,849,048	13,915,021	13,984,358	14,048,577	14,114,479	
Cumulative Capacity Factor	83.6%	83.6%	83.7%	83.7%	83.6%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	
Cumulative fuel input, MMBtu HHV	162,397	163,194	164,012	164,835	165,611	166,431	167,235	168,031	168,849	169,662	170,539	171,362	172,211	173,018	173,854	
Cumulative gross output, kWhr	13,180,894	13,246,877	13,314,460	13,381,692	13,444,830	13,515,334	13,581,738	13,646,642	13,713,978	13,779,832	13,849,048	13,915,021	13,984,358	14,048,577	14,114,479	
Cumulative heat rate, Btu/kWe gross LHV	11,091	11,090	11,089	11,089	11,089	11,085	11,084	11,084	11,083	11,084	11,085	11,086	11,086	11,087	11,088	
Cumulative heat rate, Btu/kWe gross HHV	12,321	12,319	12,318	12,318	12,318	12,314	12,313	12,313	12,312	12,312	12,314	12,315	12,315	12,316	12,317	
Service																
Engine 1	Repair wire				Service										E-Stop jumped	
Engine 2																
Engine 3																
Engine 4	Rebooted EGS-01				Service										Trip at >500 kW	Proact replaced
Oil - oil and filter change																
Service - plugs, air filter, valve inspection and adjust																
NSTAR Power Reports																
Date	7/17/2008	7/18/2008	7/19/2008	7/20/2008	7/21/2008	7/22/2008	7/23/2008	7/24/2008	7/25/2008	7/26/2008	7/27/2008	7/28/2008	7/29/2008	7/30/2008	7/31/2008	TOTAL
Hour																
1	1,596	2,818	2,769	2,744	2,729	2,867	2,828	2,672	2,837	2,837	2,841	2,842	2,805	2,806	2,819	
2	1,595	2,817	2,777	2,746	2,729	2,866	2,830	2,329	2,836	2,837	2,841	2,843	2,805	2,806	2,819	
3	1,595	2,817	2,775	2,739	2,729	2,865	2,826	2,118	2,835	2,837	2,841	2,842	2,805	2,806	2,818	
4	1,595	2,817	2,774	2,742	2,730	2,865	2,816	2,125	2,835	2,804	2,840	2,842	2,804	2,661	2,818	
5	1,595	2,817	2,773	2,742	2,731	2,863	2,810	2,126	2,836	2,165	2,840	2,842	2,805	2,361	2,819	
6	1,595	2,817	2,772	2,741	2,731	2,864	2,802	2,125	2,835	2,155	2,840	2,842	2,805	2,361	2,818	
7	1,594	2,824	2,769	2,733	2,730	2,863	2,788	2,125	2,836	2,155	2,840	2,842	2,805	2,362	2,817	
8	1,593	2,087	2,765	2,729	2,727	2,825	2,783	2,125	2,835	2,154	2,839	2,842	2,803	2,361	2,817	
9	1,588	2,087	2,743	2,729	2,640	2,783	2,426	2,476	2,835	2,268	2,839	2,841	2,800	2,359	2,815	
10	1,996	2,180	2,723	2,734	2,171	2,818	2,468	2,812	2,834	2,835	2,840	2,837	2,797	2,561	2,817	
11	2,369	2,438	2,724	2,729	1,640	2,856	2,730	2,830	2,833	2,799	2,838	2,839	2,792	2,816	2,347	
12	2,813	2,753	2,729	2,721	2,046	2,855	2,455	2,889	2,833	2,353	2,838	2,840	2,410	2,814	2,187	
13	2,807	2,736	2,733	2,712	2,227	2,853	2,641	2,901	2,832	2,630	2,836	2,839	2,251	2,279	2,115	
14	2,805	2,726	2,708	2,710	1,582	2,853	2,676	2,902	2,835	2,835	2,837	2,837	2,525	2,011	2,596	
15	2,806	2,721	2,688	2,715	2,486	2,855	2,678	2,889	2,834	2,832	2,841	2,838	2,799	2,701	2,799	
16	2,801	2,713	2,692	2,720	2,917	2,856	2,330	2,836	2,836	2,834	2,843	2,837	2,803	2,807	2,797	
17	2,805	2,738	2,696	2,727	2,861	2,856	2,716	2,837	2,837	2,836	2,841	2,835	2,805	2,810	2,801	
18	2,809	2,765	2,719	2,729	2,862	2,856	2,782	2,837	2,837	2,838	2,842	2,839	2,805	2,818	2,804	
19	2,813	2,762	2,745	2,731	2,866	2,857	2,781	2,838	2,837	2,839	2,843	2,840	2,806	2,821	2,803	
20	2,816	2,768	2,746	2,732	2,870	2,859	2,781	2,836	2,838	2,842	2,840	2,842	2,807	2,822	2,803	
21	2,818	2,767	2,748	2,731	2,872	2,852	2,765	2,837	2,836	2,843	2,840	2,482	2,809	2,822	2,803	
22	2,818	2,762	2,747	2,730	2,872	2,842	2,771	2,836	2,837	2,841	2,842	2,805	2,809	2,822	2,802	
23	2,815	2,764	2,744	2,729	2,870	2,841	2,749	2,835	2,838	2,839	2,843	2,805	2,805	2,823	2,660	
24	2,817	2,761	2,744	2,728	2,870	2,838	2,751	2,834	2,837	2,840	2,843	2,805	2,806	2,821	2,461	
TOTAL	55,254	64,055	65,803	65,523	62,488	68,408	64,983	62,970	68,054	64,048	68,168	67,698	66,066	63,431	64,955	2,023,407
Cumulative Output Sold, kWhr	1,106,757	1,170,812	1,236,615	1,302,138	1,364,626	1,433,034	1,498,017	1,560,987	1,629,041	1,693,089	1,761,257	1,828,955	1,895,021	1,958,452	2,023,407	

AUGUST 2008																
CNBE Daily Reports Summary Data																
	Friday 8/1/2008	Saturday 8/2/2008	Sunday 8/3/2008	Monday 8/4/2008	Tuesday 8/5/2008	Wednesday 8/6/2008	Thursday 8/7/2008	Friday 8/8/2008	Saturday 8/9/2008	Sunday 8/10/2008	Monday 8/11/2008	Tuesday 8/12/2008	Wednesday 8/13/2008	Thursday 8/14/2008	Friday 8/15/2008	Saturday 8/16/2008
Landfill Gas Flow to the Engines (KSCF)	1,509	1,619	1,589	1,634	1,569	1,607	1,625	1,618	1,528	1,574	1,547	1,510	1,459	1,481	1,456	1,485
Landfill Gas Flow to the Engines (MMBTU HHV)	809	851	842	850	825	846	862	855	813	832	837	839	812	817	792	815
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,509	1,619	1,589	1,634	1,569	1,607	1,625	1,618	1,528	1,574	1,547	1,510	1,459	1,481	1,456	1,485
Landfill Gas Total Flow (MMBTU HHV)	809	851	842	850	825	846	862	855	813	832	837	839	812	817	792	815
Average Methane Content wet (%)	53.0	52.0	52.4	51.4	51.9	52.0	52.4	52.2	52.6	52.2	53.4	54.9	55.0	54.5	53.7	54.2
Engine 1 Hours	24	24	23	24	23	24	24	24	22	24	24	24	24	24	24	24
Engine 2 Hours	24	24	23	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 3 Hours	24	24	23	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 4 Hours	18	24	24	24	20	24	23	24	24	24	24	24	22	24	24	24
Generator 1 Power Output (kWhr)	19,310	19,990	19,346	19,848	18,771	18,934	18,021	16,739	13,430	14,425	14,615	14,999	15,032	14,729	14,601	15,053
Generator 2 Power Output (kWhr)	18,687	19,416	18,729	19,325	18,973	18,430	17,557	16,325	16,697	17,016	16,551	16,407	15,506	16,092	15,972	16,498
Generator 3 Power Output (kWhr)	19,187	19,953	19,246	19,832	18,061	18,842	17,960	16,698	17,054	17,389	16,919	16,781	17,026	17,012	16,865	17,462
Generator 4 Power Output (kWhr)	7,433	9,202	8,651	8,669	7,962	8,318	12,549	16,072	16,491	16,792	16,317	16,194	15,028	15,987	15,831	16,406
Gross Power Output (kWhr)	64,616	68,561	65,972	67,673	63,768	64,524	66,087	65,834	63,672	65,622	64,402	64,381	62,592	63,820	63,270	65,418
Net Power Output (kWhr)	62,549	66,223	63,779	65,424	61,739	62,504	64,066	63,855	61,731	63,525	62,480	62,621	60,829	61,957	61,411	63,562
Power Sold as metered by NStar, (kWhr)	63,200	66,800	65,300	66,289	62,069	64,838	64,505	65,005	62,773	64,311	63,768	64,800	64,800	64,800	64,800	64,800
Offgrid RECs (kWhr)	2,067	2,338	2,193	2,249	2,029	2,020	2,021	1,979	1,941	2,097	1,922	1,760	1,763	1,863	1,859	1,856
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	805	833	841	827	816	789	751	697	610	601	609	625	626	614	608	627
Generator 2	779	809	814	805	791	768	732	680	696	709	690	684	646	670	666	687
Generator 3	799	831	837	826	753	785	748	696	711	725	705	699	709	709	703	728
Generator 4	413	383	360	361	398	347	546	670	687	700	680	675	683	666	660	684
Power output (kW average over 24-hrs)																
Facility Gross	2,692	2,857	2,749	2,820	2,657	2,689	2,754	2,743	2,653	2,734	2,683	2,683	2,608	2,659	2,636	2,726
Facility Net	2,606	2,759	2,657	2,726	2,572	2,604	2,669	2,661	2,572	2,647	2,603	2,609	2,535	2,582	2,559	2,648
In-plant load	86	97	91	94	85	84	84	82	81	87	80	73	73	78	77	77
Daily availability factor																
Facility	94%	100%	97%	100%	95%	100%	99%	100%	98%	100%	100%	100%	98%	100%	100%	100%
Engine 1	100%	100%	96%	100%	96%	100%	100%	100%	92%	100%	100%	100%	100%	100%	100%	100%
Engine 2	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	81%	100%	100%	100%	100%
Engine 4	75%	100%	100%	100%	83%	100%	96%	100%	100%	100%	100%	100%	92%	100%	100%	100%
Daily capacity factor																
Facility	82%	87%	83%	85%	81%	81%	83%	83%	80%	83%	81%	81%	79%	81%	80%	83%
Engine 1	98%	101%	102%	100%	99%	96%	91%	85%	74%	73%	74%	76%	76%	74%	74%	76%
Engine 2	94%	98%	99%	98%	96%	93%	89%	82%	84%	86%	84%	83%	78%	81%	81%	83%
Engine 3	97%	101%	101%	100%	91%	95%	91%	84%	86%	88%	85%	85%	86%	86%	85%	88%
Engine 4	50%	46%	44%	44%	48%	42%	66%	81%	83%	85%	82%	82%	83%	81%	80%	83%
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384
Engine 1	24	48	71	95	118	142	166	190	212	236	260	284	308	332	356	380
Engine 2	24	48	71	95	119	143	167	191	215	239	263	287	311	335	359	383
Engine 3	24	48	71	95	119	143	167	191	215	239	263	287	311	335	359	383
Engine 4	18	42	66	90	110	134	157	181	205	229	253	277	299	323	347	371
Engine operating run hours total from 0 hours																
Engine 1	23,215	23,239	23,262	23,286	23,309	23,333	23,357	23,381	23,403	23,427	23,451	23,475	23,499	23,523	23,547	23,571
Engine 2	23,090	23,114	23,137	23,161	23,185	23,209	23,233	23,257	23,281	23,305	23,329	23,353	23,377	23,401	23,425	23,449
Engine 3	22,692	22,716	22,739	22,763	22,787	22,811	22,835	22,859	22,883	22,907	22,931	22,955	22,979	23,003	23,027	23,051
Engine 4	22,914	22,938	22,962	22,986	23,006	23,030	23,053	23,077	23,101	23,125	23,149	23,173	23,195	23,219	23,243	23,267
Cumulative availability, %																
Engine 1	100%	100%	99%	99%	98%	99%	99%	99%	98%	98%	98%	99%	99%	99%	99%	99%
Engine 2	100%	100%	99%	99%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	100%	100%	99%	99%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 4	75%	88%	92%	94%	92%	93%	93%	94%	95%	95%	96%	96%	96%	96%	96%	97%
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200
Engine 1	805	1,638	2,479	3,306	4,122	4,911	5,662	6,359	6,969	7,571	8,180	8,804	9,431	10,045	10,653	11,280
Engine 2	779	1,588	2,402	3,207	3,998	4,766	5,497	6,177	6,873	7,582	8,272	8,955	9,601	10,272	10,937	11,625
Engine 3	799	1,631	2,468	3,294	4,046	4,832	5,580	6,276	6,986	7,711	8,416	9,115	9,824	10,533	11,236	11,963
Engine 4	413	796	1,157	1,518	1,916	2,263	2,808	3,478	4,165	4,865	5,545	6,219	6,903	7,569	8,228	8,912
Cumulative capacity factor, %																
Engine 1	98%	99%	100%	100%	100%	99%	98%	96%	94%	92%	90%	89%	88%	87%	86%	85%
Engine 2	94%	96%	97%	97%	97%	96%	95%	94%	93%	92%	91%	90%	90%	89%	88%	88%
Engine 3	97%	99%	100%	100%	98%	98%	97%	95%	94%	93%	93%	92%	92%	91%	91%	91%
Engine 4	50%	48%	47%	46%	46%	46%	49%	53%	56%	59%	61%	63%	64%	66%	66%	68%

AUGUST 2008

	Friday 8/1/2008	Saturday 8/2/2008	Sunday 8/3/2008	Monday 8/4/2008	Tuesday 8/5/2008	Wednesday 8/6/2008	Thursday 8/7/2008	Friday 8/8/2008	Saturday 8/9/2008	Sunday 8/10/2008	Monday 8/11/2008	Tuesday 8/12/2008	Wednesday 8/13/2008	Thursday 8/14/2008	Friday 8/15/2008	Saturday 8/16/2008
Cumulative by Facility in month																
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
Actual cumulative engine run hours	90	186	279	375	466	562	657	753	847	943	1,039	1,135	1,229	1,325	1,421	1,517
Cumulative Availability, %	93.8%	96.9%	96.9%	97.7%	97.1%	97.6%	97.8%	98.0%	98.0%	98.2%	98.4%	98.5%	98.5%	98.6%	98.7%	98.8%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200
Actual cumulative gross output, kWhr	64,616	133,177	199,149	266,822	330,590	395,114	461,201	527,035	590,707	656,329	720,731	785,112	847,704	911,524	974,794	1,040,212
Cumulative Capacity Factor	81.6%	84.1%	83.8%	84.2%	83.5%	83.1%	83.2%	83.2%	82.9%	82.9%	82.7%	82.6%	82.3%	82.2%	82.1%	82.1%
Cumulative fuel input, MMBtu HHV	809	1,660	2,503	3,353	4,178	5,024	5,886	6,741	7,554	8,386	9,223	10,062	10,874	11,691	12,483	13,298
Cumulative gross output, kWhr	64,616	133,177	199,149	266,822	330,590	395,114	461,201	527,035	590,707	656,329	720,731	785,112	847,704	911,524	974,794	1,040,212
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,274	11,176	11,495	11,310	11,644	11,807	11,740	11,692	11,496	11,409	11,693	11,738	11,681	11,525	11,264	11,216
Daily heat rate, Btu/kWe gross HHV	12,524	12,415	12,769	12,563	12,935	13,116	13,042	12,988	12,771	12,674	12,990	13,039	12,976	12,802	12,513	12,460
Cumulative heat rate, Btu/kWe gross LHV	11,274	11,223	11,313	11,312	11,376	11,447	11,489	11,514	11,512	11,502	11,519	11,537	11,548	11,546	11,528	11,508
Cumulative heat rate, Btu/kWe gross HHV	12,524	12,468	12,568	12,567	12,638	12,716	12,762	12,791	12,789	12,777	12,796	12,816	12,828	12,826	12,806	12,784
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	20,540	20,636	20,732	20,828	20,924	21,020	21,116	21,212	21,308	21,404	21,500	21,596	21,692	21,788	21,884	21,980
Actual cumulative engine run hours	19,294	19,390	19,483	19,579	19,670	19,766	19,861	19,957	20,051	20,147	20,243	20,339	20,433	20,529	20,625	20,721
Cumulative Availability, %	93.9%	94.0%	94.0%	94.0%	94.0%	94.0%	94.1%	94.1%	94.1%	94.1%	94.2%	94.2%	94.2%	94.2%	94.2%	94.3%
Max cumulative gross output, kWhr	16,945,500	17,024,700	17,103,900	17,183,100	17,262,300	17,341,500	17,420,700	17,499,900	17,579,100	17,658,300	17,737,500	17,816,700	17,895,900	17,975,100	18,054,300	18,133,500
Actual cumulative gross output, kWhr	14,179,095	14,247,656	14,313,628	14,381,301	14,445,069	14,509,593	14,575,680	14,641,514	14,705,186	14,770,808	14,835,210	14,899,591	14,962,183	15,026,003	15,089,273	15,154,691
Cumulative Capacity Factor	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.7%	83.6%	83.6%	83.6%	83.6%	83.6%	83.6%	83.6%
Cumulative fuel input, MMBtu HHV	174,663	175,514	176,357	177,207	178,032	178,878	179,740	180,595	181,408	182,240	183,077	183,916	184,728	185,545	186,337	187,152
Cumulative gross output, kWhr	14,179,095	14,247,656	14,313,628	14,381,301	14,445,069	14,509,593	14,575,680	14,641,514	14,705,186	14,770,808	14,835,210	14,899,591	14,962,183	15,026,003	15,089,273	15,154,691
Cumulative heat rate, Btu/kWe gross LHV	11,089	11,089	11,091	11,092	11,095	11,098	11,101	11,103	11,105	11,107	11,109	11,112	11,114	11,116	11,117	11,117
Cumulative heat rate, Btu/kWe gross HHV	12,318	12,319	12,321	12,322	12,325	12,328	12,332	12,334	12,336	12,338	12,341	12,344	12,346	12,348	12,349	12,349
Service																
Engine 1																
Engine 2																
Engine 3																
Engine 4																
Oil - oil and filter change	Cause of trip at higher load still unknown.					Operations Meeting	Peaker programs TecJet									
Service - plugs, air filter, valve inspection and adjustment	Suspect fuel system.						to be EGS-01 CAT compatible									
							P = 1.5 T = 105									
NSTAR Power Reports																
Date	Friday 8/1/2008	Saturday 8/2/2008	Sunday 8/3/2008	Monday 8/4/2008	Tuesday 8/5/2008	Wednesday 8/6/2008	Thursday 8/7/2008	Friday 8/8/2008	Saturday 8/9/2008	Sunday 8/10/2008	Monday 8/11/2008	Tuesday 8/12/2008	Wednesday 8/13/2008	Thursday 8/14/2008	Friday 8/15/2008	Saturday 8/16/2008
Hour																
1	2,100	2,800	2,800	2,764	2,765	2,766	2,693	2,709	2,711	2,681	2,678	2,700	2,700	2,700	2,700	2,700
2	2,100	2,800	2,800	2,764	2,765	2,765	2,695	2,708	2,710	2,681	2,679	2,700	2,700	2,700	2,700	2,700
3	2,100	2,800	2,800	2,763	2,764	2,765	2,691	2,708	2,710	2,681	2,676	2,700	2,700	2,700	2,700	2,700
4	2,100	2,800	2,800	2,763	2,763	2,765	2,694	2,709	2,710	2,680	2,679	2,700	2,700	2,700	2,700	2,700
5	2,100	2,800	2,800	2,763	2,763	2,765	2,693	2,709	2,710	2,681	2,679	2,700	2,700	2,700	2,700	2,700
6	2,300	2,800	2,800	2,763	2,763	2,765	2,694	2,709	2,708	2,682	2,680	2,700	2,700	2,700	2,700	2,700
7	2,800	2,800	2,800	2,761	2,763	2,765	2,694	2,709	2,230	2,683	2,679	2,700	2,700	2,700	2,700	2,700
8	2,800	2,800	2,800	2,755	2,597	2,658	2,692	2,709	2,026	2,680	2,678	2,700	2,700	2,700	2,700	2,700
9	2,800	2,800	2,700	2,761	2,534	2,690	2,689	2,708	2,034	2,678	2,679	2,700	2,700	2,700	2,700	2,700
10	2,800	2,800	2,700	2,758	1,400	2,691	2,668	2,708	2,688	2,676	2,680	2,700	2,700	2,700	2,700	2,700
11	2,800	2,700	2,700	2,758	2,536	2,453	2,404	2,707	2,686	2,676	2,660	2,700	2,700	2,700	2,700	2,700
12	2,800	2,700	2,800	2,759	2,506	2,693	2,707	2,707	2,684	2,677	2,639	2,700	2,700	2,700	2,700	2,700
13	2,800	2,700	2,800	2,759	2,066	2,692	2,704	2,708	2,682	2,677	2,639	2,700	2,700	2,700	2,700	2,700
14	2,800	2,700	2,000	2,761	2,074	2,692	2,704	2,707	2,681	2,678	2,638	2,700	2,700	2,700	2,700	2,700
15	2,800	2,800	2,000	2,754	2,260	2,692	2,705	2,706	2,680	2,677	2,639	2,700	2,700	2,700	2,700	2,700
16	2,800	2,800	2,800	2,763	2,631	2,691	2,707	2,709	2,678	2,678	2,639	2,700	2,700	2,700	2,700	2,700
17	2,800	2,800	2,800	2,764	2,755	2,690	2,708	2,711	2,681	2,680	2,640	2,700	2,700	2,700	2,700	2,700
18	2,800	2,800	2,800	2,769	2,768	2,690	2,709	2,710	2,681	2,682	2,640	2,700	2,700	2,700	2,700	2,700
19	2,800	2,800	2,800	2,764	2,768	2,692	2,709	2,709	2,679	2,682	2,641	2,700	2,700	2,700	2,700	2,700
20	2,800	2,800	2,800	2,765	2,767	2,692	2,709	2,709	2,680	2,683	2,642	2,700	2,700	2,700	2,700	2,700
21	2,800	2,800	2,800	2,765	2,766	2,692	2,710	2,710	2,681	2,681	2,641	2,700	2,700	2,700	2,700	2,700
22	2,800	2,800	2,800	2,764	2,765	2,691	2,709	2,708	2,681	2,680	2,641	2,700	2,700	2,700	2,700	2,700
23	2,800	2,800	2,800	2,764	2,765	2,691	2,708	2,708	2,681	2,679	2,641	2,700	2,700	2,700	2,700	2,700
24	2,800	2,800	2,800	2,765	2,765	2,692	2,709	2,710	2,681	2,678	2,641	2,700	2,700	2,700	2,700	2,700
TOTAL	63,200	66,800	65,300	66,289	62,069	64,838	64,505	65,005	62,773	64,311	63,768	64,800	64,800	64,800	64,800	64,800
Cumulative Output Sold, kWhr	63,200	130,000	195,300	261,589	323,658	388,496	453,001	518,006	580,779	645,090	708,858	773,658	838,458	903,258	968,058	1,032,858

AUGUST 2008																
CNBE Daily Reports Summary Data																
	Sunday 8/17/2008	Monday 8/18/2008	Tuesday 8/19/2008	Wednesday 8/20/2008	Thursday 8/21/2008	Friday 8/22/2008	Saturday 8/23/2008	Sunday 8/24/2008	Monday 8/25/2008	Tuesday 8/26/2008	Wednesday 8/27/2008	Thursday 8/28/2008	Friday 8/29/2008	Saturday 8/30/2008	Sunday 8/31/2008	TOTAL
Landfill Gas Flow to the Engines (KSCF)	1,448	1,082	1,398	1,444	1,526	1,557	1,559	1,551	1,549	1,528	1,494	1,579	1,583	1,603	1,597	47,308
Landfill Gas Flow to the Engines (MMBTU HHV)	791	588	798	819	837	839	844	845	839	818	802	834	823	826	813	25,413
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,448	1,082	1,398	1,444	1,526	1,557	1,559	1,551	1,549	1,528	1,494	1,579	1,583	1,603	1,597	47,308
Landfill Gas Total Flow (MMBTU HHV)	791	588	798	819	837	839	844	845	839	818	802	834	823	826	813	25,413
Average Methane Content wet (%)	54.0	53.7	56.4	56.0	54.2	53.3	53.5	53.9	53.5	52.9	53.7	52.8	52.0	51.5	50.9	53.1
Engine 1 Hours	24	17	-	9	24	24	24	24	24	24	23	24	24	24	24	693
Engine 2 Hours	24	19	24	24	24	24	24	24	24	24	24	24	24	24	24	738
Engine 3 Hours	24	19	24	24	24	24	24	24	24	24	21	24	24	24	24	735
Engine 4 Hours	24	19	24	24	24	24	24	24	24	24	24	24	24	24	24	726
Generator 1 Power Output (kWhr)	14,868	10,574	-	6,610	16,660	16,828	16,789	16,657	16,978	16,692	16,177	17,068	16,943	16,923	17,102	484,713
Generator 2 Power Output (kWhr)	16,303	12,244	20,435	18,632	16,492	16,658	16,617	16,508	16,801	16,509	16,765	16,640	16,517	16,530	16,730	528,559
Generator 3 Power Output (kWhr)	17,215	12,913	20,700	18,920	16,794	16,982	16,912	16,815	17,097	16,823	15,009	16,963	16,850	16,898	17,088	540,266
Generator 4 Power Output (kWhr)	16,172	12,410	19,978	18,441	16,399	16,513	16,497	16,476	16,674	16,386	16,636	16,499	16,388	16,448	16,616	456,375
Gross Power Output (kWhr)	64,558	48,142	61,113	62,603	66,285	66,981	66,815	66,455	67,550	66,410	64,587	67,170	66,698	66,799	67,535	2,009,913
Net Power Output (kWhr)	62,692	46,703	59,592	61,046	64,534	64,966	64,623	65,466	64,401	62,606	65,010	64,505	64,505	64,505	65,152	1,949,185
Power Sold as metered by NStar, (kWhr)	64,800	64,800	57,600	61,400	67,000	66,200	66,300	66,500	65,790	65,810	63,530	65,950	65,892	65,829	65,778	2,006,037
Offgrid REC's (kWhr)	1,866	1,439	1,521	1,557	1,751	1,847	1,849	1,832	2,084	2,009	1,981	2,160	2,193	2,299	2,383	60,728
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	620	622	-	734	694	701	700	694	707	696	703	711	706	705	713	
Generator 2	679	644	851	776	687	694	692	688	700	688	699	693	688	689	697	
Generator 3	717	680	863	768	700	708	705	701	712	701	715	707	702	704	712	
Generator 4	674	653	832	768	681	688	687	686	695	683	693	687	683	685	692	
Power output (kW average over 24-hrs)																
Facility Gross	2,690	2,006	2,546	2,608	2,762	2,791	2,784	2,769	2,815	2,767	2,691	2,799	2,779	2,783	2,814	
Facility Net	2,612	1,946	2,483	2,544	2,689	2,714	2,707	2,693	2,728	2,683	2,609	2,709	2,688	2,688	2,715	
In-plant load	78	60	63	65	73	77	77	76	87	84	83	90	91	96	99	
Daily availability factor																
Facility	100%	77%	75%	84%	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	
Engine 1	100%	71%	0%	38%	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	
Engine 2	100%	79%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	79%	100%	100%	100%	100%	100%	100%	100%	100%	88%	100%	100%	100%	100%	
Engine 4	100%	79%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																
Facility	82%	61%	77%	79%	84%	85%	84%	84%	85%	84%	82%	85%	84%	84%	85%	
Engine 1	75%	75%	0%	89%	84%	85%	85%	84%	86%	84%	85%	86%	86%	85%	86%	
Engine 2	82%	78%	103%	94%	83%	84%	84%	83%	85%	83%	85%	84%	83%	83%	84%	
Engine 3	87%	82%	105%	96%	85%	86%	85%	85%	86%	85%	87%	86%	85%	85%	86%	
Engine 4	82%	79%	101%	93%	83%	83%	83%	84%	83%	83%	84%	83%	83%	83%	84%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744	
Engine 1	404	421	421	430	454	478	502	526	550	574	597	621	645	669	693	
Engine 2	407	426	450	474	498	522	546	570	594	618	642	666	690	714	738	
Engine 3	407	426	450	474	498	522	546	570	594	618	639	663	687	711	735	
Engine 4	395	414	438	462	486	510	534	558	582	606	630	654	678	702	726	
Engine operating run hours total from 0 hours																
Engine 1	23,595	23,612	23,612	23,621	23,645	23,669	23,693	23,717	23,741	23,765	23,789	23,812	23,836	23,860	23,884	
Engine 2	23,473	23,492	23,516	23,540	23,564	23,588	23,612	23,636	23,660	23,684	23,708	23,732	23,756	23,780	23,804	
Engine 3	23,075	23,094	23,118	23,142	23,166	23,190	23,214	23,238	23,262	23,286	23,307	23,331	23,355	23,379	23,403	
Engine 4	23,291	23,310	23,334	23,358	23,382	23,406	23,430	23,454	23,478	23,502	23,526	23,550	23,574	23,598	23,622	
Cumulative availability, %																
Engine 1	99%	97%	92%	90%	90%	91%	91%	91%	92%	92%	92%	92%	93%	93%	93%	
Engine 2	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 3	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 4	97%	96%	96%	96%	96%	97%	97%	97%	97%	97%	97%	97%	97%	98%	98%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575	
Engine 1	11,900	12,522	12,522	13,256	13,950	14,651	15,351	16,045	16,752	17,448	18,151	18,862	19,568	20,273	20,986	
Engine 2	12,304	12,948	13,800	14,576	15,263	15,957	16,650	17,348	18,038	18,726	19,424	20,117	20,806	21,494	22,191	
Engine 3	12,681	13,360	14,223	15,011	15,711	16,419	17,123	17,824	18,536	19,237	19,952	20,659	21,361	22,065	22,777	
Engine 4	9,586	10,239	11,071	11,840	12,520	13,208	13,896	14,582	15,277	15,960	16,653	17,340	18,023	18,709	19,401	
Cumulative capacity factor, %																
Engine 1	85%	84%	80%	80%	81%	81%	81%	81%	81%	81%	81%	82%	82%	82%	82%	
Engine 2	88%	87%	88%	88%	88%	88%	88%	88%	87%	87%	87%	87%	87%	87%	87%	
Engine 3	90%	90%	91%	91%	91%	90%	90%	90%	90%	90%	89%	89%	89%	89%	89%	
Engine 4	68%	69%	71%	72%	72%	73%	73%	74%	74%	74%	75%	75%	75%	76%	76%	

	Sunday 8/17/2008	Monday 8/18/2008	Tuesday 8/19/2008	Wednesday 8/20/2008	Thursday 8/21/2008	Friday 8/22/2008	Saturday 8/23/2008	Sunday 8/24/2008	Monday 8/25/2008	Tuesday 8/26/2008	Wednesday 8/27/2008	Thursday 8/28/2008	Friday 8/29/2008	Saturday 8/30/2008	Sunday 8/31/2008	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976	
Actual cumulative engine run hours	1,613	1,687	1,759	1,840	1,936	2,032	2,128	2,224	2,320	2,416	2,508	2,604	2,700	2,796	2,892	
Cumulative Availability, %	98.8%	97.6%	96.4%	95.8%	96.0%	96.2%	96.4%	96.5%	96.7%	96.8%	96.8%	96.9%	97.0%	97.1%	97.2%	
Max cumulative gross output, kWhr	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200	
Actual cumulative gross output, kWhr	1,104,770	1,152,912	1,214,025	1,276,628	1,342,913	1,409,894	1,476,709	1,543,164	1,610,714	1,677,124	1,741,711	1,808,881	1,875,579	1,942,378	2,009,913	
Cumulative Capacity Factor	82.1%	80.9%	80.7%	80.6%	80.7%	80.9%	81.1%	81.2%	81.3%	81.4%	81.4%	81.6%	81.7%	81.7%	81.9%	
Cumulative fuel input, MMBtu HHV	14,089	14,677	15,474	16,293	17,130	17,969	18,814	19,659	20,497	21,315	22,118	22,952	23,774	24,600	25,413	
Cumulative gross output, kWhr	1,104,770	1,152,912	1,214,025	1,276,628	1,342,913	1,409,894	1,476,709	1,543,164	1,610,714	1,677,124	1,741,711	1,808,881	1,875,579	1,942,378	2,009,913	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,026	10,993	11,748	11,777	11,361	11,282	11,376	11,451	11,174	11,088	11,184	11,172	11,106	11,129	10,839	
Daily heat rate, Btu/kWe gross HHV	12,248	12,212	13,050	13,082	12,621	12,533	12,637	12,720	12,413	12,318	12,424	12,411	12,338	12,363	12,040	
Cumulative heat rate, Btu/kWe gross LHV	11,480	11,460	11,474	11,489	11,483	11,473	11,469	11,468	11,456	11,441	11,432	11,422	11,411	11,401	11,382	
Cumulative heat rate, Btu/kWe gross HHV	12,753	12,730	12,746	12,763	12,756	12,745	12,740	12,739	12,726	12,710	12,699	12,688	12,676	12,665	12,644	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	22,076	22,172	22,268	22,364	22,460	22,556	22,652	22,748	22,844	22,940	23,036	23,132	23,228	23,324	23,420	
Actual cumulative engine run hours	20,817	20,891	20,963	21,044	21,140	21,236	21,332	21,428	21,524	21,620	21,712	21,808	21,904	22,000	22,096	
Cumulative Availability, %	94.3%	94.2%	94.1%	94.1%	94.1%	94.1%	94.2%	94.2%	94.2%	94.2%	94.3%	94.3%	94.3%	94.3%	94.3%	
Max cumulative gross output, kWhr	18,212,700	18,291,900	18,371,100	18,450,300	18,529,500	18,608,700	18,687,900	18,767,100	18,846,300	18,925,500	19,004,700	19,083,900	19,163,100	19,242,300	19,321,500	
Actual cumulative gross output, kWhr	15,219,249	15,267,391	15,328,504	15,391,107	15,457,392	15,524,373	15,591,188	15,657,643	15,725,193	15,791,603	15,856,190	15,923,360	15,990,058	16,056,857	16,124,392	
Cumulative Capacity Factor	83.6%	83.5%	83.4%	83.4%	83.4%	83.4%	83.4%	83.4%	83.4%	83.4%	83.4%	83.4%	83.4%	83.4%	83.5%	
Cumulative fuel input, MMBtu HHV	187,943	188,531	189,328	190,147	190,984	191,823	192,668	193,513	194,351	195,170	195,972	196,806	197,628	198,454	199,267	
Cumulative gross output, kWhr	15,219,249	15,267,391	15,328,504	15,391,107	15,457,392	15,524,373	15,591,188	15,657,643	15,725,193	15,791,603	15,856,190	15,923,360	15,990,058	16,056,857	16,124,392	
Cumulative heat rate, Btu/kWe gross LHV	11,117	11,116	11,119	11,121	11,122	11,123	11,124	11,126	11,126	11,126	11,126	11,126	11,126	11,126	11,125	
Cumulative heat rate, Btu/kWe gross HHV	12,349	12,349	12,351	12,354	12,356	12,356	12,357	12,359	12,359	12,359	12,359	12,360	12,359	12,359	12,358	
Service																
Engine 1	NStar replaces	Tecjet failed	Replace Tecjet with Peaker invent.	Also Proact replaced. Last bad harness.												
Engine 2	meter.										Service					
Engine 3																
Engine 4	NStar utility trip.															
Oil - oil and filter change				TY site visit with	PP jet out lines								4 wells drilled			
Service - plugs, air filter, valve inspection and adjustm				PP. Determ wate	TY confers with								Hook up scheduled for next week.			
				Sam Chapin.												
NSTAR Power Reports																
Date	Sunday 8/17/2008	Monday 8/18/2008	Tuesday 8/19/2008	Wednesday 8/20/2008	Thursday 8/21/2008	Friday 8/22/2008	Saturday 8/23/2008	Sunday 8/24/2008	Monday 8/25/2008	Tuesday 8/26/2008	Wednesday 8/27/2008	Thursday 8/28/2008	Friday 8/29/2008	Saturday 8/30/2008	Sunday 8/31/2008	TOTAL
Hour																
1	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,750	2,740	2,740	2,750	2,747	2,745	2,741	
2	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,750	2,740	2,740	2,750	2,749	2,745	2,741	
3	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,750	2,740	2,740	2,750	2,748	2,745	2,742	
4	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,750	2,750	2,740	2,750	2,748	2,744	2,742	
5	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,750	2,750	2,740	2,750	2,749	2,744	2,742	
6	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,750	2,750	2,740	2,750	2,748	2,745	2,743	
7	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,750	2,750	2,740	2,750	2,749	2,745	2,744	
8	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,730	2,740	2,740	2,750	2,748	2,744	2,742	
9	2,700	2,700	2,400	2,400	2,800	2,800	2,800	2,800	2,720	2,740	2,270	2,750	2,746	2,744	2,742	
10	2,700	2,700	2,400	2,400	2,800	2,700	2,700	2,800	2,730	2,740	2,160	2,750	2,744	2,743	2,741	
11	2,700	2,700	2,400	2,400	2,800	2,700	2,700	2,700	2,740	2,740	2,180	2,740	2,744	2,742	2,740	
12	2,700	2,700	2,400	2,400	2,800	2,700	2,700	2,700	2,740	2,740	2,210	2,740	2,744	2,742	2,738	
13	2,700	2,700	2,400	2,400	2,800	2,700	2,700	2,700	2,740	2,740	2,540	2,740	2,743	2,742	2,738	
14	2,700	2,700	2,400	2,400	2,700	2,700	2,700	2,700	2,740	2,740	2,750	2,740	2,743	2,742	2,737	
15	2,700	2,700	2,400	2,600	2,700	2,700	2,700	2,700	2,740	2,740	2,750	2,740	2,742	2,742	2,738	
16	2,700	2,700	2,400	2,800	2,800	2,700	2,700	2,700	2,740	2,740	2,750	2,750	2,744	2,742	2,739	
17	2,700	2,700	2,400	2,800	2,800	2,700	2,700	2,800	2,740	2,740	2,750	2,750	2,744	2,743	2,739	
18	2,700	2,700	2,400	2,800	2,800	2,700	2,700	2,800	2,740	2,740	2,750	2,750	2,744	2,742	2,740	
19	2,700	2,700	2,400	2,800	2,800	2,700	2,800	2,700	2,740	2,740	2,750	2,750	2,744	2,742	2,741	
20	2,700	2,700	2,400	2,800	2,800	2,800	2,800	2,800	2,740	2,740	2,750	2,750	2,745	2,742	2,742	
21	2,700	2,700	2,400	2,800	2,800	2,800	2,800	2,800	2,740	2,740	2,750	2,750	2,744	2,741	2,742	
22	2,700	2,700	2,400	2,800	2,800	2,800	2,800	2,800	2,740	2,740	2,750	2,750	2,745	2,741	2,741	
23	2,700	2,700	2,400	2,800	2,800	2,800	2,800	2,800	2,740	2,740	2,750	2,750	2,745	2,741	2,741	
24	2,700	2,700	2,400	2,800	2,800	2,800	2,800	2,800	2,740	2,740	2,750	2,750	2,745	2,741	2,742	
TOTAL	64,800	64,800	57,600	61,400	67,000	66,200	66,300	66,500	65,790	65,810	63,530	65,950	65,892	65,829	65,778	2,006,037
Cumulative Output Sold, kWhr	1,097,658	1,162,458	1,220,058	1,281,458	1,348,458	1,414,658	1,480,958	1,547,458	1,613,248	1,679,058	1,742,588	1,808,538	1,874,430	1,940,259	2,006,037	

SEPTEMBER 2008

SEPTEMBER 2008																
CNBE Daily Reports Summary Data																
	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday
	9/1/2008	9/2/2008	9/3/2008	9/4/2008	9/5/2008	9/6/2008	9/7/2008	9/8/2008	9/9/2008	9/10/2008	9/11/2008	9/12/2008	9/13/2008	9/14/2008	9/15/2008	9/16/2008
Landfill Gas Flow to the Engines (KSCF)	1,579	1,579	1,470	1,494	1,446	1,129	1,055	1,384	1,630	1,630	1,788	1,783	1,459	1,691	1,719	1,786
Landfill Gas Flow to the Engines (MMBTU HHV)	800	811	779	798	776	628	598	785	893	875	964	978	827	952	951	959
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,579	1,579	1,470	1,494	1,446	1,129	1,055	1,384	1,630	1,630	1,788	1,783	1,459	1,691	1,719	1,786
Landfill Gas Total Flow (MMBTU HHV)	800	811	779	798	776	628	598	785	893	875	964	978	827	952	951	959
Average Methane Content wet (%)	50.0	50.7	52.4	52.8	53.0	55.0	56.0	56.0	54.1	53.0	53.3	54.2	56.0	55.6	54.6	53.1
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	23	24	24	24
Engine 2 Hours	24	24	24	24	24	15	-	13	24	24	24	24	15	24	24	24
Engine 3 Hours	24	24	24	24	24	10	14	24	24	24	24	24	23	24	24	24
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	22	24	24	24
Generator 1 Power Output (kWhr)	16,925	16,666	16,236	16,538	16,835	17,753	19,727	18,860	18,111	17,524	19,144	19,381	18,306	19,035	19,387	19,407
Generator 2 Power Output (kWhr)	16,546	16,240	15,806	16,133	16,430	10,621	-	8,389	17,562	17,241	18,507	18,658	10,682	17,401	18,321	18,347
Generator 3 Power Output (kWhr)	16,902	16,649	15,091	16,435	14,675	4,128	8,485	16,838	17,505	17,037	18,572	18,487	17,884	18,992	18,903	18,570
Generator 4 Power Output (kWhr)	16,460	16,240	14,455	15,977	14,659	17,113	19,024	17,966	17,394	16,582	18,658	18,606	17,575	18,399	18,802	18,716
Gross Power Output (kWhr)	66,833	65,795	61,588	65,084	62,598	49,616	47,235	62,053	70,572	68,384	74,881	75,133	64,447	73,827	75,412	75,041
Net Power Output (kWhr)	64,469	63,510	59,558	62,940	60,525	48,149	46,008	60,501	68,829	66,734	73,096	73,314	63,008	72,073	73,517	73,260
Power Sold as metered by NStar, (kWhr)	65,763	63,973	60,404	64,049	61,211	48,779	47,011	61,674	70,656	67,899	73,852	74,265	64,265	73,832	74,034	73,956
Offgrid RECs (kWhr)	2,364	2,285	2,030	2,144	2,073	1,467	1,227	1,552	1,743	1,650	1,785	1,819	1,439	1,754	1,895	1,781
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	705	694	677	689	701	740	822	786	755	730	798	808	796	793	808	809
Generator 2	689	677	659	672	685	708	-	645	732	718	771	777	712	725	763	764
Generator 3	704	694	629	685	611	413	606	702	729	710	774	770	778	791	788	774
Generator 4	686	677	602	666	611	713	793	749	725	691	777	775	799	767	783	780
Power output (kW average over 24-hrs)																
Facility Gross	2,785	2,741	2,566	2,712	2,608	2,067	1,968	2,586	2,941	2,849	3,120	3,131	2,685	3,076	3,142	3,127
Facility Net	2,686	2,646	2,482	2,623	2,522	2,006	1,917	2,521	2,868	2,781	3,046	3,055	2,625	3,003	3,063	3,053
In-plant load	99	95	85	89	86	61	51	65	73	69	74	76	60	73	79	74
Daily availability factor																
Facility	100%	100%	100%	100%	100%	78%	65%	89%	100%	100%	100%	100%	86%	100%	100%	100%
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%
Engine 2	100%	100%	100%	100%	100%	63%	0%	54%	100%	100%	100%	100%	63%	100%	100%	100%
Engine 3	100%	100%	100%	100%	100%	42%	58%	100%	100%	100%	100%	88%	96%	100%	100%	100%
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%
Daily capacity factor																
Facility	84%	83%	78%	82%	79%	63%	60%	78%	89%	86%	95%	95%	81%	93%	95%	95%
Engine 1	85%	84%	82%	84%	85%	90%	100%	95%	91%	89%	97%	98%	96%	96%	98%	98%
Engine 2	84%	82%	80%	81%	83%	86%	0%	78%	89%	87%	93%	94%	86%	88%	93%	93%
Engine 3	85%	84%	76%	83%	74%	50%	73%	85%	88%	86%	94%	93%	94%	96%	95%	94%
Engine 4	83%	82%	73%	81%	74%	86%	96%	91%	88%	84%	94%	94%	97%	93%	95%	95%
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384
Engine 1	24	48	72	96	120	144	168	192	216	240	264	288	311	335	359	383
Engine 2	24	48	72	96	120	135	135	148	172	196	220	244	259	283	307	331
Engine 3	24	48	72	96	120	130	144	168	192	216	240	264	287	311	335	359
Engine 4	24	48	72	96	120	144	168	192	216	240	264	288	310	334	358	382
Engine operating run hours total from 0 hours																
Engine 1	23,908	23,932	23,956	23,980	24,004	24,028	24,052	24,076	24,100	24,124	24,148	24,172	24,195	24,219	24,243	24,267
Engine 2	23,828	23,852	23,876	23,900	23,924	23,939	23,939	23,952	23,976	24,000	24,024	24,048	24,063	24,087	24,111	24,135
Engine 3	23,427	23,451	23,475	23,499	23,523	23,533	23,547	23,571	23,595	23,619	23,643	23,667	23,690	23,714	23,738	23,762
Engine 4	23,646	23,670	23,694	23,718	23,742	23,766	23,790	23,814	23,838	23,862	23,886	23,910	23,932	23,956	23,980	24,004
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 2	100%	100%	100%	100%	100%	94%	80%	77%	80%	82%	83%	85%	83%	84%	85%	86%
Engine 3	100%	100%	100%	100%	100%	90%	86%	88%	89%	90%	91%	92%	92%	93%	93%	93%
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200
Engine 1	705	1,400	2,076	2,765	3,467	4,206	5,028	5,814	6,569	7,299	8,097	8,904	9,700	10,493	11,301	12,110
Engine 2	689	1,366	2,025	2,697	3,381	4,089	4,735	5,467	6,185	6,956	7,734	8,446	9,171	9,934	10,699	11,464
Engine 3	704	1,398	2,027	2,712	3,323	3,736	4,342	5,044	5,773	6,483	7,257	8,027	8,804	9,596	10,383	11,157
Engine 4	686	1,363	1,965	2,631	3,241	3,954	4,747	5,496	6,220	6,911	7,689	8,464	9,263	10,029	10,813	11,593
Cumulative capacity factor, %																
Engine 1	85%	85%	84%	84%	84%	85%	87%	88%	88%	88%	89%	90%	90%	91%	91%	92%
Engine 2	84%	83%	82%	82%	82%	83%	71%	72%	74%	75%	77%	78%	79%	79%	80%	81%
Engine 3	85%	85%	82%	82%	81%	75%	75%	76%	78%	79%	80%	81%	82%	83%	84%	85%
Engine 4	83%	83%	79%	80%	79%	80%	82%	83%	84%	84%	85%	85%	86%	87%	87%	88%

SEPTEMBER 2008

	Monday 9/1/2008	Tuesday 9/2/2008	Wednesday 9/3/2008	Thursday 9/4/2008	Friday 9/5/2008	Saturday 9/6/2008	Sunday 9/7/2008	Monday 9/8/2008	Tuesday 9/9/2008	Wednesday 9/10/2008	Thursday 9/11/2008	Friday 9/12/2008	Saturday 9/13/2008	Sunday 9/14/2008	Monday 9/15/2008	Tuesday 9/16/2008
Cumulative by Facility in month																
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
Actual cumulative engine run hours	96	192	288	384	480	553	615	700	796	892	988	1,084	1,167	1,263	1,359	1,455
Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	96.0%	91.5%	91.1%	92.1%	92.9%	93.6%	94.1%	93.5%	94.0%	94.4%	94.7%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200
Actual cumulative gross output, kWhr	66,833	132,628	194,216	259,300	321,898	371,514	418,749	480,802	551,374	619,758	694,639	769,772	834,219	908,046	983,458	1,058,499
Cumulative Capacity Factor	84.4%	83.7%	81.7%	81.8%	81.3%	78.2%	75.5%	75.9%	77.4%	78.3%	79.7%	81.0%	81.0%	81.9%	82.8%	83.5%
Cumulative fuel input, MMBtu HHV	800	1,610	2,390	3,188	3,964	4,592	5,189	5,974	6,866	7,741	8,706	9,684	10,510	11,462	12,413	13,372
Cumulative gross output, kWhr	66,833	132,628	194,216	259,300	321,898	371,514	418,749	480,802	551,374	619,758	694,639	769,772	834,219	908,046	983,458	1,058,499
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	10,769	11,095	11,393	11,036	11,159	11,391	11,391	11,382	11,385	11,517	11,593	11,719	11,547	11,602	11,347	11,509
Daily heat rate, Btu/kWe gross HHV	11,963	12,325	12,656	12,259	12,396	12,654	12,654	12,644	12,648	12,793	12,878	13,018	12,828	12,889	12,605	12,785
Cumulative heat rate, Btu/kWe gross LHV	10,769	10,930	11,077	11,067	11,085	11,126	11,156	11,185	11,210	11,244	11,282	11,324	11,342	11,363	11,362	11,372
Cumulative heat rate, Btu/kWe gross HHV	11,963	12,142	12,305	12,294	12,314	12,359	12,392	12,425	12,453	12,491	12,533	12,580	12,599	12,623	12,621	12,633
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	23,516	23,612	23,708	23,804	23,900	23,996	24,092	24,188	24,284	24,380	24,476	24,572	24,668	24,764	24,860	24,956
Actual cumulative engine run hours	22,192	22,288	22,384	22,480	22,576	22,649	22,711	22,796	22,892	22,988	23,084	23,180	23,263	23,359	23,455	23,551
Cumulative Availability, %	94.4%	94.4%	94.4%	94.4%	94.5%	94.4%	94.3%	94.2%	94.3%	94.3%	94.3%	94.3%	94.3%	94.3%	94.3%	94.4%
Max cumulative gross output, kWhr	19,400,700	19,479,900	19,559,100	19,638,300	19,717,500	19,796,700	19,875,900	19,955,100	20,034,300	20,113,500	20,192,700	20,271,900	20,351,100	20,430,300	20,509,500	20,588,700
Actual cumulative gross output, kWhr	16,191,225	16,257,020	16,318,608	16,383,692	16,446,290	16,495,906	16,543,141	16,605,194	16,675,766	16,744,150	16,819,031	16,894,164	16,958,611	17,032,438	17,107,850	17,182,891
Cumulative Capacity Factor	83.5%	83.5%	83.4%	83.4%	83.4%	83.3%	83.2%	83.2%	83.2%	83.2%	83.3%	83.3%	83.3%	83.4%	83.4%	83.5%
Cumulative fuel input, MMBtu HHV	200,067	200,878	201,657	202,455	203,231	203,859	204,457	205,241	206,134	207,009	207,973	208,951	209,778	210,729	211,680	212,639
Cumulative gross output, kWhr	16,191,225	16,257,020	16,318,608	16,383,692	16,446,290	16,495,906	16,543,141	16,605,194	16,675,766	16,744,150	16,819,031	16,894,164	16,958,611	17,032,438	17,107,850	17,182,891
Cumulative heat rate, Btu/kWe gross LHV	11,123	11,123	11,124	11,124	11,124	11,125	11,126	11,127	11,128	11,129	11,131	11,131	11,131	11,137	11,138	11,140
Cumulative heat rate, Btu/kWe gross HHV	12,357	12,356	12,358	12,357	12,357	12,358	12,359	12,360	12,361	12,363	12,365	12,368	12,370	12,372	12,373	12,375
Service																
Engine 1						Evidence of water into facility - 2 failed PTs.					P2 LF - 1 new well connected.					
Engine 2						6% O2					Batteries changed					
Engine 3						6% O2										
Engine 4																
Oil - oil and filter change																
Service - plugs, air filter, valve inspection and adjustment																
Service																
NSTAR Power Reports	Monday 9/1/2008	Tuesday 9/2/2008	Wednesday 9/3/2008	Thursday 9/4/2008	Friday 9/5/2008	Saturday 9/6/2008	Sunday 9/7/2008	Monday 9/8/2008	Tuesday 9/9/2008	Wednesday 9/10/2008	Thursday 9/11/2008	Friday 9/12/2008	Saturday 9/13/2008	Sunday 9/14/2008	Monday 9/15/2008	Tuesday 9/16/2008
Hour																
1	2,741	2,741	2,619	2,616	2,708	2,457	1,605	2,238	2,856	2,998	3,048	3,096	3,093	3,078	3,074	3,097
2	2,742	2,741	2,619	2,615	2,708	2,029	1,605	2,239	2,857	2,999	3,049	3,096	3,095	3,079	3,074	3,097
3	2,741	2,742	2,619	2,615	2,707	2,030	1,604	2,239	2,856	2,999	3,048	3,096	932	3,078	3,074	3,098
4	2,743	2,742	2,619	2,615	2,708	2,031	1,603	2,239	2,856	3,000	3,048	3,096	588	3,078	3,073	3,098
5	2,743	2,742	2,620	2,615	2,708	2,032	1,602	2,240	2,855	3,000	3,049	3,096	2,420	3,077	3,074	3,099
6	2,743	2,743	2,620	2,615	2,707	2,033	1,601	2,240	2,856	3,000	3,050	3,096	2,425	3,076	3,075	3,098
7	2,743	2,744	2,620	2,615	2,707	2,033	1,601	2,241	2,856	3,001	3,050	3,098	2,425	3,076	3,075	3,099
8	2,742	2,741	2,618	2,615	2,707	2,033	1,601	2,240	2,891	3,000	3,049	3,097	2,424	3,076	3,074	3,098
9	2,740	2,739	2,616	2,612	2,704	2,034	1,601	2,280	2,923	3,000	3,053	3,097	2,424	3,077	3,072	3,092
10	2,739	2,642	2,617	2,651	2,703	2,033	1,600	2,409	2,968	3,019	3,094	3,096	2,422	3,079	3,069	3,072
11	2,739	2,627	2,272	2,706	2,226	1,960	1,905	2,408	2,968	3,019	3,092	3,093	2,422	3,076	3,081	3,071
12	2,737	2,627	2,036	2,704	1,836	1,314	2,236	2,516	2,967	2,457	3,092	3,092	2,649	3,075	3,089	3,070
13	2,737	2,635	2,031	2,701	1,837	826	2,235	2,763	2,968	1,461	3,093	3,091	3,084	3,076	3,090	3,071
14	2,736	2,615	2,032	2,702	1,835	1,686	2,235	2,841	2,996	1,461	3,093	3,092	3,079	3,074	3,090	3,071
15	2,737	2,612	2,309	2,701	1,988	2,712	2,235	2,852	2,997	2,045	3,094	3,092	3,078	3,074	3,090	3,072
16	2,737	2,612	2,613	2,701	2,712	2,774	2,237	2,851	2,998	3,050	3,092	3,092	3,079	3,076	3,093	3,073
17	2,738	2,613	2,615	2,702	2,712	2,775	2,237	2,853	2,999	3,049	3,092	3,093	3,078	3,077	3,094	3,072
18	2,739	2,615	2,615	2,705	2,713	2,311	2,238	2,854	2,998	3,048	3,093	3,094	3,079	3,077	3,095	3,072
19	2,740	2,615	2,615	2,706	2,714	1,970	2,239	2,855	2,999	3,047	3,094	3,095	3,078	3,077	3,097	3,073
20	2,741	2,616	2,616	2,709	2,716	1,969	2,239	2,856	2,999	3,050	3,095	3,094	3,079	3,077	3,096	3,073
21	2,741	2,616	2,616	2,707	2,715	1,969	2,239	2,855	2,999	3,050	3,096	3,095	3,078	3,075	3,097	3,073
22	2,741	2,617	2,615	2,707	2,714	1,969	2,238	2,855	2,998	3,049	3,096	3,093	3,078	3,075	3,096	3,072
23	2,741	2,618	2,616	2,707	2,713	1,969	2,237	2,855	2,998	3,049	3,096	3,092	3,078	3,075	3,096	3,073
24	2,742	2,618	2,616	2,707	2,713	1,830	2,238	2,855	2,998	3,048	3,096	3,093	3,078	3,074	3,096	3,072
TOTAL	65,763	63,973	60,404	64,049	61,211	48,779	47,011	61,674	70,656	67,899	73,852	74,265	64,265	73,832	74,034	73,956
Cumulative Output Sold, kWhr	65,763	129,736	190,140	254,189	315,400	364,179	411,190	472,864	543,520	611,419	685,271	759,536	823,801	897,633	971,667	1,045,623

SEPTEMBER 2008																
CNBE Daily Reports Summary Data																
	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday		
	9/17/2008	9/18/2008	9/19/2008	9/20/2008	9/21/2008	9/22/2008	9/23/2008	9/24/2008	9/25/2008	9/26/2008	9/27/2008	9/28/2008	9/29/2008	9/30/2008	TOTAL	
Landfill Gas Flow to the Engines (KSCF)	1,743	1,782	1,830	1,791	1,827	1,881	1,600	1,830	1,734	1,696	1,691	1,729	1,706	1,666	49,128	
Landfill Gas Flow to the Engines (MMBTU HHV)	943	950	949	938	940	946	870	949	892	892	901	928	905	886	26,258	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,743	1,782	1,830	1,791	1,827	1,881	1,600	1,830	1,734	1,696	1,691	1,729	1,706	1,666	49,128	
Landfill Gas Total Flow (MMBTU HHV)	943	950	949	938	940	946	870	949	892	892	901	928	905	886	26,258	
Average Methane Content wet (%)	53.4	52.7	51.2	51.7	50.8	49.7	53.7	51.2	50.8	51.9	53.3	53.7	53.1	53.2	52.8	
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	719	
Engine 2 Hours	24	24	24	24	24	24	24	24	24	23	24	24	24	24	666	
Engine 3 Hours	23	24	24	23	24	24	15	24	24	23	24	24	24	24	683	
Engine 4 Hours	24	24	24	24	24	24	24	24	22	24	24	24	24	24	716	
Generator 1 Power Output (kWhr)	19,387	19,207	19,262	19,274	19,289	19,226	19,500	19,452	18,560	18,283	18,408	18,809	18,441	18,394	555,324	
Generator 2 Power Output (kWhr)	18,091	18,387	18,723	18,765	18,753	18,667	18,950	18,921	18,148	17,226	18,347	18,737	18,204	15,986	492,789	
Generator 3 Power Output (kWhr)	18,018	17,473	16,711	15,767	16,750	16,603	10,918	17,496	16,644	16,235	16,370	16,732	16,403	16,655	483,929	
Generator 4 Power Output (kWhr)	18,567	18,901	18,920	18,643	18,641	18,220	18,966	18,798	16,188	18,105	18,206	18,600	17,566	17,111	532,058	
Gross Power Output (kWhr)	74,063	73,967	73,616	72,449	73,433	72,715	68,334	74,667	69,540	69,848	71,331	72,879	70,614	68,146	2,064,101	
Net Power Output (kWhr)	72,326	72,239	71,895	70,747	71,601	70,832	66,564	72,733	67,881	68,163	69,541	71,055	68,813	66,382	2,010,263	
Power Sold as metered by NStar, (kWhr)	73,200	73,341	72,851	71,637	72,450	71,980	66,232	72,515	70,671	71,090	71,991	71,960	71,117	67,530	2,044,188	
Offgrid RECs (kWhr)	1,737	1,728	1,721	1,702	1,832	1,883	1,770	1,934	1,659	1,685	1,790	1,824	1,801	1,764	53,838	
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	808	800	803	803	804	801	813	811	773	762	767	784	768	766		
Generator 2	754	766	780	782	781	778	790	788	756	749	764	781	759	666		
Generator 3	783	728	696	686	698	672	728	729	693	706	682	697	683	694		
Generator 4	774	788	788	777	777	759	790	783	736	754	759	775	732	713		
Power output (kW average over 24-hrs)																
Facility Gross	3,086	3,082	3,067	3,019	3,060	3,030	2,847	3,111	2,898	2,910	2,972	3,037	2,942	2,839		
Facility Net	3,014	3,010	2,996	2,948	2,983	2,951	2,774	3,031	2,828	2,840	2,898	2,961	2,867	2,766		
In-plant load	72	72	72	71	76	78	74	81	69	70	75	76	75	74		
Daily availability factor																
Facility	99%	100%	100%	99%	100%	100%	91%	100%	98%	98%	100%	100%	100%	100%		
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%		
Engine 3	96%	100%	100%	96%	100%	100%	63%	100%	100%	96%	100%	100%	100%	100%		
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%	100%	100%		
Daily capacity factor																
Facility	94%	93%	93%	91%	93%	92%	86%	94%	88%	88%	90%	92%	89%	86%		
Engine 1	98%	97%	97%	97%	97%	97%	98%	98%	94%	92%	93%	95%	93%	93%		
Engine 2	91%	93%	95%	95%	95%	94%	96%	96%	92%	91%	93%	95%	92%	81%		
Engine 3	95%	88%	84%	83%	85%	84%	88%	88%	84%	86%	83%	85%	83%	84%		
Engine 4	94%	95%	96%	94%	94%	92%	96%	95%	89%	91%	92%	94%	89%	86%		
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	408	432	456	480	504	528	552	576	600	624	648	672	696	720		
Engine 1	407	431	455	479	503	527	551	575	599	623	647	671	695	719		
Engine 2	355	379	403	427	451	475	499	523	547	570	594	618	642	666		
Engine 3	382	406	430	453	477	501	516	540	564	587	611	635	659	683		
Engine 4	406	430	454	478	502	526	550	574	596	620	644	668	692	716		
Engine operating run hours total from 0 hours																
Engine 1	24,291	24,315	24,339	24,363	24,387	24,411	24,435	24,459	24,483	24,507	24,531	24,555	24,579	24,603		
Engine 2	24,159	24,183	24,207	24,231	24,255	24,279	24,303	24,327	24,351	24,374	24,398	24,422	24,446	24,470		
Engine 3	23,785	23,809	23,833	23,856	23,880	23,904	23,919	23,943	23,967	23,990	24,014	24,038	24,062	24,086		
Engine 4	24,028	24,052	24,076	24,100	24,124	24,148	24,172	24,196	24,218	24,242	24,266	24,290	24,314	24,338		
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	87%	88%	88%	89%	89%	90%	90%	91%	91%	91%	92%	92%	92%	93%		
Engine 3	94%	94%	94%	94%	95%	95%	93%	94%	94%	94%	94%	94%	95%	95%		
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%		
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750		
Engine 1	12,917	13,718	14,520	15,323	16,127	16,928	17,741	18,551	19,324	20,086	20,853	21,637	22,405	23,172		
Engine 2	11,452	12,218	12,999	13,780	14,562	15,340	16,129	16,918	17,674	18,423	19,187	19,968	20,726	21,392		
Engine 3	11,941	12,669	13,365	14,050	14,748	15,440	16,168	16,897	17,590	18,296	18,978	19,676	20,359	21,053		
Engine 4	12,366	13,154	13,942	14,719	15,496	16,255	17,045	17,828	18,564	19,319	20,077	20,852	21,584	22,297		
Cumulative capacity factor, %																
Engine 1	92%	92%	93%	93%	93%	93%	93%	94%	94%	94%	94%	94%	94%	94%		
Engine 2	82%	82%	83%	84%	84%	85%	85%	85%	86%	86%	86%	86%	87%	86%		
Engine 3	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%		
Engine 4	88%	89%	89%	89%	89%	89%	90%	90%	90%	90%	90%	90%	90%	90%		

SEPTEMBER 2008

		Wednesday 9/17/2008	Thursday 9/18/2008	Friday 9/19/2008	Saturday 9/20/2008	Sunday 9/21/2008	Monday 9/22/2008	Tuesday 9/23/2008	Wednesday 9/24/2008	Thursday 9/25/2008	Friday 9/26/2008	Saturday 9/27/2008	Sunday 9/28/2008	Monday 9/29/2008	Tuesday 9/30/2008	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours		1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	
Actual cumulative engine run hours		1,550	1,646	1,742	1,837	1,933	2,029	2,116	2,212	2,306	2,400	2,496	2,592	2,688	2,784	
Cumulative Availability, %		95.0%	95.3%	95.5%	95.7%	95.9%	96.1%	95.8%	96.0%	96.1%	96.2%	96.3%	96.4%	96.6%	96.7%	
Max cumulative gross output, kWhr		1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	
Actual cumulative gross output, kWhr		1,132,562	1,206,529	1,280,145	1,352,594	1,426,027	1,498,742	1,567,076	1,641,743	1,711,283	1,781,131	1,852,462	1,925,341	1,995,955	2,064,101	
Cumulative Capacity Factor		84.1%	84.6%	85.1%	85.4%	85.7%	86.0%	86.0%	86.4%	86.4%	86.5%	86.6%	86.8%	86.9%	86.9%	
Cumulative fuel input, MMBtu HHV		14,315	15,264	16,213	17,151	18,090	19,036	19,906	20,855	21,746	22,638	23,539	24,467	25,372	26,258	
Cumulative gross output, kWhr		1,132,562	1,206,529	1,280,145	1,352,594	1,426,027	1,498,742	1,567,076	1,641,743	1,711,283	1,781,131	1,852,462	1,925,341	1,995,955	2,064,101	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV		11,458	11,557	11,600	11,652	11,520	11,707	11,460	11,436	11,542	11,491	11,376	11,462	11,541	11,700	
Daily heat rate, Btu/kWe gross HHV		12,728	12,838	12,886	12,944	12,797	13,005	12,731	12,704	12,821	12,765	12,637	12,733	12,821	12,997	
Cumulative heat rate, Btu/kWe gross LHV		11,378	11,389	11,401	11,414	11,420	11,434	11,435	11,435	11,439	11,441	11,439	11,440	11,443	11,452	
Cumulative heat rate, Btu/kWe gross HHV		12,639	12,651	12,665	12,680	12,686	12,701	12,703	12,703	12,708	12,710	12,707	12,708	12,712	12,721	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours		25,052	25,148	25,244	25,340	25,436	25,532	25,628	25,724	25,820	25,916	26,012	26,108	26,204	26,300	
Actual cumulative engine run hours		23,646	23,742	23,838	23,933	24,029	24,125	24,212	24,308	24,402	24,496	24,592	24,688	24,784	24,880	
Cumulative Availability, %		94.4%	94.4%	94.4%	94.4%	94.5%	94.5%	94.5%	94.5%	94.5%	94.5%	94.5%	94.6%	94.6%	94.6%	
Max cumulative gross output, kWhr		20,667,900	20,747,100	20,826,300	20,905,500	20,984,700	21,063,900	21,143,100	21,222,300	21,301,500	21,380,700	21,459,900	21,539,100	21,618,300	21,697,500	
Actual cumulative gross output, kWhr		17,256,954	17,330,921	17,404,537	17,476,986	17,550,419	17,623,134	17,691,468	17,766,135	17,835,675	17,905,523	17,976,854	18,049,733	18,120,347	18,188,493	
Cumulative Capacity Factor		83.5%	83.5%	83.6%	83.6%	83.6%	83.7%	83.7%	83.7%	83.7%	83.7%	83.8%	83.8%	83.8%	83.8%	
Cumulative fuel input, MMBtu HHV		213,582	214,532	215,480	216,418	217,358	218,303	219,173	220,122	221,014	221,905	222,807	223,735	224,640	225,526	
Cumulative gross output, kWhr		17,256,954	17,330,921	17,404,537	17,476,986	17,550,419	17,623,134	17,691,468	17,766,135	17,835,675	17,905,523	17,976,854	18,049,733	18,120,347	18,188,493	
Cumulative heat rate, Btu/kWe gross LHV		11,141	11,143	11,145	11,147	11,149	11,151	11,152	11,153	11,155	11,156	11,157	11,158	11,160	11,162	
Cumulative heat rate, Btu/kWe gross HHV		12,377	12,379	12,381	12,383	12,385	12,387	12,389	12,390	12,392	12,393	12,394	12,395	12,397	12,399	
Service																
Engine 1																
Engine 2																
Engine 3																
Engine 4																
Dungs valve failure																
Reverse power shutdown																
Tighten EMCPII wires																
Oil Change																
Watered out wells																
Dewatering program in progress																
Oil - oil and filter change																
Service - plugs, air filter, valve inspection and adjust																
NSTAR Power Reports																
Date		Wednesday 9/17/2008	Thursday 9/18/2008	Friday 9/19/2008	Saturday 9/20/2008	Sunday 9/21/2008	Monday 9/22/2008	Tuesday 9/23/2008	Wednesday 9/24/2008	Thursday 9/25/2008	Friday 9/26/2008	Saturday 9/27/2008	Sunday 9/28/2008	Monday 9/29/2008	Tuesday 9/30/2008	TOTAL
Hour																
1		3,073	3,075	3,050	3,026	3,024	3,016	2,339	3,024	3,022	3,026	2,998	3,000	2,996	2,935	
2		3,074	3,076	3,051	3,026	3,025	3,015	2,342	3,025	3,022	3,027	2,999	3,000	2,994	2,933	
3		2,517	3,075	3,050	3,026	3,025	3,015	2,342	3,025	3,022	3,026	2,999	3,000	2,993	2,932	
4		3,078	3,075	3,050	3,026	3,025	3,013	2,343	3,025	3,022	3,027	2,997	3,000	2,991	2,933	
5		3,078	3,076	3,050	3,025	3,024	3,014	2,343	3,025	3,021	3,027	2,998	2,999	2,991	2,933	
6		3,077	3,076	3,049	3,026	3,024	3,015	2,344	3,025	3,019	3,027	2,997	3,000	2,988	2,931	
7		3,078	3,077	3,050	3,026	3,025	3,015	2,345	3,026	3,019	3,027	2,998	2,998	2,990	2,932	
8		3,077	3,076	3,049	3,025	3,024	3,014	2,345	3,024	3,015	3,026	2,998	2,998	2,993	2,931	
9		3,074	3,074	3,048	3,025	3,022	3,011	2,343	3,023	3,016	2,902	3,001	2,998	2,990	2,930	
10		3,072	3,073	3,048	3,024	3,020	3,010	2,816	3,021	2,992	2,251	3,000	2,998	2,978	2,930	
11		3,071	2,980	3,044	2,824	3,017	3,003	3,025	3,019	2,970	2,697	3,001	2,997	2,948	2,916	
12		3,069	3,044	3,035	2,339	3,015	2,994	3,024	3,017	2,677	3,007	3,000	2,997	2,950	2,839	
13		3,071	3,044	3,021	2,985	3,014	2,995	3,023	3,018	2,298	3,005	3,001	3,000	2,950	2,702	
14		3,070	3,043	3,021	3,021	3,013	2,996	3,022	3,017	2,400	3,004	3,000	2,999	2,950	2,704	
15		3,071	3,045	3,021	3,020	3,013	2,996	3,021	3,017	2,906	3,006	3,001	2,999	2,950	2,703	
16		3,069	3,046	3,021	3,019	3,015	2,996	3,022	3,017	3,029	3,005	2,999	2,999	2,949	2,703	
17		3,070	3,046	3,022	3,018	3,015	2,996	3,023	3,019	3,028	3,004	3,002	2,998	2,949	2,704	
18		3,071	3,048	3,023	3,019	3,016	2,996	3,023	3,019	3,028	3,003	3,002	2,998	2,946	2,705	
19		3,071	3,048	3,024	3,020	3,015	2,992	3,023	3,021	3,028	2,999	3,001	2,998	2,941	2,706	
20		3,073	3,048	3,025	3,022	3,016	2,994	3,025	3,021	3,028	2,999	2,999	2,997	2,940	2,706	
21		3,073	3,049	3,025	3,023	3,016	2,992	3,025	3,022	3,028	2,997	3,000	2,998	2,936	2,707	
22		3,074	3,049	3,024	3,024	3,016	2,990	3,024	3,022	3,027	3,000	2,999	2,996	2,935	2,705	
23		3,074	3,049	3,024	3,024	3,016	2,989	3,025	3,022	3,027	2,999	3,000	2,996	2,933	2,705	
24		3,075	3,049	3,026	3,024	3,015	2,913	3,025	3,021	3,027	2,999	3,001	2,997	2,936	2,705	
TOTAL		73,200	73,341	72,851	71,637	72,450	71,980	66,232	72,515	70,671	71,090	71,991	71,960	71,117	67,530	2,044,188
Cumulative Output Sold, kWhr		1,118,823	1,192,164	1,265,015	1,336,652	1,409,102	1,481,082	1,547,314	1,619,829	1,690,500	1,761,590	1,833,581	1,905,541	1,976,658	2,044,188	

OCTOBER 2008																	
CNBE Daily Reports Summary Data																	
	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	
	10/1/2008	10/2/2008	10/3/2008	10/4/2008	10/5/2008	10/6/2008	10/7/2008	10/8/2008	10/9/2008	10/10/2008	10/11/2008	10/12/2008	10/13/2008	10/14/2008	10/15/2008	10/16/2008	
Landfill Gas Flow to the Engines (KSCF)	1,687	1,714	1,839	1,689	1,820	1,743	1,692	1,709	1,681	1,700	1,660	1,676	1,630	1,670	1,707	1,697	
Landfill Gas Flow to the Engines (MMBTU HHV)	908	901	952	883	955	922	900	909	916	913	884	902	886	907	923	920	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,687	1,714	1,839	1,689	1,820	1,743	1,692	1,709	1,681	1,700	1,660	1,676	1,630	1,670	1,707	1,697	
Landfill Gas Total Flow (MMBTU HHV)	908	901	952	883	955	922	900	909	916	913	884	902	886	907	923	920	
Average Methane Content wet (%)	53.2	52.0	51.1	51.6	51.9	52.3	52.6	52.6	53.8	53.1	52.6	53.2	53.7	53.7	53.4	53.6	
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
Generator 1 Power Output (kWhr)	18,530	18,560	18,361	16,279	17,615	17,342	17,010	17,867	15,623	16,881	16,419	16,613	16,320	16,680	16,849	18,110	
Generator 2 Power Output (kWhr)	15,496	16,030	17,253	16,407	17,758	17,108	16,611	17,448	17,737	16,459	15,984	16,183	15,878	16,245	16,390	16,962	
Generator 3 Power Output (kWhr)	17,985	18,431	18,271	16,171	17,487	16,847	16,328	17,150	16,219	16,505	16,337	16,548	16,240	16,692	17,012	17,245	
Generator 4 Power Output (kWhr)	17,749	16,324	17,117	15,738	17,051	16,805	16,566	17,400	17,332	16,359	15,877	16,111	15,822	16,217	17,028	17,336	
Gross Power Output (kWhr)	69,759	69,345	71,002	64,595	69,911	68,102	66,514	69,865	66,911	66,204	64,618	65,455	64,260	65,835	67,279	69,653	
Net Power Output (kWhr)	67,746	67,241	68,967	62,874	68,101	66,296	64,684	67,943	65,068	64,352	62,866	63,696	62,546	64,083	65,430	67,653	
Power Sold as metered by NStar, (kWhr)	69,236	72,350	67,820	66,240	66,330	67,280	67,096	67,766	65,456	66,224	65,388	65,401	65,420	65,580	66,316	67,113	
Offgrid RECs (kWhr)	2,013	2,104	2,035	1,721	1,810	1,806	1,830	1,922	1,843	1,852	1,752	1,759	1,714	1,752	1,849	2,000	
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	772	773	765	678	734	723	709	744	651	703	684	692	680	695	702	755	
Generator 2	646	668	719	684	740	713	692	727	739	686	666	674	662	677	683	707	
Generator 3	749	768	761	674	729	702	680	715	676	688	681	689	677	696	709	719	
Generator 4	740	680	713	656	710	700	690	725	722	682	662	671	659	676	709	722	
Power output (kW average over 24-hrs)																	
Facility Gross	2,907	2,889	2,958	2,691	2,913	2,838	2,771	2,911	2,788	2,759	2,692	2,727	2,678	2,743	2,803	2,902	
Facility Net	2,823	2,802	2,874	2,620	2,838	2,762	2,695	2,831	2,711	2,681	2,619	2,654	2,606	2,670	2,726	2,819	
In-plant load	84	88	85	72	75	75	76	80	77	77	73	73	71	73	77	83	
Daily availability factor																	
Facility	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	82%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																	
Facility	88%	88%	90%	82%	88%	86%	84%	88%	84%	84%	82%	83%	81%	83%	85%	88%	
Engine 1	94%	94%	93%	82%	89%	88%	86%	90%	79%	85%	83%	84%	82%	84%	85%	91%	
Engine 2	78%	81%	87%	83%	90%	86%	84%	88%	82%	83%	81%	82%	80%	83%	83%	86%	
Engine 3	91%	93%	92%	82%	88%	85%	82%	87%	82%	83%	83%	84%	82%	84%	86%	87%	
Engine 4	90%	82%	86%	79%	86%	85%	84%	88%	88%	83%	80%	81%	80%	82%	86%	88%	
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	
Engine 1	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	
Engine 2	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	
Engine 3	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	
Engine 4	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	
Engine operating run hours total from 0 hours																	
Engine 1	24,627	24,651	24,675	24,699	24,723	24,747	24,771	24,795	24,819	24,843	24,867	24,891	24,915	24,939	24,963	24,987	
Engine 2	24,494	24,518	24,542	24,566	24,590	24,614	24,638	24,662	24,686	24,710	24,734	24,758	24,782	24,806	24,830	24,854	
Engine 3	24,110	24,134	24,158	24,182	24,206	24,230	24,254	24,278	24,302	24,326	24,350	24,374	24,398	24,422	24,446	24,470	
Engine 4	24,362	24,386	24,410	24,434	24,458	24,482	24,506	24,530	24,554	24,578	24,602	24,626	24,650	24,674	24,698	24,722	
Cumulative availability, %																	
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200	
Engine 1	772	1,545	2,310	2,989	3,723	4,445	5,154	5,898	6,549	7,253	7,937	8,629	9,309	10,004	10,706	11,461	
Engine 2	646	1,314	2,032	2,716	3,456	4,169	4,861	5,588	6,327	7,013	7,679	8,353	9,015	9,692	10,374	11,081	
Engine 3	749	1,517	2,279	2,952	3,681	4,383	5,063	5,778	6,454	7,141	7,822	8,512	9,188	9,884	10,593	11,311	
Engine 4	740	1,420	2,133	2,789	3,499	4,199	4,890	5,615	6,337	7,018	7,680	8,351	9,010	9,686	10,396	11,118	
Cumulative capacity factor, %																	
Engine 1	94%	94%	93%	91%	90%	90%	89%	89%	88%	88%	87%	87%	87%	87%	87%	87%	
Engine 2	78%	80%	82%	82%	84%	84%	85%	85%	85%	85%	85%	84%	84%	84%	84%	84%	
Engine 3	91%	92%	92%	89%	89%	89%	88%	88%	87%	87%	86%	86%	86%	86%	86%	86%	
Engine 4	90%	86%	86%	85%	85%	85%	85%	85%	85%	85%	85%	84%	84%	84%	84%	84%	

OCTOBER 2008

		Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday
		10/1/2008	10/2/2008	10/3/2008	10/4/2008	10/5/2008	10/6/2008	10/7/2008	10/8/2008	10/9/2008	10/10/2008	10/11/2008	10/12/2008	10/13/2008	10/14/2008	10/15/2008	10/16/2008
Cumulative by Facility in month																	
	Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
	Actual cumulative engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
	Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
	Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200
	Actual cumulative gross output, kWhr	69,759	139,104	210,106	274,701	344,612	412,714	479,228	549,093	616,004	682,208	746,826	812,281	876,541	942,376	1,009,655	1,079,308
	Cumulative Capacity Factor	88.1%	87.8%	88.4%	86.7%	87.0%	86.9%	86.4%	86.7%	86.4%	86.1%	85.7%	85.5%	85.1%	85.0%	85.0%	85.2%
	Cumulative fuel input, MMBtu HHV	908	1,810	2,761	3,644	4,599	5,522	6,422	7,331	8,248	9,161	10,044	10,947	11,832	12,740	13,662	14,582
	Cumulative gross output, kWhr	69,759	139,104	210,106	274,701	344,612	412,714	479,228	549,093	616,004	682,208	746,826	812,281	876,541	942,376	1,009,655	1,079,308
Heat Rate																	
	Daily heat rate, Btu/kWe gross LHV	11,721	11,702	12,064	12,302	12,303	12,188	12,186	11,718	12,326	12,417	12,311	12,411	12,405	12,404	12,349	11,890
	Daily heat rate, Btu/kWe gross HHV	13,020	12,999	13,402	13,666	13,667	13,539	13,537	13,017	13,692	13,794	13,676	13,786	13,780	13,780	13,718	13,208
	Cumulative heat rate, Btu/kWe gross LHV	11,721	11,711	11,831	11,941	12,015	12,043	12,063	12,019	12,053	12,088	12,107	12,132	12,152	12,169	12,181	12,163
	Cumulative heat rate, Btu/kWe gross HHV	13,020	13,010	13,142	13,265	13,347	13,379	13,401	13,352	13,389	13,428	13,450	13,477	13,499	13,519	13,532	13,511
Cumulative by Facility starting Calendar Year																	
	Max cumulative available engine run hours	26,396	26,492	26,588	26,684	26,780	26,876	26,972	27,068	27,164	27,260	27,356	27,452	27,548	27,644	27,740	27,836
	Actual cumulative engine run hours	24,976	25,072	25,168	25,264	25,360	25,456	25,552	25,648	25,744	25,840	25,936	26,032	26,128	26,224	26,320	26,416
	Cumulative Availability, %	94.6%	94.6%	94.7%	94.7%	94.7%	94.7%	94.7%	94.8%	94.8%	94.8%	94.8%	94.8%	94.8%	94.9%	94.9%	94.9%
	Max cumulative gross output, kWhr	21,776,700	21,855,900	21,935,100	22,014,300	22,093,500	22,172,700	22,251,900	22,331,100	22,410,300	22,489,500	22,568,700	22,647,900	22,727,100	22,806,300	22,885,500	22,964,700
	Actual cumulative gross output, kWhr	18,258,252	18,327,597	18,398,599	18,463,194	18,533,105	18,601,207	18,667,721	18,737,587	18,804,497	18,870,701	18,935,319	19,000,774	19,065,034	19,130,869	19,198,148	19,267,801
	Cumulative Capacity Factor	83.8%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%	83.9%
	Cumulative fuel input, MMBtu HHV	226,434	227,335	228,287	229,170	230,125	231,047	231,947	232,857	233,773	234,686	235,570	236,472	237,358	238,265	239,188	240,108
	Cumulative gross output, kWhr	18,258,252	18,327,597	18,398,599	18,463,194	18,533,105	18,601,207	18,667,721	18,737,587	18,804,497	18,870,701	18,935,319	19,000,774	19,065,034	19,130,869	19,198,148	19,267,801
	Cumulative heat rate, Btu/kWe gross LHV	11,164	11,166	11,170	11,173	11,178	11,181	11,185	11,187	11,191	11,195	11,199	11,203	11,207	11,211	11,215	11,218
	Cumulative heat rate, Btu/kWe gross HHV	12,402	12,404	12,408	12,412	12,417	12,421	12,425	12,427	12,432	12,437	12,441	12,445	12,450	12,454	12,459	12,462
Service																	
	Engine 1																Lowered engines
	Engine 2																to 300 kW for
	Engine 3																LFGCS repairs.
	Engine 4																
Oil - oil and filter change																	
Service - plugs, air filter, valve inspection and adjustment																	
	NSTAR Power Reports	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday
	Date	10/1/2008	10/2/2008	10/3/2008	10/4/2008	10/5/2008	10/6/2008	10/7/2008	10/8/2008	10/9/2008	10/10/2008	10/11/2008	10/12/2008	10/13/2008	10/14/2008	10/15/2008	10/16/2008
	Hour																
	1	2,706	3,100	2,950	2,760	2,770	2,770	2,801	2,796	2,845	2,794	2,726	2,725	2,727	2,729	2,746	2,784
	2	2,707	3,100	2,950	2,760	2,770	2,770	2,801	2,797	2,845	2,794	2,726	2,726	2,726	2,725	2,746	2,784
	3	2,707	3,100	2,950	2,760	2,770	2,770	2,801	2,796	2,844	2,794	2,726	2,727	2,727	2,727	2,747	2,784
	4	2,707	3,100	2,950	2,760	2,770	2,770	2,801	2,796	2,843	2,794	2,727	2,726	2,727	2,727	2,747	2,783
	5	2,707	3,100	2,950	2,760	2,770	2,770	2,801	2,796	2,842	2,795	2,727	2,726	2,727	2,727	2,748	2,784
	6	2,708	3,100	2,950	2,760	2,770	2,770	2,800	2,797	2,842	2,796	2,726	2,726	2,727	2,727	2,747	2,782
	7	2,709	3,100	2,950	2,760	2,770	2,770	2,800	2,797	2,843	2,797	2,727	2,727	2,727	2,727	2,747	2,782
	8	2,709	2,900	2,950	2,760	2,770	2,770	2,800	2,797	2,843	2,797	2,727	2,727	2,728	2,727	2,748	2,761
	9	2,707	2,900	2,860	2,760	2,770	2,820	2,800	2,796	2,136	2,796	2,725	2,726	2,726	2,727	2,746	2,311
	10	2,706	2,900	2,750	2,760	2,760	2,820	2,795	2,795	2,157	2,794	2,724	2,724	2,726	2,726	2,746	2,743
	11	2,943	2,900	2,750	2,760	2,760	2,820	2,791	2,834	2,378	2,791	2,723	2,724	2,724	2,725	2,742	2,740
	12	3,028	2,900	2,750	2,760	2,760	2,820	2,791	2,841	2,520	2,790	2,722	2,723	2,724	2,725	2,746	2,738
	13	3,026	2,900	2,750	2,760	2,760	2,820	2,790	2,842	2,796	2,742	2,722	2,722	2,723	2,724	2,779	2,739
	14	3,026	2,900	2,760	2,760	2,760	2,820	2,790	2,842	2,793	2,718	2,721	2,723	2,722	2,723	2,778	2,738
	15	3,024	2,900	2,760	2,760	2,760	2,820	2,788	2,842	2,791	2,718	2,722	2,723	2,722	2,724	2,778	2,817
	16	3,025	3,050	2,760	2,760	2,760	2,820	2,790	2,842	2,791	2,721	2,722	2,723	2,724	2,725	2,778	2,865
	17	3,025	3,050	2,760	2,760	2,760	2,820	2,792	2,844	2,793	2,722	2,723	2,724	2,726	2,743	2,779	2,903
	18	3,025	3,050	2,760	2,760	2,760	2,820	2,793	2,844	2,793	2,723	2,723	2,725	2,727	2,746	2,779	2,897
	19	3,024	3,050	2,760	2,760	2,760	2,820	2,794	2,845	2,794	2,723	2,724	2,724	2,727	2,746	2,780	2,898
	20	3,012	3,050	2,760	2,760	2,760	2,820	2,795	2,846	2,794	2,723	2,724	2,725	2,726	2,747	2,781	2,894
	21	3,006	3,050	2,760	2,760	2,760	2,820	2,795	2,846	2,794	2,726	2,725	2,726	2,727	2,746	2,781	2,897
	22	3,003	3,050	2,760	2,760	2,760	2,820	2,795	2,845	2,793	2,724	2,725	2,726	2,726	2,746	2,782	2,897
	23	3,000	3,050	2,760	2,760	2,760	2,820	2,796	2,846	2,793	2,726	2,725	2,726	2,727	2,746	2,782	2,895
	24	2,996	3,050	2,760	2,760	2,760	2,820	2,796	2,844	2,793	2,726	2,726	2,727	2,727	2,745	2,783	2,897
	TOTAL	69,236	72,350	67,820	66,240	66,330	67,280	67,096	67,766	65,456	66,224	65,388	65,401	65,420	65,580	66,316	67,113
	Cumulative Output Sold, kWhr	69,236	141,586	209,406	275,646	341,976	409,256	476,352	544,118	609,574	675,798	741,186	806,587	872,007	937,587	1,003,903	1,071,016

OCTOBER 2008																	
CNBE Daily Reports Summary Data																	
	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday		
	10/17/2008	10/18/2008	10/19/2008	10/20/2008	10/21/2008	10/22/2008	10/23/2008	10/24/2008	10/25/2008	10/26/2008	10/27/2008	10/28/2008	10/29/2008	10/30/2008	10/31/2008	TOTAL	
Landfill Gas Flow to the Engines (KSCF)	1,757	1,918	1,915	1,808	1,731	1,798	1,732	1,847	1,826	1,795	1,770	1,776	1,786	1,707	1,707	54,188	
Landfill Gas Flow to the Engines (MMBTU HHV)	928	1,005	1,003	955	948	984	941	1,013	1,019	1,020	1,024	1,007	996	934	938	29,296	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,757	1,918	1,915	1,808	1,731	1,798	1,732	1,847	1,826	1,795	1,770	1,776	1,786	1,707	1,707	54,188	
Landfill Gas Total Flow (MMBTU HHV)	928	1,005	1,003	955	948	984	941	1,013	1,019	1,020	1,024	1,007	996	934	938	29,296	
Average Methane Content wet (%)	52.2	51.8	51.8	52.2	54.1	54.1	53.7	54.2	55.2	56.1	57.8	56.7	55.8	54.7	54.9	53.4	
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	22	24	24	24	742	
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	744	
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	22	742	
Engine 4 Hours	24	24	24	24	24	24	23	24	24	24	24	24	24	24	24	743	
Generator 1 Power Output (kWhr)	19,918	20,525	20,496	19,548	19,190	19,401	19,148	20,151	20,497	20,504	20,585	17,736	19,361	18,541	19,623	570,284	
Generator 2 Power Output (kWhr)	16,768	16,830	16,806	16,367	16,334	17,323	16,994	17,992	18,302	18,308	18,380	19,151	18,649	17,754	18,707	530,617	
Generator 3 Power Output (kWhr)	17,478	17,978	17,952	17,000	16,660	17,247	16,341	17,914	18,222	18,228	18,300	19,163	19,124	17,894	16,968	537,938	
Generator 4 Power Output (kWhr)	17,136	17,711	17,686	16,797	16,422	17,322	16,270	17,991	18,301	18,307	18,379	18,585	18,606	17,962	18,918	533,225	
Gross Power Output (kWhr)	71,300	73,044	72,941	69,713	68,606	71,294	68,754	74,048	75,322	75,348	75,643	74,635	75,740	72,151	74,216	2,172,063	
Net Power Output (kWhr)	69,451	70,859	70,759	67,698	66,779	69,507	67,073	72,261	73,535	73,561	73,856	72,882	73,977	70,489	72,515	2,114,748	
Power Sold as metered by NStar, (kWhr)	69,104	68,661	68,564	68,035	67,798	69,915	67,547	71,900	73,167	73,193	73,487	72,678	74,543	70,868	73,078	2,133,554	
Offgrid RECs (kWhr)	1,849	2,185	2,182	2,015	1,827	1,787	1,681	1,787	1,787	1,787	1,787	1,753	1,763	1,662	1,701	57,315	
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	830	855	854	815	800	808	798	840	854	854	858	806	807	773	818		
Generator 2	699	701	700	682	681	722	708	750	763	763	766	798	777	740	779		
Generator 3	728	749	748	708	694	719	681	746	759	760	762	798	797	746	771		
Generator 4	714	738	737	700	684	722	707	750	763	763	766	774	775	748	788		
Power output (kW average over 24-hrs)																	
Facility Gross	2,971	3,044	3,039	2,905	2,859	2,971	2,865	3,085	3,138	3,139	3,152	3,110	3,156	3,006	3,092		
Facility Net	2,894	2,952	2,948	2,821	2,782	2,896	2,795	3,011	3,064	3,065	3,077	3,037	3,082	2,937	3,021		
In-plant load	77	91	91	84	76	74	70	74	74	74	74	73	73	69	71		
Daily availability factor																	
Facility	100%	100%	100%	100%	100%	100%	99%	100%	100%	100%	100%	98%	100%	100%	98%		
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%		
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%		
Engine 4	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%		
Daily capacity factor																	
Facility	90%	92%	92%	88%	87%	90%	87%	93%	95%	95%	96%	94%	96%	91%	94%		
Engine 1	101%	104%	104%	99%	97%	98%	97%	102%	104%	104%	104%	98%	98%	94%	99%		
Engine 2	85%	85%	85%	83%	82%	87%	86%	91%	92%	92%	93%	97%	94%	90%	94%		
Engine 3	88%	91%	91%	86%	84%	87%	83%	90%	92%	92%	92%	97%	97%	90%	93%		
Engine 4	87%	89%	89%	85%	83%	87%	86%	91%	92%	92%	93%	94%	94%	91%	96%		
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744		
Engine 1	408	432	456	480	504	528	552	576	600	624	648	670	694	718	742		
Engine 2	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744		
Engine 3	408	432	456	480	504	528	552	576	600	624	648	672	696	720	742		
Engine 4	408	432	456	480	504	528	551	575	599	623	647	671	695	719	743		
Engine operating run hours total from 0 hours																	
Engine 1	25,011	25,035	25,059	25,083	25,107	25,131	25,155	25,179	25,203	25,227	25,251	25,273	25,297	25,321	25,345		
Engine 2	24,878	24,902	24,926	24,950	24,974	24,998	25,022	25,046	25,070	25,094	25,118	25,142	25,166	25,190	25,214		
Engine 3	24,494	24,518	24,542	24,566	24,590	24,614	24,638	24,662	24,686	24,710	24,734	24,758	24,782	24,806	24,828		
Engine 4	24,746	24,770	24,794	24,818	24,842	24,866	24,889	24,913	24,937	24,961	24,985	25,009	25,033	25,057	25,081		
Cumulative availability, %																	
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575		
Engine 1	12,291	13,146	14,000	14,814	15,614	16,422	17,220	18,060	18,914	19,768	20,626	21,432	22,239	23,011	23,829		
Engine 2	11,780	12,481	13,181	13,863	14,544	15,266	15,974	16,724	17,486	18,249	19,015	19,813	20,590	21,330	22,109		
Engine 3	12,039	12,789	13,537	14,245	14,939	15,658	16,339	17,085	17,844	18,604	19,366	20,165	20,962	21,707	22,478		
Engine 4	11,832	12,570	13,307	14,007	14,691	15,413	16,120	16,870	17,632	18,395	19,161	19,935	20,711	21,459	22,247		
Cumulative capacity factor, %																	
Engine 1	88%	89%	89%	90%	90%	90%	91%	91%	92%	92%	93%	93%	93%	93%	93%		
Engine 2	84%	84%	84%	84%	84%	84%	84%	84%	85%	85%	85%	86%	86%	86%	86%		
Engine 3	86%	86%	86%	86%	86%	86%	86%	86%	87%	87%	87%	87%	88%	88%	88%		
Engine 4	84%	85%	85%	85%	85%	85%	85%	85%	85%	86%	86%	86%	87%	87%	87%		

OCTOBER 2008

		Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	
		10/17/2008	10/18/2008	10/19/2008	10/20/2008	10/21/2008	10/22/2008	10/23/2008	10/24/2008	10/25/2008	10/26/2008	10/27/2008	10/28/2008	10/29/2008	10/30/2008	10/31/2008	TOTAL
Cumulative by Facility in month																	
	Max cumulative available engine run hours	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976	
	Actual cumulative engine run hours	1,632	1,728	1,824	1,920	2,016	2,112	2,207	2,303	2,399	2,495	2,591	2,685	2,781	2,877	2,971	
	Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	99.9%	99.9%	99.9%	99.8%	
	Max cumulative gross output, kWhr	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200	
	Actual cumulative gross output, kWhr	1,150,608	1,223,652	1,296,593	1,366,306	1,434,912	1,506,206	1,574,960	1,649,008	1,724,330	1,799,678	1,875,321	1,949,956	2,025,696	2,097,847	2,172,063	
	Cumulative Capacity Factor	85.5%	85.8%	86.2%	86.3%	86.3%	86.4%	86.5%	86.8%	87.1%	87.4%	87.7%	87.9%	88.2%	88.3%	88.5%	
	Cumulative fuel input, MMBtu HHV	15,510	16,515	17,518	18,474	19,421	20,405	21,346	22,359	23,379	24,398	25,422	26,429	27,425	28,359	29,296	
	Cumulative gross output, kWhr	1,150,608	1,223,652	1,296,593	1,366,306	1,434,912	1,506,206	1,574,960	1,649,008	1,724,330	1,799,678	1,875,321	1,949,956	2,025,696	2,097,847	2,172,063	
Heat Rate																	
	Daily heat rate, Btu/kWe gross LHV	11,715	12,382	12,382	12,338	12,433	12,425	12,316	12,316	12,184	12,184	12,184	12,142	11,836	11,650	11,374	
	Daily heat rate, Btu/kWe gross HHV	13,014	13,755	13,755	13,705	13,812	13,802	13,682	13,682	13,535	13,535	13,535	13,488	13,148	12,942	12,635	
	Cumulative heat rate, Btu/kWe gross LHV	12,135	12,150	12,163	12,172	12,184	12,195	12,201	12,206	12,205	12,204	12,203	12,201	12,187	12,169	12,142	
	Cumulative heat rate, Btu/kWe gross HHV	13,480	13,497	13,511	13,521	13,535	13,548	13,553	13,559	13,558	13,557	13,556	13,554	13,538	13,518	13,488	
Cumulative by Facility starting Calendar Year																	
	Max cumulative available engine run hours	27,932	28,028	28,124	28,220	28,316	28,412	28,508	28,604	28,700	28,796	28,892	28,988	29,084	29,180	29,276	
	Actual cumulative engine run hours	26,512	26,608	26,704	26,800	26,896	26,992	27,087	27,183	27,279	27,375	27,471	27,565	27,661	27,757	27,851	
	Cumulative Availability, %	94.9%	94.9%	95.0%	95.0%	95.0%	95.0%	95.0%	95.0%	95.0%	95.1%	95.1%	95.1%	95.1%	95.1%	95.1%	
	Max cumulative gross output, kWhr	23,043,900	23,123,100	23,202,300	23,281,500	23,360,700	23,439,900	23,519,100	23,598,300	23,677,500	23,756,700	23,835,900	23,915,100	23,994,300	24,073,500	24,152,700	
	Actual cumulative gross output, kWhr	19,339,101	19,412,145	19,485,086	19,554,799	19,623,405	19,694,699	19,763,453	19,837,502	19,912,823	19,988,171	20,063,814	20,138,449	20,214,189	20,286,340	20,360,556	
	Cumulative Capacity Factor	83.9%	84.0%	84.0%	84.0%	84.0%	84.0%	84.0%	84.1%	84.1%	84.1%	84.2%	84.2%	84.2%	84.3%	84.3%	
	Cumulative fuel input, MMBtu HHV	241,036	242,041	243,044	243,999	244,947	245,931	246,872	247,885	248,904	249,924	250,948	251,954	252,950	253,884	254,822	
	Cumulative gross output, kWhr	19,339,101	19,412,145	19,485,086	19,554,799	19,623,405	19,694,699	19,763,453	19,837,502	19,912,823	19,988,171	20,063,814	20,138,449	20,214,189	20,286,340	20,360,556	
	Cumulative heat rate, Btu/kWe gross LHV	11,220	11,224	11,228	11,232	11,237	11,241	11,245	11,249	11,252	11,256	11,259	11,262	11,265	11,266	11,266	
	Cumulative heat rate, Btu/kWe gross HHV	12,464	12,469	12,473	12,478	12,482	12,487	12,491	12,496	12,500	12,504	12,507	12,511	12,514	12,515	12,515	
Service																	
	Engine 1																
	Engine 2																
	Engine 3																
	Engine 4																
Oil - oil and filter change																	
Service - plugs, air filter, valve inspection and adjustn																	
		Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	
	Date	10/17/2008	10/18/2008	10/19/2008	10/20/2008	10/21/2008	10/22/2008	10/23/2008	10/24/2008	10/25/2008	10/26/2008	10/27/2008	10/28/2008	10/29/2008	10/30/2008	10/31/2008	TOTAL
	Hour																
	1	2,897	2,876	2,869	2,861	2,825	2,829	2,950	2,904	3,052	3,046	3,050	3,072	3,142	3,039	3,076	
	2	2,896	2,877	2,867	2,861	2,824	2,828	2,950	2,911	3,052	3,048	3,050	3,072	3,141	3,052	3,058	
	3	2,895	2,864	2,867	2,860	2,824	2,829	2,950	2,906	3,052	3,050	3,050	3,072	3,141	3,042	3,050	
	4	2,893	2,861	2,873	2,858	2,824	2,829	2,949	2,905	3,050	3,052	3,049	3,073	3,141	3,034	3,075	
	5	2,888	2,853	2,865	2,861	2,824	2,829	2,950	2,912	3,050	3,049	3,049	3,072	3,141	3,039	3,052	
	6	2,884	2,852	2,865	2,865	2,824	2,829	2,949	2,905	3,052	3,048	3,050	3,072	3,141	3,046	3,060	
	7	2,879	2,852	2,864	2,868	2,824	2,869	2,949	2,908	3,051	3,050	3,049	3,073	3,140	3,044	3,055	
	8	2,874	2,868	2,866	2,868	2,824	2,924	2,951	2,910	3,050	3,051	3,051	3,073	3,140	3,046	2,847	
	9	2,884	2,865	2,862	2,804	2,823	2,922	2,950	2,905	3,050	3,050	3,049	2,999	3,140	3,038	2,364	
	10	2,886	2,865	2,855	2,816	2,822	2,928	2,950	3,014	3,049	3,051	3,048	2,403	3,140	3,036	2,374	
	11	2,884	2,865	2,853	2,817	2,821	2,930	2,627	3,053	3,048	3,050	3,062	2,470	3,132	2,909	2,982	
	12	2,879	2,864	2,848	2,817	2,822	2,952	1,858	3,051	3,047	3,050	3,071	3,142	3,068	2,200	3,162	
	13	2,876	2,863	2,846	2,818	2,821	2,953	1,867	3,052	3,047	3,050	3,070	2,624	3,061	2,146	3,138	
	14	2,870	2,861	2,852	2,818	2,824	2,953	2,603	3,051	3,046	3,049	3,070	3,203	3,066	2,261	3,164	
	15	2,868	2,860	2,854	2,819	2,825	2,952	2,914	3,051	3,047	3,049	3,070	2,937	3,120	3,064	3,168	
	16	2,862	2,860	2,848	2,824	2,826	2,953	2,913	3,051	3,048	3,050	3,071	3,171	3,136	3,101	3,168	
	17	2,862	2,858	2,844	2,824	2,827	2,952	2,911	3,052	3,048	3,049	3,071	3,147	3,133	3,101	3,168	
	18	2,862	2,857	2,851	2,825	2,827	2,952	2,910	3,052	3,047	3,049	3,072	3,144	3,090	3,101	3,169	
	19	2,880	2,855	2,853	2,825	2,827	2,951	2,906	3,052	3,048	3,050	3,073	3,143	3,061	3,100	3,168	
	20	2,877	2,851	2,849	2,825	2,828	2,951	2,909	3,051	3,047	3,051	3,074	3,143	3,063	3,100	3,167	
	21	2,880	2,849	2,852	2,825	2,828	2,950	2,909	3,051	3,047	3,051	3,074	3,143	3,074	3,099	3,164	
	22	2,877	2,848	2,852	2,825	2,828	2,950	2,905	3,051	3,047	3,050	3,072	3,144	3,039	3,095	3,149	
	23	2,876	2,865	2,853	2,825	2,828	2,950	2,910	3,051	3,046	3,050	3,071	3,143	3,044	3,088	3,153	
	24	2,875	2,872	2,856	2,826	2,828	2,950	2,907	3,051	3,046	3,050	3,071	3,143	3,049	3,087	3,147	
	TOTAL	69,104	68,661	68,564	68,035	67,798	69,915	67,547	71,900	73,167	73,193	73,487	72,678	74,543	70,868	73,078	2,133,554
	Cumulative Output Sold, kWhr	1,140,120	1,208,781	1,277,345	1,345,380	1,413,178	1,483,093	1,550,640	1,622,540	1,695,707	1,768,900	1,842,387	1,915,065	1,989,608	2,060,476	2,133,554	

NOVEMBER 2008															
CNBE Daily Reports Summary Data			Daylight savings												
	Saturday 11/1/2008	Sunday 11/2/2008	Monday 11/3/2008	Tuesday 11/4/2008	Wednesday 11/5/2008	Thursday 11/6/2008	Friday 11/7/2008	Saturday 11/8/2008	Sunday 11/9/2008	Monday 11/10/2008	Tuesday 11/11/2008	Wednesday 11/12/2008	Thursday 11/13/2008	Friday 11/14/2008	Saturday 11/15/2008
Landfill Gas Flow to the Engines (KSCF)	1,719	1,854	1,719	1,729	1,683	1,652	1,711	1,733	1,719	1,755	1,781	1,788	1,723	1,780	1,703
Landfill Gas Flow to the Engines (MMBTU HHV)	950	1,020	950	952	927	922	964	972	969	992	999	1,001	969	1,000	957
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,719	1,854	1,719	1,729	1,683	1,652	1,711	1,733	1,719	1,755	1,781	1,788	1,723	1,780	1,703
Landfill Gas Total Flow (MMBTU HHV)	950	1,020	950	952	927	922	964	972	969	992	999	1,001	969	1,000	957
Average Methane Content wet (%)	54.6	54.4	54.6	54.4	54.4	55.1	55.7	55.4	55.7	55.8	55.4	55.3	55.6	55.5	55.6
Engine 1 Hours	24	25	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 2 Hours	24	25	24	24	24	24	23	24	24	24	24	24	23	24	24
Engine 3 Hours	24	25	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 4 Hours	24	25	24	24	24	23	24	24	24	24	24	24	23	24	24
Generator 1 Power Output (kWhr)	19,730	20,724	19,917	19,802	19,489	19,575	19,828	19,513	19,363	19,570	19,791	19,818	19,540	19,886	19,228
Generator 2 Power Output (kWhr)	18,706	19,611	18,883	18,639	18,382	18,573	18,346	18,612	18,349	18,481	18,829	18,526	17,519	19,327	18,683
Generator 3 Power Output (kWhr)	19,470	20,377	19,654	19,569	19,339	19,407	19,682	19,486	19,372	19,527	19,748	19,722	19,445	19,841	19,243
Generator 4 Power Output (kWhr)	18,571	19,630	18,747	18,434	18,076	17,243	19,086	18,981	18,825	19,042	19,282	19,272	18,284	19,276	18,611
Gross Power Output (kWhr)	76,478	80,342	77,200	76,444	75,287	74,798	76,942	76,592	75,909	76,620	77,649	77,339	74,788	78,330	75,764
Net Power Output (kWhr)	74,701	78,492	75,400	74,642	73,458	73,007	75,105	74,749	74,137	74,758	75,677	75,362	72,922	76,347	73,815
Power Sold as metered by NStar, (kWhr)	75,228	78,389	75,320	75,293	75,387	74,622	75,319	75,495	75,360	75,286	75,357	75,075	73,682	75,733	75,696
Offgrid RECs (kWhr)	1,777	1,850	1,800	1,802	1,829	1,791	1,837	1,843	1,772	1,862	1,972	1,977	1,866	1,983	1,949
Calculated Performance Results															
Daily															
Power output (kW average when running)															
Generator 1	822	829	830	825	812	816	826	813	807	815	825	826	814	829	801
Generator 2	779	784	787	777	766	774	798	775	765	770	785	772	762	805	778
Generator 3	811	815	819	815	806	809	820	812	807	814	823	822	810	827	802
Generator 4	774	785	781	768	753	750	795	791	784	793	803	803	795	803	775
Power output (kW average over 24-hrs)															
Facility Gross	3,187	3,214	3,217	3,185	3,137	3,117	3,206	3,191	3,163	3,193	3,235	3,222	3,116	3,264	3,157
Facility Net	3,113	3,140	3,142	3,110	3,061	3,042	3,129	3,115	3,089	3,115	3,153	3,140	3,038	3,181	3,076
In-plant load	74	74	75	75	76	75	77	77	74	78	82	82	78	83	81
Daily availability factor															
Facility	100%	100%	100%	100%	100%	99%	99%	100%	100%	100%	100%	100%	98%	100%	100%
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 2	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	96%	100%	100%
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	98%	100%	100%	100%
Engine 4	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	96%	100%	100%
Daily capacity factor															
Facility	97%	97%	97%	97%	95%	94%	97%	97%	96%	97%	98%	98%	94%	99%	96%
Engine 1	100%	100%	101%	100%	98%	99%	100%	99%	98%	99%	100%	100%	99%	100%	97%
Engine 2	94%	95%	95%	94%	93%	94%	97%	94%	93%	93%	95%	94%	92%	98%	94%
Engine 3	98%	99%	99%	99%	98%	98%	99%	98%	98%	99%	100%	100%	98%	100%	97%
Engine 4	94%	95%	95%	93%	91%	91%	96%	96%	95%	96%	97%	97%	96%	97%	94%
Cumulative by engine															
Engine operating run hours in the month															
Max Cumulative Available, hours	24	49	73	97	121	145	169	193	217	241	265	289	313	337	361
Engine 1	24	49	73	97	121	145	169	193	217	241	265	289	313	337	361
Engine 2	24	49	73	97	121	145	168	192	216	240	264	288	311	335	359
Engine 3	24	49	73	97	121	145	169	193	217	241	265	289	313	337	361
Engine 4	24	49	73	97	121	144	168	192	216	240	264	288	311	335	359
Engine operating run hours total from 0 hours															
Engine 1	25,369	25,394	25,418	25,442	25,466	25,490	25,514	25,538	25,562	25,586	25,610	25,634	25,658	25,682	25,706
Engine 2	25,238	25,263	25,287	25,311	25,335	25,359	25,382	25,406	25,430	25,454	25,478	25,502	25,525	25,549	25,573
Engine 3	24,852	24,877	24,901	24,925	24,949	24,973	24,997	25,021	25,045	25,069	25,093	25,117	25,141	25,165	25,189
Engine 4	25,105	25,130	25,154	25,178	25,202	25,225	25,249	25,273	25,297	25,321	25,345	25,369	25,392	25,416	25,440
Cumulative availability, %															
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 2	100%	100%	100%	100%	100%	100%	99%	99%	100%	100%	100%	100%	99%	99%	99%
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 4	100%	100%	100%	100%	100%	99%	99%	99%	100%	100%	100%	100%	99%	99%	99%
Engine cumulative gross output, kWhr															
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375
Engine 1	822	1,651	2,481	3,306	4,118	4,934	5,760	6,573	7,380	8,195	9,020	9,845	10,660	11,488	12,289
Engine 2	779	1,564	2,351	3,127	3,893	4,667	5,465	6,240	7,005	7,775	8,559	9,331	10,093	10,898	11,677
Engine 3	811	1,626	2,445	3,261	4,066	4,875	5,695	6,507	7,314	8,128	8,951	9,772	10,583	11,409	12,211
Engine 4	774	1,559	2,340	3,108	3,861	4,611	5,406	6,197	6,982	7,775	8,578	9,381	10,176	10,980	11,755
Cumulative capacity factor, %															
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	99%
Engine 2	94%	95%	95%	95%	94%	94%	95%	95%	94%	94%	94%	94%	94%	94%	94%
Engine 3	98%	99%	99%	99%	99%	98%	99%	99%	99%	99%	99%	99%	99%	99%	99%
Engine 4	94%	94%	95%	94%	94%	93%	94%	94%	94%	94%	95%	95%	95%	95%	95%

	Saturday 11/1/2008	Sunday 11/2/2008	Monday 11/3/2008	Tuesday 11/4/2008	Wednesday 11/5/2008	Thursday 11/6/2008	Friday 11/7/2008	Saturday 11/8/2008	Sunday 11/9/2008	Monday 11/10/2008	Tuesday 11/11/2008	Wednesday 11/12/2008	Thursday 11/13/2008	Friday 11/14/2008	Saturday 11/15/2008
Cumulative by Facility in month															
Max cumulative available engine run hours	96	196	292	388	484	580	676	772	868	964	1,060	1,156	1,252	1,348	1,444
Actual cumulative engine run hours	96	196	292	388	484	579	674	770	866	962	1,058	1,154	1,248	1,344	1,440
Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	99.8%	99.7%	99.7%	99.8%	99.8%	99.8%	99.8%	99.7%	99.7%	99.7%
Max cumulative gross output, kWhr	79,200	161,700	240,900	320,100	399,300	478,500	557,700	636,900	716,100	795,300	874,500	953,700	1,032,900	1,112,100	1,191,300
Actual cumulative gross output, kWhr	76,478	156,820	234,020	310,464	385,751	460,549	537,491	614,083	689,992	766,612	844,261	921,600	996,388	1,074,718	1,150,482
Cumulative Capacity Factor	96.6%	97.0%	97.1%	97.0%	96.6%	96.2%	96.4%	96.4%	96.4%	96.4%	96.5%	96.6%	96.5%	96.6%	96.6%
Cumulative fuel input, MMBtu HHV	950	1,970	2,920	3,872	4,798	5,720	6,685	7,657	8,626	9,618	10,617	11,618	12,587	13,587	14,544
Cumulative gross output, kWhr	76,478	156,820	234,020	310,464	385,751	460,549	537,491	614,083	689,992	766,612	844,261	921,600	996,388	1,074,718	1,150,482
Heat Rate															
Daily heat rate, Btu/kWe gross LHV	11,177	11,434	11,072	11,211	11,083	11,096	11,282	11,426	11,494	11,654	11,579	11,648	11,666	11,490	11,376
Daily heat rate, Btu/kWe gross HHV	12,416	12,701	12,300	12,454	12,311	12,326	12,533	12,693	12,768	12,946	12,863	12,940	12,960	12,764	12,637
Cumulative heat rate, Btu/kWe gross LHV	11,177	11,308	11,231	11,226	11,198	11,181	11,196	11,224	11,254	11,294	11,320	11,348	11,372	11,380	11,380
Cumulative heat rate, Btu/kWe gross HHV	12,416	12,562	12,476	12,470	12,439	12,421	12,437	12,469	12,502	12,546	12,575	12,606	12,632	12,642	12,642
Cumulative by Facility starting Calendar Year															
Max cumulative available engine run hours	29,372	29,472	29,568	29,664	29,760	29,856	29,952	30,048	30,144	30,240	30,336	30,432	30,528	30,624	30,720
Actual cumulative engine run hours	27,947	28,047	28,143	28,239	28,335	28,430	28,525	28,621	28,717	28,813	28,909	29,005	29,099	29,195	29,291
Cumulative Availability, %	95.1%	95.2%	95.2%	95.2%	95.2%	95.2%	95.2%	95.3%	95.3%	95.3%	95.3%	95.3%	95.3%	95.3%	95.3%
Max cumulative gross output, kWhr	24,231,900	24,314,400	24,393,600	24,472,800	24,552,000	24,631,200	24,710,400	24,789,600	24,868,800	24,948,000	25,027,200	25,106,400	25,185,600	25,264,800	25,344,000
Actual cumulative gross output, kWhr	20,437,034	20,517,376	20,594,576	20,671,021	20,746,308	20,821,106	20,898,048	20,974,640	21,050,549	21,127,169	21,204,818	21,282,157	21,356,945	21,435,275	21,511,039
Cumulative Capacity Factor	84.3%	84.4%	84.4%	84.5%	84.5%	84.5%	84.6%	84.6%	84.6%	84.7%	84.7%	84.8%	84.8%	84.8%	84.9%
Cumulative fuel input, MMBtu HHV	255,771	256,792	257,741	258,693	259,620	260,542	261,507	262,479	263,448	264,440	265,439	266,439	267,409	268,408	269,366
Cumulative gross output, kWhr	20,437,034	20,517,376	20,594,576	20,671,021	20,746,308	20,821,106	20,898,048	20,974,640	21,050,549	21,127,169	21,204,818	21,282,157	21,356,945	21,435,275	21,511,039
Cumulative heat rate, Btu/kWe gross LHV	11,266	11,267	11,266	11,266	11,265	11,265	11,265	11,265	11,266	11,267	11,269	11,270	11,271	11,272	11,272
Cumulative heat rate, Btu/kWe gross HHV	12,515	12,516	12,515	12,515	12,514	12,513	12,513	12,514	12,515	12,517	12,518	12,519	12,521	12,522	12,522
Service															
Engine 1															
Engine 2															
Engine 3															
Engine 4															
Oil - oil and filter change															
Service - plugs, air filter, valve inspection and adjustment															
NSTAR Power Reports															
Date	Saturday 11/1/2008	Sunday 11/2/2008	Monday 11/3/2008	Tuesday 11/4/2008	Wednesday 11/5/2008	Thursday 11/6/2008	Friday 11/7/2008	Saturday 11/8/2008	Sunday 11/9/2008	Monday 11/10/2008	Tuesday 11/11/2008	Wednesday 11/12/2008	Thursday 11/13/2008	Friday 11/14/2008	Saturday 11/15/2008
Hour															
1	3,142	3,166	3,152	3,157	3,141	3,125	3,186	3,147	3,145	3,126	3,136	3,137	3,112	3,157	3,157
2	3,139	3,164	3,157	3,158	3,173	3,122	3,185	3,148	3,149	3,127	3,145	3,137	3,120	3,157	3,157
3	3,126	3,163	3,151	3,158	3,154	3,124	3,183	3,145	3,144	3,130	3,147	3,133	3,116	3,157	3,160
4	3,130	3,161	3,158	3,147	3,156	3,126	3,183	3,143	3,131	3,131	3,155	3,130	3,121	3,157	3,159
5	3,129	3,162	3,138	3,139	3,156	3,117	3,179	3,147	3,130	3,124	3,146	3,135	3,119	3,158	3,158
6	3,127	3,159	3,136	3,131	3,146	3,119	3,175	3,148	3,130	3,125	3,146	3,129	3,120	3,157	3,158
7	3,130	3,146	3,122	3,123	3,154	3,125	3,175	3,149	3,127	3,128	3,147	3,133	3,131	3,158	3,155
8	3,123	3,120	3,128	3,145	3,158	3,131	3,173	3,145	3,133	3,129	3,139	3,133	3,132	3,158	3,154
9	3,141	3,114	3,125	3,103	3,143	3,113	2,956	3,144	3,144	3,132	3,138	3,131	3,132	3,159	3,157
10	3,145	3,106	3,132	3,087	3,153	2,710	2,776	3,145	3,143	3,135	3,136	3,126	2,799	3,158	3,159
11	3,135	3,109	3,153	3,110	3,148	2,546	3,170	3,143	3,145	3,149	3,138	3,132	2,389	3,157	3,158
12	3,116	3,112	3,116	3,130	3,141	3,188	3,152	3,143	3,149	3,158	3,140	3,132	2,487	3,155	3,155
13	3,126	3,111	3,128	3,126	3,130	3,161	3,142	3,146	3,147	3,159	3,141	3,134	3,162	3,151	3,157
14	3,117	3,145	3,136	3,134	3,141	3,158	3,144	3,146	3,149	3,152	3,142	3,136	3,160	3,152	3,154
15	3,149	3,135	3,119	3,139	3,127	3,158	3,161	3,147	3,146	3,146	3,136	3,124	3,160	3,151	3,157
16	3,131	3,126	3,139	3,135	3,127	3,158	3,161	3,144	3,146	3,140	3,133	3,122	3,160	3,152	3,158
17	3,144	3,114	3,114	3,132	3,151	3,155	3,158	3,145	3,146	3,137	3,143	3,126	3,159	3,151	3,152
18	3,121	3,121	3,125	3,153	3,125	3,168	3,147	3,147	3,138	3,141	3,138	3,127	3,159	3,152	3,148
19	3,129	3,122	3,119	3,149	3,132	3,184	3,150	3,150	3,138	3,138	3,138	3,116	3,158	3,152	3,149
20	3,135	3,140	3,146	3,144	3,146	3,188	3,157	3,147	3,138	3,134	3,138	3,134	3,158	3,154	3,149
21	3,132	3,125	3,156	3,146	3,123	3,187	3,149	3,148	3,137	3,137	3,133	3,124	3,157	3,157	3,146
22	3,161	3,136	3,156	3,144	3,118	3,187	3,156	3,139	3,136	3,138	3,131	3,114	3,157	3,158	3,148
23	3,141	3,134	3,158	3,147	3,120	3,187	3,154	3,141	3,135	3,132	3,133	3,114	3,157	3,158	3,144
24	3,159	3,148	3,156	3,156	3,124	3,185	3,147	3,148	3,134	3,138	3,138	3,116	3,157	3,157	3,147
		3,150													
TOTAL	75,228	78,389	75,320	75,293	75,387	74,622	75,319	75,495	75,360	75,286	75,357	75,075	73,682	75,733	75,696
Cumulative Output Sold, kWhr	75,228	153,617	228,937	304,230	379,617	454,239	529,558	605,053	680,413	755,699	831,056	906,131	979,813	1,055,546	1,131,242

NOVEMBER 2008																
CNBE Daily Reports Summary Data																
	Sunday 11/16/2008	Monday 11/17/2008	Tuesday 11/18/2008	Wednesday 11/19/2008	Thursday 11/20/2008	Friday 11/21/2008	Saturday 11/22/2008	Sunday 11/23/2008	Monday 11/24/2008	Tuesday 11/25/2008	Wednesday 11/26/2008	Thursday 11/27/2008	Friday 11/28/2008	Saturday 11/29/2008	Sunday 11/30/2008	TOTAL
Landfill Gas Flow to the Engines (KSCF)	1,746	1,771	1,720	1,767	1,750	1,605	1,760	1,744	1,554	1,566	1,692	1,725	1,732	1,727	1,736	51,644
Landfill Gas Flow to the Engines (MMBTU HHV)	997	1,007	975	1,008	1,000	916	1,003	981	889	905	978	984	993	987	996	29,162
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,746	1,771	1,720	1,767	1,750	1,605	1,760	1,744	1,554	1,566	1,692	1,725	1,732	1,727	1,736	51,644
Landfill Gas Total Flow (MMBTU HHV)	997	1,007	975	1,008	1,000	916	1,003	981	889	905	978	984	993	987	996	29,162
Average Methane Content wet (%)	56.4	56.2	56.0	56.4	56.5	56.4	56.3	55.6	56.6	57.1	57.1	57.0	57.3	57.1	57.4	55.8
Engine 1 Hours	24	24	24	24	22	15	24	24	24	24	24	24	24	24	24	710
Engine 2 Hours	24	24	24	24	24	24	24	24	19	24	24	24	24	24	24	714
Engine 3 Hours	24	24	22	23	24	24	24	24	20	24	24	24	24	24	24	714
Engine 4 Hours	24	24	24	24	24	24	24	24	24	19	24	24	24	24	24	714
Generator 1 Power Output (kWhr)	19,712	19,755	19,416	19,732	18,447	11,946	19,325	19,464	19,079	18,523	19,180	19,434	19,481	19,303	19,415	577,985
Generator 2 Power Output (kWhr)	19,166	19,210	19,020	19,239	19,335	19,266	19,057	17,645	13,468	18,247	18,452	18,701	18,757	18,590	18,676	556,294
Generator 3 Power Output (kWhr)	19,714	19,690	18,164	19,075	19,842	19,729	19,606	19,755	15,678	18,792	19,266	19,647	19,707	19,553	19,654	581,754
Generator 4 Power Output (kWhr)	18,953	19,085	18,936	19,259	18,898	18,897	18,891	19,024	18,764	14,194	18,588	18,973	18,987	18,833	18,919	560,563
Gross Power Output (kWhr)	77,546	77,740	75,536	77,304	76,521	69,838	76,879	75,888	66,988	69,755	75,486	76,756	76,932	76,281	76,663	2,276,595
Net Power Output (kWhr)	75,593	75,805	73,721	75,517	74,733	68,295	75,077	74,154	65,567	68,240	73,796	75,035	75,164	74,490	74,857	2,222,616
Power Sold as metered by NStar, (kWhr)	75,635	75,688	73,558	75,524	74,954	69,021	76,124	74,617	67,575	70,751	76,358	76,545	76,559	76,547	76,515	2,247,213
Offgrid RECs (kWhr)	1,953	1,935	1,815	1,787	1,788	1,543	1,802	1,734	1,421	1,515	1,690	1,721	1,768	1,791	1,806	53,979
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	821	823	809	822	838	796	805	811	795	772	799	810	812	804	809	
Generator 2	799	800	793	802	806	803	794	735	709	760	769	779	782	775	778	
Generator 3	821	820	826	829	827	822	817	823	784	783	803	819	821	815	819	
Generator 4	790	795	789	802	787	787	787	793	782	747	775	791	791	785	788	
Power output (kW average over 24-hrs)																
Facility Gross	3,231	3,239	3,147	3,221	3,188	2,910	3,203	3,162	2,791	2,906	3,145	3,198	3,206	3,178	3,194	
Facility Net	3,150	3,159	3,072	3,147	3,114	2,846	3,128	3,090	2,732	2,843	3,075	3,126	3,132	3,104	3,119	
In-plant load	81	81	76	74	75	64	75	72	59	63	70	72	74	75	75	
Daily availability factor																
Facility	100%	100%	98%	99%	98%	91%	100%	100%	91%	95%	100%	100%	100%	100%	100%	
Engine 1	100%	100%	100%	100%	92%	63%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	79%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	92%	96%	100%	100%	100%	100%	83%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	79%	100%	100%	100%	100%	100%	
Daily capacity factor																
Facility	98%	98%	95%	98%	97%	88%	97%	96%	85%	88%	95%	97%	97%	96%	97%	
Engine 1	100%	100%	98%	100%	102%	97%	98%	98%	96%	94%	97%	98%	98%	97%	98%	
Engine 2	97%	97%	96%	97%	98%	97%	96%	89%	86%	92%	93%	94%	95%	94%	94%	
Engine 3	100%	99%	100%	101%	100%	100%	100%	100%	95%	95%	97%	99%	100%	99%	99%	
Engine 4	96%	96%	96%	97%	95%	95%	95%	96%	95%	91%	94%	96%	96%	95%	96%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	385	409	433	457	481	505	529	553	577	601	625	649	673	697	721	
Engine 1	385	409	433	457	479	494	518	542	566	590	614	638	662	686	710	
Engine 2	383	407	431	455	479	503	527	551	570	594	618	642	666	690	714	
Engine 3	385	409	431	454	478	502	526	550	570	594	618	642	666	690	714	
Engine 4	383	407	431	455	479	503	527	551	575	594	618	642	666	690	714	
Engine operating run hours total from 0 hours																
Engine 1	25,730	25,754	25,778	25,802	25,824	25,839	25,863	25,887	25,911	25,935	25,959	25,983	26,007	26,031	26,055	
Engine 2	25,597	25,621	25,645	25,669	25,693	25,717	25,741	25,765	25,784	25,808	25,832	25,856	25,880	25,904	25,928	
Engine 3	25,213	25,237	25,259	25,282	25,306	25,330	25,354	25,378	25,398	25,422	25,446	25,470	25,494	25,518	25,542	
Engine 4	25,464	25,488	25,512	25,536	25,560	25,584	25,608	25,632	25,656	25,675	25,699	25,723	25,747	25,771	25,795	
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	100%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	
Engine 2	99%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	99%	
Engine 3	100%	100%	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 4	99%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	
Engine 1	13,111	13,934	14,743	15,565	16,404	17,200	18,005	18,816	19,611	20,383	21,182	21,992	22,803	23,608	24,417	
Engine 2	12,475	13,276	14,068	14,870	15,675	16,478	17,272	18,007	18,716	19,477	20,245	21,025	21,806	22,581	23,359	
Engine 3	13,033	13,853	14,679	15,508	16,335	17,157	17,974	18,797	19,581	20,364	21,166	21,985	22,806	23,621	24,440	
Engine 4	12,545	13,340	14,129	14,931	15,719	16,506	17,293	18,086	18,868	19,615	20,389	21,180	21,971	22,756	23,544	
Cumulative capacity factor, %																
Engine 1	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 2	95%	95%	95%	95%	95%	95%	95%	95%	95%	94%	94%	94%	94%	94%	94%	
Engine 3	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 4	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	

	Sunday 11/16/2008	Monday 11/17/2008	Tuesday 11/18/2008	Wednesday 11/19/2008	Thursday 11/20/2008	Friday 11/21/2008	Saturday 11/22/2008	Sunday 11/23/2008	Monday 11/24/2008	Tuesday 11/25/2008	Wednesday 11/26/2008	Thursday 11/27/2008	Friday 11/28/2008	Saturday 11/29/2008	Sunday 11/30/2008	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours	1,540	1,636	1,732	1,828	1,924	2,020	2,116	2,212	2,308	2,404	2,500	2,596	2,692	2,788	2,884	
Actual cumulative engine run hours	1,536	1,632	1,726	1,821	1,915	2,002	2,098	2,194	2,281	2,372	2,468	2,564	2,660	2,756	2,852	
Cumulative Availability, %	99.7%	99.8%	99.7%	99.6%	99.5%	99.1%	99.1%	99.2%	98.8%	98.7%	98.7%	98.8%	98.8%	98.9%	98.9%	
Max cumulative gross output, kWhr	1,270,500	1,349,700	1,428,900	1,508,100	1,587,300	1,666,500	1,745,700	1,824,900	1,904,100	1,983,300	2,062,500	2,141,700	2,220,900	2,300,100	2,379,300	
Actual cumulative gross output, kWhr	1,228,028	1,305,768	1,381,304	1,458,608	1,535,129	1,604,967	1,681,846	1,757,734	1,824,722	1,894,477	1,969,963	2,046,719	2,123,651	2,199,932	2,276,595	
Cumulative Capacity Factor	96.7%	96.7%	96.7%	96.7%	96.7%	96.3%	96.3%	96.3%	95.8%	95.5%	95.5%	95.6%	95.6%	95.6%	95.7%	
Cumulative fuel input, MMBtu HHV	15,541	16,548	17,523	18,530	19,530	20,446	21,449	22,430	23,319	24,225	25,203	26,187	27,180	28,167	29,162	
Cumulative gross output, kWhr	1,228,028	1,305,768	1,381,304	1,458,608	1,535,129	1,604,967	1,681,846	1,757,734	1,824,722	1,894,477	1,969,963	2,046,719	2,123,651	2,199,932	2,276,595	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,572	11,657	11,621	11,734	11,761	11,808	11,741	11,638	11,953	11,682	11,664	11,541	11,618	11,647	11,693	
Daily heat rate, Btu/kWe gross HHV	12,855	12,949	12,910	13,035	13,065	13,117	13,043	12,928	13,278	12,977	12,957	12,820	12,906	12,939	12,990	
Cumulative heat rate, Btu/kWe gross LHV	11,392	11,408	11,420	11,436	11,452	11,468	11,480	11,487	11,504	11,511	11,517	11,518	11,521	11,526	11,531	
Cumulative heat rate, Btu/kWe gross HHV	12,655	12,673	12,686	12,704	12,722	12,739	12,753	12,761	12,780	12,787	12,794	12,795	12,799	12,803	12,810	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	30,816	30,912	31,008	31,104	31,200	31,296	31,392	31,488	31,584	31,680	31,776	31,872	31,968	32,064	32,160	
Actual cumulative engine run hours	29,387	29,483	29,577	29,672	29,766	29,853	29,949	30,045	30,132	30,223	30,319	30,415	30,511	30,607	30,703	
Cumulative Availability, %	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.4%	95.5%	95.5%	
Max cumulative gross output, kWhr	25,423,200	25,502,400	25,581,600	25,660,800	25,740,000	25,819,200	25,898,400	25,977,600	26,056,800	26,136,000	26,215,200	26,294,400	26,373,600	26,452,800	26,532,000	
Actual cumulative gross output, kWhr	21,588,585	21,666,325	21,741,861	21,819,165	21,895,686	21,965,524	22,042,403	22,118,291	22,185,279	22,255,034	22,330,520	22,407,276	22,484,208	22,560,489	22,637,152	
Cumulative Capacity Factor	84.9%	85.0%	85.0%	85.0%	85.1%	85.1%	85.1%	85.1%	85.1%	85.2%	85.2%	85.2%	85.3%	85.3%	85.3%	
Cumulative fuel input, MMBtu HHV	270,363	271,369	272,345	273,352	274,352	275,268	276,271	277,252	278,141	279,046	280,025	281,009	282,001	282,988	283,984	
Cumulative gross output, kWhr	21,588,585	21,666,325	21,741,861	21,819,165	21,895,686	21,965,524	22,042,403	22,118,291	22,185,279	22,255,034	22,330,520	22,407,276	22,484,208	22,560,489	22,637,152	
Cumulative heat rate, Btu/kWe gross LHV	11,274	11,275	11,276	11,278	11,279	11,281	11,283	11,284	11,286	11,287	11,288	11,289	11,290	11,292	11,293	
Cumulative heat rate, Btu/kWe gross HHV	12,523	12,525	12,526	12,528	12,530	12,532	12,534	12,535	12,537	12,539	12,540	12,541	12,542	12,544	12,545	
Service																
Engine 1																
Engine 2																
Engine 3																
Engine 4																
Oil - oil and filter change																
Service - plugs, air filter, valve inspection and adjust																
NSTAR Power Reports																
Date	Sunday 11/16/2008	Monday 11/17/2008	Tuesday 11/18/2008	Wednesday 11/19/2008	Thursday 11/20/2008	Friday 11/21/2008	Saturday 11/22/2008	Sunday 11/23/2008	Monday 11/24/2008	Tuesday 11/25/2008	Wednesday 11/26/2008	Thursday 11/27/2008	Friday 11/28/2008	Saturday 11/29/2008	Sunday 11/30/2008	TOTAL
Hour																
1	3,156	3,151	3,155	3,164	3,174	3,182	3,170	3,172	2,968	3,153	3,170	3,186	3,192	3,187	3,185	
2	3,159	3,151	3,156	3,167	3,178	3,176	3,170	3,170	2,967	3,153	3,170	3,191	3,188	3,191	3,190	
3	3,160	3,148	3,158	3,163	3,175	3,176	3,174	3,171	2,972	3,154	3,170	3,189	3,189	3,186	3,184	
4	3,159	3,147	3,158	3,168	3,171	3,179	3,171	3,174	2,966	3,154	3,165	3,188	3,190	3,191	3,185	
5	3,157	3,148	3,155	3,163	3,175	3,172	3,170	3,170	2,966	3,154	3,169	3,191	3,186	3,187	3,190	
6	3,157	3,146	3,155	3,162	3,170	3,176	3,172	3,170	2,971	3,153	3,164	3,186	3,191	3,190	3,184	
7	3,157	3,149	3,158	3,168	3,170	3,176	3,173	3,175	2,967	3,154	3,168	3,190	3,188	3,189	3,188	
8	3,155	3,147	3,154	3,162	3,175	3,171	3,170	3,171	2,967	3,098	3,164	3,190	3,192	3,187	3,186	
9	3,154	3,152	3,159	3,168	2,546	2,486	3,172	3,171	2,496	2,382	3,180	3,187	3,191	3,191	3,189	
10	3,150	3,150	3,158	3,168	2,417	2,416	3,173	3,174	2,408	2,380	3,188	3,190	3,191	3,191	3,187	
11	3,148	3,151	3,161	2,574	3,187	2,414	3,175	3,174	2,405	2,380	3,189	3,190	3,190	3,191	3,191	
12	3,143	3,150	2,909	3,147	3,217	2,409	3,175	3,174	2,399	2,380	3,189	3,189	3,190	3,190	3,187	
13	3,146	3,151	1,643	3,182	3,205	2,411	3,171	3,174	2,377	2,266	3,190	3,189	3,191	3,190	3,191	
14	3,147	3,159	2,568	3,181	3,195	2,411	3,174	3,174	2,388	2,094	3,191	3,189	3,190	3,191	3,187	
15	3,151	3,159	3,206	3,181	3,191	2,411	3,174	3,171	2,387	3,170	3,190	3,190	3,191	3,190	3,191	
16	3,145	3,160	3,176	3,178	3,189	2,412	3,171	3,175	2,393	3,169	3,190	3,190	3,191	3,191	3,190	
17	3,147	3,160	3,168	3,179	3,184	2,408	3,171	3,084	2,498	3,169	3,190	3,191	3,191	3,191	3,186	
18	3,149	3,159	3,165	3,180	3,179	2,798	3,174	2,967	3,158	3,170	3,189	3,191	3,192	3,191	3,191	
19	3,148	3,160	3,168	3,177	3,175	3,174	3,170	2,969	3,153	3,169	3,188	3,192	3,188	3,191	3,186	
20	3,149	3,156	3,164	3,180	3,179	3,171	3,169	2,966	3,156	3,169	3,190	3,188	3,191	3,187	3,190	
21	3,149	3,160	3,168	3,178	3,176	3,176	3,174	2,967	3,155	3,170	3,187	3,192	3,187	3,191	3,190	
22	3,150	3,157	3,164	3,177	3,178	3,171	3,170	2,970	3,151	3,170	3,190	3,188	3,191	3,187	3,189	
23	3,149	3,158	3,167	3,180	3,176	3,170	3,169	2,966	3,154	3,170	3,187	3,191	3,187	3,187	3,189	
24	3,150	3,159	3,165	3,177	3,172	3,175	3,172	2,968	3,153	3,170	3,190	3,187	3,191	3,189	3,189	
TOTAL	75,635	75,688	73,558	75,524	74,954	69,021	76,124	74,617	67,575	70,751	76,358	76,545	76,559	76,547	76,515	2,247,213
Cumulative Output Sold, kWhr	1,206,877	1,282,565	1,356,123	1,431,647	1,506,601	1,575,622	1,651,746	1,726,363	1,793,938	1,864,689	1,941,047	2,017,592	2,094,151	2,170,698	2,247,213	

DECEMBER 2008

DECEMBER 2008																	
CNBE Daily Reports Summary Data																	
	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	
	12/1/2008	12/2/2008	12/3/2008	12/4/2008	12/5/2008	12/6/2008	12/7/2008	12/8/2008	12/9/2008	12/10/2008	12/11/2008	12/12/2008	12/13/2008	12/14/2008	12/15/2008	12/16/2008	
Landfill Gas Flow to the Engines (KSCF)	1,723	1,686	1,692	1,655	1,680	1,676	1,697	1,664	1,686	1,598	1,605	1,464	1,727	1,751	1,691	1,720	
Landfill Gas Flow to the Engines (MMBTU HHV)	994	956	962	946	959	956	973	933	945	905	926	844	980	969	933	951	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,723	1,686	1,692	1,655	1,680	1,676	1,697	1,664	1,686	1,598	1,605	1,464	1,727	1,751	1,691	1,720	
Landfill Gas Total Flow (MMBTU HHV)	994	956	962	946	959	956	973	933	945	905	926	844	980	969	933	951	
Average Methane Content wet (%)	57.0	56.1	56.2	56.5	56.4	56.4	56.7	55.4	55.4	56.0	57.0	57.0	56.1	54.7	54.5	54.7	
Engine 1 Hours	24	24	24	24	24	24	24	24	24	24	24	22	24	24	24	24	
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	22	24	24	24	24	
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	24	22	24	24	24	24	
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	22	24	24	24	24	
Generator 1 Power Output (kWhr)	19,602	19,500	19,482	19,271	19,270	19,281	19,471	19,214	19,353	17,803	16,604	15,944	19,193	19,299	19,200	19,076	
Generator 2 Power Output (kWhr)	18,873	16,348	16,218	16,049	16,652	16,048	16,208	16,382	16,690	16,978	18,275	16,156	18,474	18,576	18,474	18,365	
Generator 3 Power Output (kWhr)	19,866	19,757	19,706	19,551	19,507	19,567	19,761	19,307	19,332	18,885	19,157	16,854	19,120	19,247	19,161	19,028	
Generator 4 Power Output (kWhr)	18,863	19,018	18,994	18,811	18,802	18,843	19,028	18,613	18,584	18,015	18,256	16,120	18,418	18,537	18,373	18,284	
Gross Power Output (kWhr)	77,204	74,622	74,399	73,683	74,232	73,739	74,468	73,516	73,960	71,681	72,292	65,073	75,204	75,659	75,208	74,753	
Net Power Output (kWhr)	75,419	72,896	72,691	72,000	72,509	72,041	72,719	71,715	72,170	70,029	70,848	63,847	73,863	74,306	73,881	73,445	
Power Sold as metered by NStar, (kWhr)	76,273	74,096	74,005	74,022	74,617	74,020	73,991	73,975	74,057	71,957	73,179	65,848	75,482	75,483	75,484	75,503	
Offgrid RECs (kWhr)	1,785	1,726	1,708	1,683	1,723	1,698	1,749	1,801	1,790	1,652	1,444	1,226	1,341	1,353	1,327	1,308	
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	817	813	812	803	803	803	811	801	806	742	692	725	800	804	800	795	
Generator 2	786	681	676	669	694	669	675	683	695	707	761	734	770	774	770	765	
Generator 3	828	823	821	815	813	815	823	804	806	787	798	766	797	802	798	793	
Generator 4	786	792	791	784	783	785	793	776	774	751	761	733	767	772	766	762	
Power output (kW average over 24-hrs)																	
Facility Gross	3,217	3,109	3,100	3,070	3,093	3,072	3,103	3,063	3,082	2,987	3,012	2,711	3,134	3,152	3,134	3,115	
Facility Net	3,142	3,037	3,029	3,000	3,021	3,002	3,030	2,988	3,007	2,918	2,952	2,660	3,078	3,096	3,078	3,060	
In-plant load	74	72	71	70	72	71	73	75	75	69	60	51	56	56	55	55	
Daily availability factor																	
Facility	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%	100%	
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	94%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%	100%	
Daily capacity factor																	
Facility	97%	94%	94%	93%	94%	93%	94%	93%	93%	91%	91%	82%	95%	96%	95%	94%	
Engine 1	99%	98%	98%	97%	97%	97%	98%	97%	98%	90%	84%	88%	97%	97%	97%	96%	
Engine 2	95%	83%	82%	81%	84%	81%	82%	83%	84%	86%	92%	89%	93%	94%	93%	93%	
Engine 3	100%	100%	100%	99%	99%	99%	100%	98%	98%	95%	97%	93%	97%	97%	97%	96%	
Engine 4	95%	96%	96%	95%	95%	95%	96%	94%	94%	91%	92%	89%	93%	94%	93%	92%	
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	384	
Engine 1	24	48	72	96	120	144	168	192	216	240	264	286	310	334	358	382	
Engine 2	24	48	72	96	120	144	168	192	216	240	264	286	310	334	358	382	
Engine 3	24	48	72	96	120	144	168	192	216	240	264	286	310	334	358	382	
Engine 4	24	48	72	96	120	144	168	192	216	240	264	286	310	334	358	382	
Engine operating run hours total from 0 hours																	
Engine 1	26,079	26,103	26,127	26,151	26,175	26,199	26,223	26,247	26,271	26,295	26,319	26,341	26,365	26,389	26,413	26,437	
Engine 2	25,952	25,976	26,000	26,024	26,048	26,072	26,096	26,120	26,144	26,168	26,192	26,214	26,238	26,262	26,286	26,310	
Engine 3	25,566	25,590	25,614	25,638	25,662	25,686	25,710	25,734	25,758	25,782	25,806	25,828	25,852	25,876	25,900	25,924	
Engine 4	25,819	25,843	25,867	25,891	25,915	25,939	25,963	25,987	26,011	26,035	26,059	26,081	26,105	26,129	26,153	26,177	
Cumulative availability, %																	
Engine 1	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	99%	99%	99%	99%	99%	
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	13,200	
Engine 1	817	1,629	2,441	3,244	4,047	4,850	5,662	6,462	7,269	8,010	8,702	9,427	10,227	11,031	11,831	12,626	
Engine 2	786	1,468	2,143	2,812	3,506	4,175	4,850	5,532	6,228	6,935	7,697	8,431	9,201	9,975	10,745	11,510	
Engine 3	828	1,651	2,472	3,287	4,099	4,915	5,738	6,543	7,348	8,135	8,933	9,699	10,496	11,298	12,096	12,889	
Engine 4	786	1,578	2,370	3,154	3,937	4,722	5,515	6,291	7,065	7,815	8,576	9,309	10,076	10,849	11,614	12,376	
Cumulative capacity factor, %																	
Engine 1	99%	99%	99%	98%	98%	98%	98%	98%	98%	97%	96%	95%	95%	96%	96%	96%	
Engine 2	95%	89%	87%	85%	85%	84%	84%	84%	84%	84%	86%	85%	86%	86%	87%	87%	
Engine 3	100%	100%	100%	100%	99%	99%	99%	99%	99%	99%	98%	98%	98%	98%	98%	98%	
Engine 4	95%	96%	96%	96%	95%	95%	95%	95%	95%	95%	95%	94%	94%	94%	94%	94%	

DECEMBER 2008

		Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday
		12/1/2008	12/2/2008	12/3/2008	12/4/2008	12/5/2008	12/6/2008	12/7/2008	12/8/2008	12/9/2008	12/10/2008	12/11/2008	12/12/2008	12/13/2008	12/14/2008	12/15/2008	12/16/2008
Cumulative by Facility in month																	
	Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440	1,536
	Actual cumulative engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,144	1,240	1,336	1,432	1,528
	Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	99.3%	99.4%	99.4%	99.4%	99.5%
	Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000	1,267,200
	Actual cumulative gross output, kWhr	77,204	151,826	226,225	299,908	374,140	447,879	522,347	595,863	669,823	741,504	813,796	878,869	954,073	1,029,732	1,104,940	1,179,693
	Cumulative Capacity Factor	97.5%	95.8%	95.2%	94.7%	94.5%	94.3%	94.2%	94.0%	94.0%	93.6%	93.4%	92.5%	92.7%	92.9%	93.0%	93.1%
	Cumulative fuel input, MMBtu HHV	994	1,950	2,913	3,858	4,818	5,774	6,747	7,680	8,624	9,529	10,455	11,299	12,279	13,249	14,181	15,133
	Cumulative gross output, kWhr	77,204	151,826	226,225	299,908	374,140	447,879	522,347	595,863	669,823	741,504	813,796	878,869	954,073	1,029,732	1,104,940	1,179,693
Heat Rate																	
	Daily heat rate, Btu/kWe gross LHV	11,589	11,538	11,644	11,552	11,634	11,676	11,764	11,421	11,497	11,366	11,528	11,674	11,732	11,532	11,164	11,458
	Daily heat rate, Btu/kWe gross HHV	12,874	12,817	12,935	12,833	12,924	12,970	13,068	12,687	12,771	12,626	12,806	12,968	13,032	12,811	12,402	12,728
	Cumulative heat rate, Btu/kWe gross LHV	11,589	11,564	11,590	11,581	11,591	11,605	11,628	11,602	11,591	11,569	11,565	11,573	11,586	11,582	11,553	11,547
	Cumulative heat rate, Btu/kWe gross HHV	12,874	12,846	12,875	12,865	12,876	12,892	12,917	12,889	12,876	12,852	12,848	12,856	12,870	12,866	12,834	12,828
Cumulative by Facility starting Calendar Year																	
	Max cumulative available engine run hours	32,256	32,352	32,448	32,544	32,640	32,736	32,832	32,928	33,024	33,120	33,216	33,312	33,408	33,504	33,600	33,696
	Actual cumulative engine run hours	30,799	30,895	30,991	31,087	31,183	31,279	31,375	31,471	31,567	31,663	31,759	31,847	31,943	32,039	32,135	32,231
	Cumulative Availability, %	95.5%	95.5%	95.5%	95.5%	95.5%	95.5%	95.6%	95.6%	95.6%	95.6%	95.6%	95.6%	95.6%	95.6%	95.6%	95.7%
	Max cumulative gross output, kWhr	26,611,200	26,690,400	26,769,600	26,848,800	26,928,000	27,007,200	27,086,400	27,165,600	27,244,800	27,324,000	27,403,200	27,482,400	27,561,600	27,640,800	27,720,000	27,799,200
	Actual cumulative gross output, kWhr	22,714,356	22,788,978	22,863,377	22,937,060	23,011,292	23,085,031	23,159,499	23,233,015	23,306,975	23,378,656	23,450,948	23,516,021	23,591,225	23,666,884	23,742,092	23,816,845
	Cumulative Capacity Factor	85.4%	85.4%	85.4%	85.4%	85.5%	85.5%	85.5%	85.5%	85.5%	85.6%	85.6%	85.6%	85.6%	85.6%	85.6%	85.7%
	Cumulative fuel input, MMBtu HHV	284,978	285,935	286,897	287,842	288,802	289,758	290,731	291,664	292,609	293,514	294,440	295,283	296,264	297,233	298,165	299,117
	Cumulative gross output, kWhr	22,714,356	22,788,978	22,863,377	22,937,060	23,011,292	23,085,031	23,159,499	23,233,015	23,306,975	23,378,656	23,450,948	23,516,021	23,591,225	23,666,884	23,742,092	23,816,845
	Cumulative heat rate, Btu/kWe gross LHV	11,294	11,295	11,296	11,297	11,298	11,299	11,301	11,301	11,302	11,302	11,302	11,304	11,305	11,306	11,305	11,306
	Cumulative heat rate, Btu/kWe gross HHV	12,546	12,547	12,548	12,549	12,550	12,552	12,553	12,554	12,555	12,555	12,556	12,557	12,558	12,559	12,559	12,559
Service																	
	Engine 1																
	Engine 2																
	Engine 3																
	Engine 4																
Oil - oil and filter change												tree damage to line					
Service - plugs, air filter, valve inspection and adjustment																	

DECEMBER 2008

DECEMBER 2008																	
CNBE Daily Reports Summary Data																	
	Wednesday 12/17/2008	Thursday 12/18/2008	Friday 12/19/2008	Saturday 12/20/2008	Sunday 12/21/2008	Monday 12/22/2008	Tuesday 12/23/2008	Wednesday 12/24/2008	Thursday 12/25/2008	Friday 12/26/2008	Saturday 12/27/2008	Sunday 12/28/2008	Monday 12/29/2008	Tuesday 12/30/2008	Wednesday 12/31/2008	TOTAL	
Landfill Gas Flow to the Engines (KSCF)	1,711	1,712	1,741	1,735	1,690	1,324	1,619	1,612	1,616	1,632	1,609	1,609	1,627	1,645	1,645	51,242	
Landfill Gas Flow to the Engines (MMBTU HHV)	962	959	973	967	948	737	916	922	921	914	910	919	930	938	938	28,984	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,711	1,712	1,741	1,735	1,690	1,324	1,619	1,612	1,616	1,632	1,609	1,609	1,627	1,645	1,645	51,242	
Landfill Gas Total Flow (MMBTU HHV)	962	959	973	967	948	737	916	922	921	914	910	919	930	938	938	28,984	
Average Methane Content wet (%)	55.6	55.4	55.2	55.1	55.4	55.0	55.9	56.5	56.3	55.3	56.5	57.1	57.1	57.0	57.0	55.9	
Engine 1 Hours	24	24	24	24	24	23	24	24	24	24	24	24	24	24	24	741	
Engine 2 Hours	24	23	24	24	24	22	24	24	24	24	24	24	24	24	24	739	
Engine 3 Hours	24	24	24	24	24	23	24	24	24	24	24	24	24	24	24	741	
Engine 4 Hours	24	23	24	24	24	22	24	24	24	24	24	24	24	24	24	739	
Generator 1 Power Output (kWhr)	19,022	19,263	19,086	19,264	18,099	15,141	19,507	19,456	19,468	19,333	19,257	19,220	19,332	19,484	19,484	585,979	
Generator 2 Power Output (kWhr)	18,307	17,908	18,377	18,549	17,199	11,956	18,776	18,735	18,748	18,615	18,540	18,502	18,613	18,753	18,753	545,097	
Generator 3 Power Output (kWhr)	18,965	19,200	19,014	19,191	18,399	16,224	17,024	16,981	16,973	16,867	16,791	16,762	16,866	17,000	17,000	571,062	
Generator 4 Power Output (kWhr)	18,243	17,699	18,271	18,442	17,599	12,247	18,686	18,681	18,686	18,572	18,479	18,471	18,528	18,730	18,730	565,623	
Gross Power Output (kWhr)	74,536	74,070	74,748	75,446	71,296	55,568	73,993	73,853	73,875	73,387	73,068	72,954	73,339	73,968	73,968	2,267,762	
Net Power Output (kWhr)	73,192	72,722	73,302	74,000	69,850	54,626	72,860	72,708	72,682	72,197	71,900	71,753	72,153	72,742	72,742	2,223,808	
Power Sold as metered by NStar, (kWhr)	75,461	74,037	75,386	73,456	69,483	55,083	73,347	73,308	73,274	73,280	73,262	73,200	73,256	73,230	73,209	2,264,264	
Offgrid RECs (kWhr)	1,344	1,348	1,446	1,446	1,446	942	1,133	1,145	1,193	1,190	1,168	1,201	1,186	1,226	1,226	43,954	
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	793	803	795	803	754	658	813	811	811	806	802	801	806	812	812		
Generator 2	763	779	766	773	717	543	782	781	781	776	773	771	776	781	781		
Generator 3	790	800	792	800	767	705	709	708	707	703	700	698	703	708	708		
Generator 4	760	770	761	768	733	557	779	778	779	774	770	770	772	780	780		
Power output (kW average over 24-hrs)																	
Facility Gross	3,106	3,086	3,115	3,144	2,971	2,315	3,083	3,077	3,078	3,058	3,045	3,040	3,056	3,082	3,082		
Facility Net	3,050	3,030	3,054	3,083	2,910	2,276	3,036	3,030	3,028	3,008	2,996	2,990	3,006	3,031	3,031		
In-plant load	56	56	60	60	60	39	47	48	50	50	49	50	49	51	51		
Daily availability factor																	
Facility	100%	98%	100%	100%	100%	94%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 1	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	96%	100%	100%	100%	92%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 3	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Engine 4	100%	96%	100%	100%	100%	92%	100%	100%	100%	100%	100%	100%	100%	100%	100%		
Daily capacity factor																	
Facility	94%	94%	94%	95%	90%	70%	93%	93%	93%	93%	92%	92%	93%	93%	93%		
Engine 1	96%	97%	96%	97%	91%	80%	99%	98%	98%	97%	98%	98%	98%	98%	98%		
Engine 2	92%	94%	93%	94%	87%	66%	95%	95%	95%	94%	94%	93%	94%	95%	95%		
Engine 3	96%	97%	96%	97%	93%	86%	86%	86%	86%	85%	85%	85%	85%	86%	86%		
Engine 4	92%	93%	92%	93%	89%	67%	94%	94%	94%	94%	93%	93%	94%	95%	95%		
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744		
Engine 1	406	430	454	478	502	525	549	573	597	621	645	669	693	717	741		
Engine 2	406	429	453	477	501	523	547	571	595	619	643	667	691	715	739		
Engine 3	406	430	454	478	502	525	549	573	597	621	645	669	693	717	741		
Engine 4	406	429	453	477	501	523	547	571	595	619	643	667	691	715	739		
Engine operating run hours total from 0 hours																	
Engine 1	26,461	26,485	26,509	26,533	26,557	26,580	26,604	26,628	26,652	26,676	26,700	26,724	26,748	26,772	26,796		
Engine 2	26,334	26,357	26,381	26,405	26,429	26,451	26,475	26,499	26,523	26,547	26,571	26,595	26,619	26,643	26,667		
Engine 3	25,948	25,972	25,996	26,020	26,044	26,067	26,091	26,115	26,139	26,163	26,187	26,211	26,235	26,259	26,283		
Engine 4	26,201	26,224	26,248	26,272	26,296	26,318	26,342	26,366	26,390	26,414	26,438	26,462	26,486	26,510	26,534		
Cumulative availability, %																	
Engine 1	100%	100%	100%	100%	100%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%		
Engine 2	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%		
Engine 3	100%	100%	100%	100%	100%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%		
Engine 4	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%		
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575		
Engine 1	13,418	14,221	15,016	15,819	16,573	17,231	18,044	18,855	19,666	20,471	21,274	22,074	22,880	23,692	24,504		
Engine 2	12,273	13,051	13,817	14,590	15,306	15,850	16,632	17,413	18,194	18,970	19,742	20,513	21,289	22,070	22,851		
Engine 3	13,679	14,479	15,271	16,071	16,838	17,543	18,252	18,960	19,667	20,370	21,070	21,768	22,471	23,179	23,887		
Engine 4	13,136	13,906	14,667	15,435	16,169	16,725	17,504	18,282	19,061	19,835	20,605	21,374	22,146	22,927	23,707		
Cumulative capacity factor, %																	
Engine 1	96%	96%	96%	96%	96%	95%	95%	95%	95%	95%	96%	96%	96%	96%	96%		
Engine 2	88%	88%	88%	88%	88%	87%	88%	88%	88%	88%	89%	89%	89%	89%	89%		
Engine 3	98%	98%	97%	97%	97%	97%	96%	96%	95%	95%	95%	94%	94%	94%	93%		
Engine 4	94%	94%	94%	94%	93%	92%	92%	92%	92%	92%	93%	93%	93%	93%	93%		

DECEMBER 2008

	Wednesday 12/17/2008	Thursday 12/18/2008	Friday 12/19/2008	Saturday 12/20/2008	Sunday 12/21/2008	Monday 12/22/2008	Tuesday 12/23/2008	Wednesday 12/24/2008	Thursday 12/25/2008	Friday 12/26/2008	Saturday 12/27/2008	Sunday 12/28/2008	Monday 12/29/2008	Tuesday 12/30/2008	Wednesday 12/31/2008	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976	
Actual cumulative engine run hours	1,624	1,718	1,814	1,910	2,006	2,096	2,192	2,288	2,384	2,480	2,576	2,672	2,768	2,864	2,960	
Cumulative Availability, %	99.5%	99.4%	99.5%	99.5%	99.5%	99.2%	99.3%	99.3%	99.3%	99.4%	99.4%	99.4%	99.4%	99.4%	99.5%	
Max cumulative gross output, kWhr	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200	
Actual cumulative gross output, kWhr	1,254,229	1,328,299	1,403,047	1,478,493	1,549,789	1,605,357	1,679,350	1,753,203	1,827,078	1,900,465	1,973,533	2,046,487	2,119,826	2,193,794	2,267,762	
Cumulative Capacity Factor	93.2%	93.2%	93.2%	93.3%	93.2%	92.1%	92.2%	92.2%	92.3%	92.3%	92.3%	92.3%	92.3%	92.3%	92.4%	
Cumulative fuel input, MMBtu HHV	16,095	17,054	18,028	18,995	19,942	20,679	21,595	22,517	23,437	24,351	25,261	26,180	27,109	28,047	28,984	
Cumulative gross output, kWhr	1,254,229	1,328,299	1,403,047	1,478,493	1,549,789	1,605,357	1,679,350	1,753,203	1,827,078	1,900,465	1,973,533	2,046,487	2,119,826	2,193,794	2,267,762	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,622	11,659	11,720	11,541	11,964	11,936	11,142	11,235	11,220	11,209	11,209	11,336	11,410	11,410	11,410	
Daily heat rate, Btu/kWe gross HHV	12,911	12,952	13,020	12,821	13,290	13,260	12,377	12,481	12,464	12,451	12,452	12,593	12,676	12,675	12,675	
Cumulative heat rate, Btu/kWe gross LHV	11,552	11,558	11,567	11,565	11,584	11,596	11,576	11,561	11,548	11,535	11,522	11,516	11,512	11,509	11,505	
Cumulative heat rate, Btu/kWe gross HHV	12,833	12,839	12,849	12,847	12,868	12,881	12,859	12,843	12,828	12,813	12,800	12,793	12,788	12,785	12,781	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	33,792	33,888	33,984	34,080	34,176	34,272	34,368	34,464	34,560	34,656	34,752	34,848	34,944	35,040	35,136	
Actual cumulative engine run hours	32,327	32,421	32,517	32,613	32,709	32,799	32,895	32,991	33,087	33,183	33,279	33,375	33,471	33,567	33,663	
Cumulative Availability, %	95.7%	95.7%	95.7%	95.7%	95.7%	95.7%	95.7%	95.7%	95.7%	95.7%	95.8%	95.8%	95.8%	95.8%	95.8%	
Max cumulative gross output, kWhr	27,878,400	27,957,600	28,036,800	28,116,000	28,195,200	28,274,400	28,353,600	28,432,800	28,512,000	28,591,200	28,670,400	28,749,600	28,828,800	28,908,000	28,987,200	
Actual cumulative gross output, kWhr	23,891,381	23,965,451	24,040,199	24,115,645	24,186,941	24,242,509	24,316,502	24,390,355	24,464,230	24,537,617	24,610,685	24,683,639	24,756,978	24,830,946	24,904,914	
Cumulative Capacity Factor	85.7%	85.7%	85.7%	85.8%	85.8%	85.7%	85.8%	85.8%	85.8%	85.8%	85.9%	85.9%	85.9%	85.9%	85.9%	
Cumulative fuel input, MMBtu HHV	300,079	301,039	302,012	302,979	303,927	304,663	305,579	306,501	307,422	308,335	309,245	310,164	311,094	312,031	312,969	
Cumulative gross output, kWhr	23,891,381	23,965,451	24,040,199	24,115,645	24,186,941	24,242,509	24,316,502	24,390,355	24,464,230	24,537,617	24,610,685	24,683,639	24,756,978	24,830,946	24,904,914	
Cumulative heat rate, Btu/kWe gross LHV	11,307	11,308	11,309	11,310	11,312	11,313	11,313	11,312	11,312	11,312	11,311	11,311	11,312	11,312	11,312	
Cumulative heat rate, Btu/kWe gross HHV	12,560	12,561	12,563	12,564	12,566	12,567	12,567	12,566	12,566	12,566	12,565	12,566	12,566	12,566	12,567	
Service																
Engine 1																
Engine 2		Oil change?														
Engine 3																
Engine 4					NStar Trip	Wellhead leak										
Oil - oil and filter change						Wellhead positive pressure										
Service - plugs, air filter, valve inspection and adjust																
NSTAR Power Reports																
Date	12/17/2008	12/18/2008	12/19/2008	12/20/2008	12/21/2008	12/22/2008	12/23/2008	12/24/2008	12/25/2008	12/26/2008	12/27/2008	12/28/2008	12/29/2008	12/30/2008	12/31/2008	TOTAL
Hour																
1	3,146	3,146	3,140	3,135	3,043	3,051	3,057	3,056	3,054	3,050	3,051	3,050	3,048	3,052	3,048	
2	3,142	3,142	3,144	3,141	3,049	3,047	3,058	3,054	3,051	3,050	3,053	3,051	3,051	3,055	3,051	
3	3,143	3,141	3,143	3,140	3,046	3,043	3,053	3,059	3,053	3,055	3,054	3,048	3,049	3,051	3,052	
4	3,148	3,146	3,140	3,138	3,045	3,048	3,057	3,054	3,053	3,053	3,051	3,051	3,054	3,054	3,049	
5	3,145	3,142	3,142	3,068	3,050	1,406	3,056	3,054	3,050	3,051	3,057	3,051	3,052	3,053	3,052	
6	3,143	3,140	3,144	3,040	3,046	1,450	3,052	3,059	3,055	3,051	3,052	3,048	3,050	3,050	3,052	
7	3,149	3,145	3,140	3,041	3,045	1,456	3,059	3,053	3,051	3,054	3,057	3,050	3,054	3,056	3,049	
8	3,143	3,142	3,141	3,041	3,051	1,468	3,054	3,055	3,057	3,052	3,052	3,052	3,052	3,050	3,052	
9	3,144	3,140	3,144	3,042	3,048	1,411	3,054	3,058	3,052	3,051	3,055	3,051	3,051	3,050	3,052	
10	3,143	3,145	3,142	3,041	3,046	728	3,060	3,053	3,056	3,058	3,053	3,048	3,055	3,053	3,050	
11	3,148	2,393	3,143	3,041	3,048	1,185	3,055	3,056	3,051	3,052	3,056	3,051	3,054	3,053	3,053	
12	3,143	2,478	3,146	3,042	3,047	689	3,056	3,055	3,055	3,056	3,051	3,051	3,051	3,051	3,050	
13	3,148	3,147	3,141	3,047	3,045	1,646	3,059	3,053	3,054	3,053	3,055	3,052	3,054	3,050	3,048	
14	3,142	3,150	3,147	3,046	3,044	2,591	3,054	3,057	3,050	3,056	3,050	3,051	3,051	3,052	3,053	
15	3,147	3,150	3,138	3,043	476	3,059	3,058	3,054	3,054	3,053	3,054	3,051	3,056	3,051	3,049	
16	3,142	3,144	3,138	3,048	1,960	3,053	3,056	3,051	3,051	3,056	3,053	3,050	3,050	3,049	3,048	
17	3,147	3,149	3,143	3,041	3,056	3,059	3,053	3,057	3,055	3,051	3,052	3,050	3,055	3,048	3,051	
18	3,142	3,142	3,140	3,047	3,049	3,057	3,059	3,051	3,052	3,054	3,053	3,051	3,051	3,053	3,050	
19	3,147	3,141	3,136	3,045	3,051	3,055	3,056	3,056	3,051	3,056	3,048	3,047	3,053	3,048	3,047	
20	3,141	3,146	3,140	3,044	3,050	3,059	3,053	3,049	3,055	3,051	3,052	3,050	3,055	3,049	3,052	
21	3,141	3,142	3,139	3,049	3,045	3,055	3,060	3,055	3,054	3,055	3,052	3,051	3,051	3,052	3,049	
22	3,146	3,141	3,135	3,042	3,049	3,055	3,056	3,052	3,051	3,054	3,049	3,047	3,054	3,048	3,047	
23	3,140	3,145	3,140	3,048	3,049	3,059	3,054	3,053	3,053	3,051	3,052	3,051	3,054	3,050	3,054	
24	3,141	3,140	3,140	3,046	3,045	3,053	3,058	3,054	3,056	3,057	3,050	3,047	3,051	3,052	3,051	
TOTAL	75,461	74,037	75,386	73,456	69,483	55,083	73,347	73,308	73,274	73,280	73,262	73,200	73,256	73,230	73,209	2,264,264
Cumulative Output Sold, kWhr	1,257,453	1,331,490	1,406,876	1,480,332	1,549,815	1,604,898	1,678,245	1,751,553	1,824,827	1,898,107	1,971,369	2,044,569	2,117,825	2,191,055	2,264,264	

EXHIBIT 6

Calibration records of the LFG flow rate and compilation of methane content calibration reports for the California analytical analyzer for the periods

FIRST HALF 2009

Calibration records of the LFG flow rate and compilation of methane content calibration reports for the California analytical analyzer for the periods

Landfill Gas Flow Calculation							
Crapo Hill Landfill, New Bedford/Dartmouth, Massachusetts							
Note: Calculation of volumetric flow of LFG through a pipe using a pitot tube and manometer.							
		Engine 1, kW	835	750	795	825	750
		Engine 2, kW	820	800	800	825	740
		Engine 3, kW	820	700	790	825	740
		Engine 4, kW	-	800	815	-	740
		Gross, kW	2,475	3,050	3,200	2,475	2,970
MEASURING INSTRUMENT:		Pitot Tube:	166	166	166	166	166
		Manometer:	Dwyer Mark II	Dwyer Mark II	Dwyer Mark II	Dwyer Mark II	Dwyer Mark II
DATE OF MEASUREMENT:			27-Jan-09	8-Feb-09	24-Mar-09	28-Apr-09	5-Jun-09
TIME OF MEASUREMENT:			2:30	12:30	11:30	14:00	9:15
PARAMETERS		UNITS	VALUES	VALUES	VALUES	VALUES	VALUES
Pipe dimensions							
Inside Diameter		inches	10.420	10.420	10.420	10.420	10.420
Area of cross section		square feet	0.5922	0.5922	0.5922	0.5922	0.5922
Flow Calculation							
Kp	pitot tube constant	ft/sec((lb/lb-mole)(in. Hg)/(R)(in H2O))^1/2	85.49	85.49	85.49	85.49	85.49
Cp	Pitot tube coefficient	dimensionless	1.00	1.00	1.00	1.00	1.00
dP	Average velocity pressure of stack gas	in H2O	0.148	0.259	0.318	0.159	0.320
Blower Inlet							
Ts	Stack temperature	Degrees Fahrenheit	65	60	64	74	80
		Degrees Rankine	525	520	524	534	540
Pg	Stack static pressure	inch H2O	-32	-57	-58	-48	-60
		inch Hg	(2.35)	(4.19)	(4.27)	(3.53)	(4.41)
Ps	Absolute stack gas pressure	inch Hg	28.02	26.10	25.97	26.52	25.62
Blower Outlet							
Ts	Stack temperature	Degrees Fahrenheit	88	110	110	110	109
		Degrees Rankine	548	570	570	570	569
Pg	Stack static pressure	inch H2O	44.3	44.3	44.3	44.3	47.1
		inch Hg	3.26	3.26	3.26	3.26	3.46
		psig	1.60	1.60	1.60	1.60	1.70
Pbar	Barometric pressure	inch Hg	30.37	30.29	30.24	30.05	30.03
Ps	Absolute stack gas pressure	inch Hg	33.63	33.55	33.50	33.31	33.49
Ms	Molecular weight of stack gas, wet	lb/lb-mole	27.44	27.87	28.05	27.64	27.97
Vs	Average stack gas velocity	feet per second	27.1	36.8	40.9	29.1	42.0
Qact	Volumetric Flow	actual cubic feet per minute	964	1,306	1,452	1,033	1,492
Qstd	Volumetric Flow at actual methane content	standard cubic feet per minute *	908	1,157	1,270	905	1,249
Qstd	Volumetric Flow at 50% methane	standard cubic feet per minute **	1,013	1,291	1,417	1,010	1,394
Ht HHV	Heat input	MMBtu per hour HHV	30.76	39.20	43.02	30.67	42.31
Ht LHV	Heat input	MMBtu per hour LHV	27.69	35.29	38.73	27.61	38.09
	Methane Content	%, vol/vol wet	58.40%	54.50%	52.98%	57.30%	52.60%
Diff. between pitot tube and orifice reading:			0.967	1.027	1.016	0.983	1.003
dP	Delta pressure across orifice plate	inches H2O	5.70	10.90	12.90	6.20	12.20
Qact	Volumetric Flow	acfm	811	1,144	1,244	863	1,205
Qstd	Volumetric Flow at actual methane content	standard cubic feet per minute *	878	1,188	1,290	890	1,252
Qstd	Volumetric Flow at 50% methane	standard cubic feet per minute **	1,026	1,295	1,367	1,019	1,317
Ht HHV	Heat input	MMBtu per hour HHV	31.14	39.31	41.51	30.95	39.99
Ht LHV	Heat input	MMBtu per hour LHV	28.04	35.39	37.37	27.86	36.00
* Standard conditions are corrected to 68 degrees F and 29.92 in Hg at actual methane content.							
** Standard conditions corrected to 50 % methane content.							
Input values are in blue or bold.							
Calculated output values are in black or not bold.							
Calculation Formulas:							
Vs = Kp*Cp*(sqrt dP) * sqrt (Ts/(Ps*Ms))							
Qact = Vs * A * 60							
Qstd = Qact * Tstd/ Ts * Ps/Pstd							
Flow, ACFM = 96.3221*SQRT(dP)*SQRT((460+Temperature)/(2.703*(Pressure +14.7)))							
Conversions and constants							
13.596 in H2O/in Hg							
1 PSI = 2.036 in HG							
1 PSI = 27.68 in WG							
Tstd = 528 degrees R							
Pstd = 29.92 in Hg							
Methane heat content = 1,012 BTU per scf HHV							
Methane heat content = 911 BTU per scf LHV							

Landfill Gas Flow Measurements					
Crapo Hill Landfill, New Bedford/Dartmouth, Massachusetts					
Measurements by	TY/RB	TY/RB	TY/RB	TY/RB	TY/RB
Date	27-Jan-09	8-Feb-09	24-Mar-09	28-Apr-09	5-Jun-09
Time	2:30	12:30	11:30	14:00	9:15
Flow valve	NA	NA	NA	NA	NA
Pipe inside diameter, inches	10.42	10.42	10.42	10.42	10.42
Orifice measurement, cfm	NA	NA	NA	NA	NA
Ambient Temperature, F	45	37	37	76	65
Barometric Pressure, In Hg	30.37	30.29	30.24	30.05	30.03
Blower Inlet Temperature, F	65	60	64	74	80
Outlet Temperature, F	88	110	110	110	109
Blower Inlet Pressure (SP), In H2O	-32	-57	-58	-48	-60
Blower Outlet Pressure, PSIG	1.60	1.60	1.60	1.60	1.70
Blower Outlet Pressure, In H2O	44.29	44.29	44.29	44.29	47.06
Measurement					
Manometer					
Pitot Tube					
Velocity Pressure (dP)					
Point					
1	0.13	0.25	0.3	0.15	0.32
2	0.15	0.26	0.32	0.16	0.32
3	0.15	0.26	0.32	0.16	0.32
4	0.15	0.26	0.32	0.16	0.32
5	0.15	0.26	0.32	0.16	0.32
6	0.15	0.26	0.32	0.16	0.32
7	0.15	0.26	0.32	0.16	0.32
8	0.15	0.26	0.32	0.16	0.32
9					
Average	0.148	0.259	0.318	0.159	0.320
Gas Composition					
Compound					
CH4	58.4%	54.5%	53.0%	57.3%	52.6%
CO2	40.6%	40.4%	39.5%	41.6%	39.6%
O2	0.00%	0.27%	0.55%	0.21%	0.67%
Balance	1.00%	4.92%	6.98%	0.93%	7.10%
Total	100.0%	100.1%	100.0%	100.0%	100.0%

Commonwealth New Bedford Energy, LLC
Greater New Bedford LFG Utilization Project
300 Samuel Barnett Blvd.
New Bedford, Massachusetts
(508) 985-0923

'California Analytical' Analyzer Calibration Results

Month: January-09

[illegible]

Commonwealth New Bedford Energy, LLC
Greater New Bedford LFG Utilization Project
300 Samuel Barnett Blvd.
New Bedford, Massachusetts
(508) 985-0923

'California Analytical' Analyzer Calibration Results

Month: February-09

[illegible]

**Commonwealth New Bedford Energy, LLC
Greater New Bedford LFG Utilization Project
300 Samuel Barnett Blvd.
New Bedford, Massachusetts
(508) 985-0923**

'California Analytical' Analyzer Calibration Results

[illegible]

**Commonwealth New Bedford Energy, LLC
Greater New Bedford LFG Utilization Project
300 Samuel Barnett Blvd.
New Bedford, Massachusetts
(508) 985-0923**

'California Analytical' Analyzer Calibration Results

[illegible]

Commonwealth New Bedford Energy, LLC
 Greater New Bedford LFG Utilization Project
 300 Samuel Barnett Blvd.
 New Bedford, Massachusetts
 (508) 985-0923

'California Analytical' Analyzer Calibration Results

Month: May 2009		Methane (% v/v) measurements				Oxygen (% v/v) measurements			
Week	Date	Pre-calibration	Zero gas	Span gas	Post-calibration	Pre-calibration	Zero gas	Span gas	Post-calibration
3-May-09	E4 install	E4 install	E4 install	E4 install	E4 install	E4 install	E4 install	E4 install	E4 install
10-May-09	TEOS *	TEOS	TEOS	TEOS	TEOS	TEOS	TEOS	TEOS	TEOS
17-May-09	21-May-09	55.22%	0.03%	55.78%	55.39%	0.52%	-0.01%	9.15%	0.57%
24-May-09									

* TEOS mean top end overhaul service.

Commonwealth New Bedford Energy, LLC
Greater New Bedford LFG Utilization Project
300 Samuel Barnett Blvd.
New Bedford, Massachusetts
(508) 985-0923

'California Analytical' Analyzer Calibration Results

[illegible]

SECOND HALF 2008

Calibration records of the LFG flow rate and compilation of methane content calibration reports for the California analytical analyzer for the periods

Landfill Gas Flow Measurements				
Crapo Hill Landfill, New Bedford/Dartmouth, Massachusetts				
Measurements by	TY	TY	TY	TY
Date	21-Jul-08	9-Sep-08	3-Oct-08	2-Dec-08
Time	15:17	13:15	12:40	9:30
Drive Speed (1 to 10)	NA	NA	NA	NA
Flow valve	NA	NA	NA	NA
Pipe inside diameter, inches	10.42	10.42	10.42	10.42
Orifice measurement, cfm	NA	NA	NA	NA
Ambient Temperature, F	90	77	60	45
Barometric Pressure, In Hg	29.77	29.88	29.71	29.99
Blower Inlet Temperature, F	90	84	81	70
Outlet Temperature, F	110	110	110	110
Blower Inlet Pressure (SP), In H2O	-40	-46	-52	-46
Blower Outlet Pressure, PSIG	1.90	1.50	1.50	1.50
Blower Outlet Pressure, In H2O	52.592	41.52	41.52	41.52
Measurement				
Manometer				
Pitot Tube				
Velocity Pressure (dP)				
Point				
1	0.3	0.25	0.24	0.24
2	0.3	0.27	0.28	0.25
3	0.3	0.26	0.29	0.25
4	0.29	0.28	0.29	0.26
5	0.29	0.28	0.29	0.26
6	0.29	0.28	0.29	0.26
7	0.29	0.28	0.28	0.26
8	0.28	0.29	0.28	0.26
9				
Average	0.293	0.274	0.280	0.255
Gas Composition				
Compound				
CH4	56.5%	57.3%	53.8%	58.0%
CO2	40.5%	41.4%	39.5%	41.0%
O2	0.00%	0.00%	0.36%	0.00%
N2	3.00%	1.30%	6.30%	1.00%
Total	100.0%	100.0%	100.0%	100.0%

Greater New Bedford LFG Utilization Project
New England Energy Services, CNBE
300 Samuel Barnett Blvd.
New Bedford, MA
(508) 985-0923

'California Analytical' Analyzer Calibration Results

July 2, 2008

CH4- pre-53.5, zero gas-.01, span gas-55.2, post-53.3
O2- pre-.89, zero gas-.02, span gas-9.03, post-.9

July 7, 2008

CH4- pre-53.9, zero gas-.03, span gas-55.6, post-53.6
O2- pre-.8, zero gas-.04, span gas-9, post-1.02

July 15, 2008

CH4- pre-54.5, zero gas-.02, span gas-55.2, post-54.3
O2- pre-.3, zero gas-.03, span gas-9.03, post-.32

July 21, 2008

CH4- pre-54.2, zero gas-.03, span gas-55.6, post-54
O2- pre-.7, zero gas-.04, span gas-9.02, post-.05

August 5, 2008

CH4- pre-53.1, zero gas-.00, span gas-55.0, post-53.0
O2- pre-0.5, zero gas-.02, span gas-8.99, post-0.5

August 11, 2008

CH4- pre-55.1, zero gas-.01, span gas-54.9, post-55.0
O2- pre-0.2, zero gas-.03, span gas-9.02, post-0.21

August 19, 2008

CH4- pre-58.9, zero gas-.03, span gas-55.1, post-58.7
O2- pre-0.0, zero gas-.01, span gas-9.02, post-0.00

August 25, 2008

CH4- pre-56.0, zero gas-.02, span gas-55.0, post-56.0
O2- pre-0.2, zero gas-.01, span gas-8.98, post-0.1

September 1, 2008

CH4- pre-52.3, zero gas-.00, span gas-55.0, post-52.4
O2- pre-0.5, zero gas-.02, span gas-9.03, post-0.5

September 8, 2008

CH4- pre-58.56, zero gas-.02, span gas-55.0, post-58.6

O2- pre-0.21, zero gas-.02, span gas-9.02, post-0.21

September 15, 2008

CH4- pre-56.4, zero gas-.02, span gas-55.0, post-56.3

O2- pre-0.2, zero gas-.02, span gas-9.02, post-0.21

September 22, 2008

CH4- pre-51.4, zero gas-.01, span gas-55.0, post-51.3

O2- pre-0.01, zero gas-.01, span gas-9.0, post-0.00

September 30, 2008

CH4- pre-53.9, zero gas-.01, span gas-55.0, post-54.1

O2- pre-0.3, zero gas-.01, span gas-8.98, post-0.4

October 07, 2008

CH4- pre-54.1, zero gas-.01, span gas-55.0, post-54.1

O2- pre-0.3, zero gas-.01, span gas-9.02, post-0.3

October 13, 2008

CH4- pre-55.6, zero gas-.01, span gas-55.0, post-55.64

O2- pre-0.2, zero gas-.01, span gas-9.0, post-0.21

Commonwealth New Bedford Energy
300 Samuel Barnett Blvd.
New Bedford, MA
(508) 985-0923

California Analytical Calibration Report 'October 2008'

DATE	GAS	PRE GAS	ZERO GAS	SPAN GAS	POST GAS
10/07/08	CH4	54.1	0.01	55.01	54.1
10/07/08	O2	0.3	0	9.02	0.31
10/13/08	CH4	55.6	0.01	55.02	55.64
10/13/08	O2	0.2	0.01	9	0.21
10/21/08	CH4	55.6	0.02	55	55.5
10/21/08	O2	0.1	-0.01	8.99	0
10/27/08	CH4	56.9	-0.01	54.95	56.9
10/27/08	O2	0	0	9.1	-0.01

Commonwealth New Bedford Energy
300 Samuel Barnett Blvd.
New Bedford, MA
(508) 985-0923

California Analytical Calibration Report 'November 2008'

DATE	GAS	PRE GAS	ZERO GAS	SPAN GAS	POST GAS
11/04/08	CH4	56.8	-0.01	55	56.75
11/04/08	O2	0.01	0	8.99	0
11/10/08	CH4	57.9	0	55.9	58
11/10/08	O2	0	-0.01	8.99	0
11/18/08	CH4	57.9	-0.01	54.92	57.5
11/18/08	O2	0.1	0.02	8.97	0
11/24/08	CH4	59.3	0	55.02	59.3
11/24/08	O2	0	-0.02	9.02	0

Commonwealth New Bedford Energy
300 Samuel Barnett Blvd.
New Bedford, MA
(508) 985-0923

California Analytical Calibration Report 'December 2008'

DATE	GAS	PRE GAS	ZERO GAS	SPAN GAS	POST GAS
------	-----	---------	----------	----------	----------

12/03/08	CH4	57.7	-0.02	55.95	57.5
12/03/08	O2	0	-0.01	9.02	0

12/08/08	CH4	57	-0.02	55.04	57.3
12/08/08	O2	0.02	0.01	9.02	0

12/15/08	CH4	56.7	-0.02	55.03	56.9
12/15/08	O2	0	0	9	0

12/23/08	CH4	57.6	0	54.97	57.6
12/23/08	O2	0	-0.02	9.01	-0.01

12/29/08	CH4	57.7	-0.02	55.03	57.9
12/29/08	O2	0	0	9	0.01

EXHIBIT 7

SAMPLES OF DATA REPORTED FROM
THE SCADA SYSTEM ON AN HOURLY BASIS

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	74.1949997	39	0	0	74.1949997	39	51.9	51.9	787	766	793	769	3148	3100
2:05	141	74	0	0	141	74	52.0	52.1	1495	1460	1504	1462	5979	5888
3:05	216	114	0	0	216	114	52.2	52.6	2298	2244	2310	2246	9180	9037
4:05	291	154	0	0	291	154	52.3	52.4	3101	3024	3117	3030	12386	12195
5:05	366	194	0	0	366	194	52.4	52.7	3904	3805	3921	3814	15592	15349
6:05	441	234	0	0	441	234	52.4	52.5	4708	4588	4727	4598	18797	18508
7:05	516	274	0	0	516	274	52.5	52.9	5511	5369	5531	5382	22003	21661
8:05	590	313	0	0	590	313	52.5	52.4	6301	6136	6324	6153	25156	24768
9:05	664	353	0	0	664	353	52.5	52.8	7105	6918	7126	6938	28366	27925
10:05	739	393	0	0	739	393	52.5	52.8	7909	7699	7932	7722	31575	31087
11:05	814	433	0	0	814	433	52.5	52.6	8713	8478	8736	8506	34780	34240
12:05	884	470	0	0	884	470	52.5	52.2	9462	9204	9484	9237	37776	37191
13:05	954	507	0	0	954	507	52.5	52.4	10212	9933	10234	9968	40773	40140
14:05	1029	546	0	0	1029	546	52.4	51.7	11016	10715	11038	10752	43985	43303
15:05	1103	586	0	0	1103	586	52.5	53.0	11820	11496	11840	11534	47194	46461
16:05	1178	626	0	0	1178	626	52.5	52.9	12624	12277	12643	12317	50404	49621
17:05	1253	666	0	0	1253	666	52.5	52.9	13427	13057	13448	13100	53610	52778
18:05	1328	706	0	0	1328	706	52.5	52.8	14230	13837	14251	13885	56818	55934
19:05	1402	746	0	0	1402	746	52.6	52.8	15035	14618	15053	14671	60032	59100
20:05	1477	786	0	0	1477	786	52.6	52.9	15840	15398	15857	15458	63245	62260
21:05	1552	826	0	0	1552	826	52.6	52.9	16644	16178	16663	16243	66457	65425
22:05	1627	866	0	0	1627	866	52.6	52.7	17449	16961	17465	17028	69666	68581
23:05	1693	901	0	0	1693	901	52.6	52.1	18159	17655	18174	17722	72500	71372
0:04	1768.13599	941	0	0	1768.13599	941	52.6	52.9	18962	18439	18979	18506	75707	74529

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
							Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		%	%	Hours	Hours	Hours	Hours	kW	kW
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU								
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	74.8320007	40	0	0	74.8320007	40	52.8	52.8	803	781	804	784	3205	3154
2:05	149	80	0	0	149	80	52.9	53.0	1606	1563	1607	1566	6406	6309
3:05	224	120	0	0	224	120	52.9	53.0	2408	2345	2413	2350	9610	9461
4:05	298	160	0	0	298	160	53.1	53.4	3212	3126	3219	3134	12813	12621
5:05	372	200	0	0	372	200	53.1	53.5	4015	3910	4024	3917	16015	15772
6:05	446	240	0	0	446	240	53.2	53.3	4818	4689	4829	4700	19218	18929
7:05	520	280	0	0	520	280	53.2	53.3	5621	5470	5634	5485	22424	22085
8:05	594	320	0	0	594	320	53.2	53.3	6423	6253	6440	6269	25628	25239
9:05	667	359	0	0	667	359	53.2	53.1	7213	7025	7232	7040	28781	28345
10:05	733	394	0	0	733	394	53.1	52.5	7933	7724	7953	7744	31658	31172
11:05	808	435	0	0	808	435	53.2	53.6	8758	8525	8781	8549	34946	34409
12:05	884	476	0	0	884	476	53.2	53.7	9582	9324	9610	9354	38237	37644
13:05	960	517	0	0	960	517	53.2	53.5	10406	10127	10438	10159	41527	40883
14:05	1036	558	0	0	1036	558	53.2	53.3	11229	10929	11264	10964	44815	44114
15:05	1112	599	0	0	1112	599	53.2	53.1	12051	11732	12090	11767	48106	47351
16:05	1186	639	0	0	1186	639	53.3	53.6	12847	12506	12889	12546	51290	50482
17:05	1259	679	0	0	1259	679	53.3	53.5	13641	13279	13685	13322	54460	53604
18:05	1333	719	0	0	1333	719	53.3	53.8	14436	14053	14482	14098	57629	56721
19:05	1402	756	0	0	1402	756	53.3	53.2	15177	14776	15226	14822	60588	59637
20:05	1473	794	0	0	1473	794	53.3	52.8	15944	15525	15996	15573	63652	62650
21:05	1546	834	0	0	1546	834	53.3	53.7	16737	16302	16792	16349	66819	65772
22:05	1620	874	0	0	1620	874	53.3	53.6	17529	17072	17590	17125	69985	68886
23:05	1694	914	0	0	1694	914	53.3	53.5	18322	17843	18385	17901	73155	72009
0:04	1767.71204	954	0	0	1767.71204	954	53.3	53.5	19113	18614	19181	18675	76320	75126




CommonWealth

New Bedford Energy LLC

Hourly Report

Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
	0:05	0	0	0	0	0	0	0	0	0	0	0	0	0
1:05	74.0550003	40	0	0	74.0550003	40	53.4	53.4	793	771	793	775	3169	3123
2:05	148	79	0	0	148	79	52.6	51.9	1587	1541	1588	1549	6336	6244
3:05	222	119	0	0	222	119	52.8	53.3	2380	2311	2382	2325	9497	9359
4:05	297	158	0	0	297	158	52.6	52.0	3174	3082	3175	3101	12667	12485
5:05	369	196	0	0	369	196	52.5	52.1	3941	3827	3942	3850	15727	15499
6:05	434	231	0	0	434	231	52.5	52.5	4655	4519	4655	4548	18574	18308
7:05	507	269	0	0	507	269	52.4	51.7	5448	5292	5447	5322	21743	21427
8:05	581	308	0	0	581	308	52.4	52.2	6244	6063	6238	6092	24909	24551
9:05	656	348	0	0	656	348	52.4	52.3	7049	6844	7041	6875	28126	27715
10:05	733	389	0	0	733	389	52.4	53.0	7862	7636	7852	7670	31368	30907
11:05	800	425	0	0	800	425	52.5	53.0	8676	8426	8660	8037	34177	33671
12:05	857	456	0	0	857	456	52.6	54.0	9492	9217	9468	8059	36636	36092
13:05	914	487	0	0	914	487	52.6	53.3	10316	9354	10283	8856	39220	38640
14:05	971	518	0	0	971	518	52.7	54.2	11139	9399	11103	9659	41720	41105
15:05	1044	558	0	0	1044	558	52.8	53.8	11976	10114	11939	10479	44964	44297
16:05	1110	594	0	0	1110	594	52.9	53.7	12705	10822	12666	11188	47865	47156
17:05	1186	635	0	0	1186	635	52.9	53.5	13529	11623	13490	11993	51149	50387
18:05	1262	676	0	0	1262	676	52.9	53.2	14353	12424	14313	12798	54432	53622
19:05	1339	717	0	0	1339	717	52.9	53.0	15178	13224	15135	13604	57718	56855
20:05	1415	758	0	0	1415	758	52.9	52.9	16000	14027	15956	14407	61001	60087
21:05	1492	799	0	0	1492	799	52.9	52.9	16823	14826	16779	15211	64283	63319
22:05	1569	840	0	0	1569	840	52.9	52.7	17647	15625	17604	16013	67563	66546
23:05	1646	881	0	0	1646	881	52.9	52.9	18471	16424	18427	16817	70843	69779
0:04	1721.16504	921	0	0	1721.16504	921	52.9	52.3	19297	17225	19250	17620	74125	73007



CommonWealth

New Bedford Energy LLC

Hourly Report

Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	75.4100037	40	0	0	75.4100037	40	52.4	52.4	825	802	826	805	3280	3236
2:05	140	74	0	0	140	74	52.4	52.4	1526	1483	1528	1489	6066	5978
3:05	215	114	0	0	215	114	52.4	52.4	2351	2283	2355	2293	9346	9211
4:05	291	153	0	0	291	153	52.0	50.9	3178	3084	3182	3099	12629	12444
5:05	366	192	0	0	366	192	51.8	51.0	4002	3883	4007	3901	15909	15673
6:05	442	231	0	0	442	231	51.6	50.9	4826	4684	4832	4705	19189	18906
7:05	518	270	0	0	518	270	51.5	50.9	5651	5488	5655	5511	22472	22135
8:05	594	310	0	0	594	310	51.6	52.0	6475	6289	6475	6316	25753	25371
9:05	671	350	0	0	671	350	51.5	51.2	7293	7085	7288	7117	29009	28573
10:05	748	390	0	0	748	390	51.5	51.0	8110	7876	8101	7913	32256	31767
11:05	825	430	0	0	825	430	51.5	51.4	8926	8666	8913	8708	35505	34957
12:05	893	465	0	0	893	465	51.4	50.8	9647	9366	9632	9411	38372	37777
13:05	969	504	0	0	969	504	51.4	51.0	10445	10140	10427	10190	41552	40905
14:05	1044	544	0	0	1044	544	51.5	52.7	11239	10911	11219	10966	44716	44017
15:05	1119	584	0	0	1119	584	51.6	52.9	12033	11684	12011	11740	47878	47132
16:05	1194	624	0	0	1194	624	51.7	52.9	12827	12455	12801	12516	51043	50245
17:05	1267	663	0	0	1267	663	51.7	52.6	13608	13216	13580	13278	54153	53310
18:05	1341	702	0	0	1341	702	51.7	51.8	14403	13987	14372	14053	57320	56424
19:05	1416	742	0	0	1416	742	51.8	52.6	15198	14758	15162	14828	60485	59542
20:05	1492	782	0	0	1492	782	51.8	52.6	15993	15530	15954	15603	63651	62654
21:05	1568	823	0	0	1568	823	51.9	53.0	16800	16312	16757	16391	66868	65822
22:05	1639	861	0	0	1639	861	51.9	52.6	17554	17043	17509	17126	69874	68781
23:05	1707	897	0	0	1707	897	51.9	52.6	18269	17737	18222	17824	72721	71582
0:04	1782.32605	937	0	0	1782.32605	937	51.9	52.4	19063	18506	19016	18597	75879	74691

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	75.5019989	40	0	0	75.5019989	40	52.4	52.4	804	782	803	785	3201	3153
2:05	151	80	0	0	151	80	52.4	52.5	1607	1562	1607	1568	6399	6300
3:05	226	120	0	0	226	120	52.5	52.6	2410	2344	2413	2352	9596	9450
4:05	301	160	0	0	301	160	52.5	52.6	3213	3127	3221	3135	12792	12595
5:05	371	197	0	0	371	197	52.5	52.3	3963	3855	3971	3866	15779	15537
6:05	435	232	0	0	435	232	52.6	53.5	4659	4532	4668	4545	18548	18264
7:05	509	271	0	0	509	271	52.7	52.7	5450	5297	5458	5316	21695	21361
8:05	583	311	0	0	583	311	52.7	53.3	6254	6079	6261	6099	24896	24514
9:05	657	351	0	0	657	351	52.8	52.9	7061	6869	7068	6893	28124	27688
10:05	734	391	0	0	734	391	52.7	51.8	7887	7674	7894	7701	31424	30932
11:05	810	432	0	0	810	432	52.7	53.1	8716	8479	8723	8509	34731	34183
12:05	886	473	0	0	886	473	52.7	53.2	9545	9285	9551	9317	38036	37432
13:05	962	514	0	0	962	514	52.8	53.7	10374	10089	10381	10124	41340	40681
14:05	1037	555	0	0	1037	555	52.9	53.6	11204	10894	11213	10931	44643	43930
15:05	1113	596	0	0	1113	596	52.9	53.6	12034	11700	12044	11738	47947	47180
16:05	1187	636	0	0	1187	636	53.0	53.5	12848	12492	12856	12530	51188	50371
17:05	1261	676	0	0	1261	676	53.0	53.3	13661	13282	13671	13322	54432	53567
18:05	1335	716	0	0	1335	716	53.0	53.5	14475	14075	14485	14115	57674	56761
19:05	1406	755	0	0	1406	755	53.1	53.8	15262	14839	15272	14880	60809	59845
20:05	1472	790	0	0	1472	790	53.0	52.9	15980	15537	15991	15580	63676	62670
21:05	1545	830	0	0	1545	830	53.1	54.1	16783	16317	16793	16360	66868	65815
22:05	1619	870	0	0	1619	870	53.1	53.3	17597	17111	17606	17154	70110	69005
23:05	1693	910	0	0	1693	910	53.1	53.5	18410	17899	18420	17946	73348	72195
0:04	1766.77698	950	0	0	1766.77698	950	53.1	53.5	19224	18690	19235	18739	76588	75387

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	74.3410034	40	0	0	74.3410034	40	53.2	53.2	814	791	814	794	3243	3190
2:05	148	80	0	0	148	80	53.3	53.4	1629	1582	1628	1589	6484	6383
3:05	223	120	0	0	223	120	53.2	53.0	2443	2371	2443	2383	9724	9573
4:05	297	160	0	0	297	160	53.2	53.3	3258	3162	3256	3177	12964	12763
5:05	369	199	0	0	369	199	53.3	53.8	4046	3927	4041	3943	16093	15845
6:05	435	235	0	0	435	235	53.4	53.9	4765	4625	4760	4645	18954	18660
7:05	496	268	0	0	496	268	53.4	53.6	5431	5270	5425	5293	21601	21268
8:05	565	305	0	0	565	305	53.4	52.7	6191	6008	6185	6032	24626	24244
9:05	639	345	0	0	639	345	53.3	53.1	7005	6800	6996	6825	27869	27439
10:05	713	385	0	0	713	385	53.3	53.3	7820	7591	7807	7618	31110	30631
11:05	788	425	0	0	788	425	53.3	53.2	8634	8383	8621	8411	34353	33824
12:05	862	465	0	0	862	465	53.3	53.4	9446	9173	9437	9205	37599	37018
13:05	936	505	0	0	936	505	53.3	53.3	10260	9962	10252	9997	40844	40210
14:05	1010	545	0	0	1010	545	53.3	53.6	11074	10755	11066	10790	44089	43403
15:05	1084	584	0	0	1084	584	53.3	52.2	11888	11551	11881	11582	47337	46598
16:05	1157	623	0	0	1157	623	53.2	52.2	12701	12340	12695	12373	50579	49788
17:05	1229	662	0	0	1229	662	53.2	53.7	13486	13102	13483	13140	53713	52873
18:05	1289	694	0	0	1289	694	53.2	52.7	14136	13735	14134	13774	56307	55428
19:05	1358	731	0	0	1358	731	53.2	53.3	14880	14460	14879	14501	59281	58357
20:05	1429	769	0	0	1429	769	53.2	52.9	15653	15212	15652	15254	62362	61392
21:05	1501	808	0	0	1501	808	53.2	53.2	16440	15978	16439	16019	65496	64479
22:05	1576	849	0	0	1576	849	53.2	54.0	17253	16767	17253	16810	68740	67674
23:05	1651	889	0	0	1651	889	53.2	52.9	18068	17557	18067	17602	71985	70870
0:04	1725.59399	929	0	0	1725.59399	929	53.2	52.9	18882	18348	18879	18395	75230	74066

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	74.4520035	40	0	0	74.4520035	40	53.1	53.1	814	794	813	794	3238	3190
2:05	149	80	0	0	149	80	53.1	53.2	1628	1584	1626	1587	6475	6378
3:05	223	121	0	0	223	121	53.6	54.5	2440	2375	2439	2380	9712	9566
4:05	298	162	0	0	298	162	53.8	54.4	3255	3166	3253	3173	12951	12757
5:05	372	203	0	0	372	203	53.9	54.3	4069	3956	4068	3965	16188	15945
6:05	444	242	0	0	444	242	53.8	53.5	4856	4720	4854	4732	19318	19028
7:05	509	277	0	0	509	277	53.8	53.5	5561	5409	5557	5421	22129	21797
8:05	581	316	0	0	581	316	53.7	53.4	6350	6174	6344	6187	25260	24881
9:05	653	355	0	0	653	355	53.7	53.5	7137	6939	7132	6953	28392	27965
10:05	727	395	0	0	727	395	53.7	53.3	7951	7730	7945	7746	31633	31154
11:05	802	435	0	0	802	435	53.6	53.2	8765	8521	8759	8538	34880	34347
12:05	876	474	0	0	876	474	53.5	51.8	9579	9312	9572	9330	38122	37535
13:05	950	513	0	0	950	513	53.3	51.8	10392	10103	10386	10123	41364	40723
14:05	1025	552	0	0	1025	552	53.2	52.0	11205	10895	11199	10915	44609	43913
15:05	1099	591	0	0	1099	591	53.1	51.8	12016	11687	12014	11705	47853	47103
16:05	1174	631	0	0	1174	631	53.1	52.9	12829	12478	12830	12496	51096	50290
17:05	1249	671	0	0	1249	671	53.1	52.6	13642	13270	13645	13289	54340	53479
18:05	1324	711	0	0	1324	711	53.0	52.3	14456	14062	14461	14080	57580	56666
19:05	1400	751	0	0	1400	751	53.0	52.3	15270	14855	15277	14873	60824	59856
20:05	1477	791	0	0	1477	791	52.9	51.2	16098	15660	16107	15678	64122	63100
21:05	1538	823	0	0	1538	823	52.9	51.8	16750	16294	16761	16311	66717	65653
22:05	1615	863	0	0	1615	863	52.8	51.8	17562	17086	17574	17103	69957	68843
23:05	1691	903	0	0	1691	903	52.8	51.9	18374	17878	18389	17894	73196	72032
0:04	1767.45801	944	0	0	1767.45801	944	52.8	52.9	19188	18671	19204	18686	76433	75220

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
							Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
Time	LFG Flow to Engines KSCF	MMBTU	LFG Flow to Flare KSCF	MMBTU	Total LFG Flow KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	76.7200012	41	0	0	76.7200012	41	52.8	52.8	814	793	816	792	3236	3188
2:05	153	82	0	0	153	82	52.8	52.8	1628	1585	1631	1585	6474	6378
3:05	230	123	0	0	230	123	52.8	52.9	2440	2376	2446	2377	9709	9565
4:05	307	164	0	0	307	164	52.8	52.7	3253	3168	3262	3171	12946	12750
5:05	383	205	0	0	383	205	52.8	52.9	4066	3961	4079	3963	16184	15939
6:05	460	245	0	0	460	245	52.7	51.9	4879	4753	4894	4756	19423	19129
7:05	523	279	0	0	523	279	52.7	52.8	5557	5410	5572	5416	22123	21785
8:05	594	317	0	0	594	317	52.7	52.9	6318	6149	6331	6156	25145	24760
9:05	671	358	0	0	671	358	52.7	53.0	7132	6938	7144	6949	28388	27948
10:05	741	396	0	0	741	396	52.8	53.1	7892	7676	7901	7689	31412	30919
11:05	800	428	0	0	800	428	52.8	53.5	8529	8295	8536	8310	33951	33416
12:05	874	467	0	0	874	467	52.8	52.7	9315	9060	9321	9078	37089	36502
13:05	949	508	0	0	949	508	52.9	53.6	10129	9850	10132	9871	40332	39689
14:05	1024	549	0	0	1024	549	53.0	54.0	10938	10634	10940	10659	43549	42855
15:05	1098	589	0	0	1098	589	53.0	53.4	11732	11407	11731	11435	46712	45970
16:05	1172	629	0	0	1172	629	53.0	53.3	12526	12180	12521	12209	49877	49083
17:05	1247	669	0	0	1247	669	53.0	53.2	13320	12951	13313	12983	53038	52197
18:05	1321	709	0	0	1321	709	53.0	53.1	14113	13722	14103	13757	56198	55305
19:05	1389	745	0	0	1389	745	53.0	52.3	14841	14428	14829	14467	59091	58154
20:05	1455	780	0	0	1455	780	53.0	52.6	15541	15109	15528	15150	61884	60901
21:05	1528	819	0	0	1528	819	53.0	52.6	16321	15867	16307	15910	64995	63965
22:05	1603	859	0	0	1603	859	53.0	52.8	17114	16641	17101	16683	68154	67072
23:05	1677	899	0	0	1677	899	53.0	53.0	17907	17412	17894	17456	71314	70185
0:04	1752.30505	939	0	0	1752.30505	939	53.0	52.8	18703	18184	18686	18231	74475	73294

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	75.0159988	40	0	0	75.0159988	40	52.7	52.7	795	770	794	774	3161	3113
2:05	150	80	0	0	150	80	52.7	52.7	1589	1539	1587	1549	6320	6221
3:05	225	120	0	0	225	120	52.7	52.7	2383	2314	2379	2324	9479	9332
4:05	300	160	0	0	300	160	52.7	52.5	3176	3087	3175	3099	12636	12438
5:05	375	200	0	0	375	200	52.6	52.6	3970	3859	3966	3874	15796	15551
6:05	448	239	0	0	448	239	52.7	52.7	4739	4606	4732	4623	18850	18554
7:05	521	278	0	0	521	278	52.7	52.8	5505	5351	5498	5372	21904	21563
8:05	597	318	0	0	597	318	52.6	52.1	6306	6127	6296	6153	25086	24690
9:05	673	357	0	0	673	357	52.4	51.0	7111	6909	7101	6936	28287	27838
10:05	749	397	0	0	749	397	52.4	52.1	7917	7689	7905	7719	31491	30988
11:05	825	436	0	0	825	436	52.2	50.8	8722	8470	8708	8503	34693	34136
12:05	901	475	0	0	901	475	52.1	50.8	9526	9251	9512	9287	37896	37284
13:05	975	514	0	0	975	514	52.1	51.8	10316	10019	10301	10057	41044	40378
14:05	1046	551	0	0	1046	551	52.0	51.2	11080	10759	11064	10802	44085	43368
15:05	1114	586	0	0	1114	586	52.0	51.1	11804	11461	11787	11508	46970	46205
16:05	1189	625	0	0	1189	625	51.9	51.3	12607	12239	12590	12289	50163	49350
17:05	1265	665	0	0	1265	665	52.0	52.2	13410	13018	13393	13072	53362	52501
18:05	1341	705	0	0	1341	705	52.0	52.0	14213	13797	14193	13855	56561	55652
19:05	1417	745	0	0	1417	745	52.0	51.9	15015	14578	14997	14637	59762	58804
20:05	1493	785	0	0	1493	785	51.9	51.9	15818	15360	15803	15419	62964	61957
21:05	1569	825	0	0	1569	825	51.9	52.0	16623	16141	16608	16203	66162	65107
22:05	1645	865	0	0	1645	865	51.9	52.0	17425	16923	17410	16987	69362	68254
23:05	1721	905	0	0	1721	905	52.0	52.0	18230	17705	18213	17771	72560	71405
0:04	1789.53503	941	0	0	1789.53503	941	52.0	52.1	18953	18408	18936	18477	75439	74241

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
							Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		%	%	Hours	Hours	Hours	Hours	kW	kW
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU								
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	68.2350006	36	0	0	68.2350006	36	52.1	52.1	724	702	724	706	2878	2831
2:05	136	72	0	0	136	72	52.1	52.2	1447	1405	1447	1411	5756	5666
3:05	212	112	0	0	212	112	52.2	52.3	2251	2186	2249	2196	8954	8816
4:05	288	152	0	0	288	152	52.2	52.3	3055	2966	3052	2981	12153	11964
5:05	363	192	0	0	363	192	52.2	52.2	3861	3750	3855	3764	15353	15117
6:05	439	232	0	0	439	232	52.3	52.5	4666	4530	4657	4547	18554	18267
7:05	514	272	0	0	514	272	52.3	52.4	5471	5310	5460	5332	21755	21420
8:05	589	312	0	0	589	312	52.4	52.9	6275	6091	6263	6116	24959	24573
9:05	663	352	0	0	663	352	52.4	52.9	7079	6870	7065	6900	28157	27718
10:05	739	393	0	0	739	393	52.6	53.6	7896	7662	7880	7696	31411	30917
11:05	810	431	0	0	810	431	52.6	52.8	8673	8419	8653	8453	34507	33962
12:05	876	467	0	0	876	467	52.7	53.9	9396	9123	9373	9158	37388	36794
13:05	948	506	0	0	948	506	52.7	53.3	10188	9894	10159	9929	40538	39892
14:05	1023	546	0	0	1023	546	52.8	53.1	10993	10675	10961	10714	43742	43043
15:05	1097	586	0	0	1097	586	52.8	53.2	11795	11455	11763	11498	46943	46192
16:05	1171	626	0	0	1171	626	52.8	53.3	12600	12236	12565	12283	50147	49348
17:05	1245	666	0	0	1245	666	52.9	53.5	13403	13020	13368	13066	53352	52505
18:05	1319	706	0	0	1319	706	52.9	53.4	14206	13800	14169	13848	56556	55661
19:05	1393	746	0	0	1393	746	52.9	53.4	15009	14581	14969	14631	59756	58813
20:05	1467	786	0	0	1467	786	52.9	53.5	15813	15362	15770	15414	62959	61968
21:05	1540	825	0	0	1540	825	52.9	53.0	16604	16130	16560	16184	66107	65069
22:05	1609	862	0	0	1609	862	52.9	52.8	17354	16860	17309	16916	69097	68014
23:05	1680	900	0	0	1680	900	52.9	53.1	18119	17601	18071	17661	72141	71012
0:04	1751.63403	939	0	0	1751.63403	939	53.0	53.6	18898	18353	18848	18420	75236	74061

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	74.8799973	40	0	0	74.8799973	40	52.8	52.8	806	784	803	787	3203	3151
2:05	150	80	0	0	150	80	52.7	52.6	1611	1564	1607	1572	6403	6303
3:05	225	120	0	0	225	120	52.6	52.4	2415	2345	2412	2357	9602	9450
4:05	301	160	0	0	301	160	52.5	52.0	3219	3127	3214	3142	12803	12603
5:05	378	200	0	0	378	200	52.4	52.0	4023	3906	4018	3926	16001	15748
6:05	454	241	0	0	454	241	52.4	52.9	4827	4688	4820	4710	19201	18897
7:05	531	282	0	0	531	282	52.5	52.8	5632	5469	5621	5494	22403	22047
8:05	607	322	0	0	607	322	52.4	51.6	6437	6253	6422	6278	25607	25200
9:05	677	358	0	0	677	358	52.2	50.9	7175	6969	7156	6996	28544	28087
10:05	750	396	0	0	750	396	52.2	52.0	7940	7711	7917	7741	31588	31079
11:05	822	434	0	0	822	434	52.2	51.9	8705	8452	8680	8485	34633	34071
12:05	898	474	0	0	898	474	52.2	52.0	9510	9235	9481	9268	37835	37219
13:05	975	514	0	0	975	514	52.1	51.0	10329	10029	10296	10065	41089	40418
14:05	1052	554	0	0	1052	554	52.1	51.9	11134	10809	11101	10849	44288	43563
16:05	1127	593	0	0	1127	593	52.0	52.0	11931	11582	11896	11626	47459	46683
17:05	1202	632	0	0	1202	632	52.0	51.4	12725	12355	12689	12399	50621	49797
18:05	1277	671	0	0	1277	671	51.9	51.2	13519	13125	13480	13173	53783	52911
19:05	1353	710	0	0	1353	710	51.9	51.0	14313	13898	14272	13947	56946	56026
20:05	1429	750	0	0	1429	750	51.9	51.9	15106	14672	15063	14720	60109	59136
21:05	1504	789	0	0	1504	789	51.8	51.3	15886	15432	15838	15480	63217	62197
22:05	1581	829	0	0	1581	829	51.8	51.7	16678	16202	16630	16253	66378	65305
23:05	1657	869	0	0	1657	869	51.8	51.4	17469	16973	17422	17026	69536	68414
0:04	1734.31897	909	0	0	1734.31897	909	51.8	51.4	18262	17744	18215	17801	72694	71521

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	76.8089981	40	0	0	76.8089981	40	51.5	51.5	795	773	793	776	3155	3104
2:05	154	80	0	0	154	80	51.4	51.3	1591	1544	1586	1551	6316	6215
3:05	231	120	0	0	231	120	51.4	51.5	2385	2316	2380	2327	9473	9320
4:05	307	160	0	0	307	160	51.4	51.5	3178	3087	3172	3101	12631	12431
5:05	384	200	0	0	384	200	51.4	51.4	3972	3857	3965	3878	15791	15539
6:05	457	238	0	0	457	238	51.4	51.5	4727	4590	4719	4615	18793	18496
7:05	531	276	0	0	531	276	51.4	50.8	5495	5336	5484	5363	21848	21502
8:05	605	315	0	0	605	315	51.4	51.9	6262	6082	6248	6111	24903	24509
9:05	682	355	0	0	682	355	51.4	51.3	7055	6853	7039	6886	28065	27618
10:05	759	395	0	0	759	395	51.4	51.4	7849	7623	7829	7662	31231	30731
11:05	836	435	0	0	836	435	51.4	51.5	8644	8396	8618	8437	34398	33844
12:05	912	475	0	0	912	475	51.4	51.6	9437	9167	9409	9212	37564	36955
13:05	989	515	0	0	989	515	51.5	51.8	10231	9937	10199	9986	40727	40063
14:05	1065	555	0	0	1065	555	51.5	51.8	11026	10707	10992	10760	43887	43170
15:05	1135	587	0	0	1135	587	51.1	44.9	11817	11187	11780	11517	46728	45964
16:05	1190	616	0	0	1190	616	51.2	52.7	12625	11187	12576	12299	49130	48332
17:05	1243	645	0	0	1243	645	51.3	54.2	13422	11187	13363	13074	51507	50675
18:05	1295	674	0	0	1295	674	51.4	54.9	14212	11187	14143	13840	53862	52998
19:05	1349	704	0	0	1349	704	51.6	55.1	15029	11187	14948	14634	56295	55394
20:05	1403	734	0	0	1403	734	51.7	54.6	15862	11187	15767	15442	58767	57837
21:05	1462	766	0	0	1462	766	51.8	53.9	16650	11343	16560	16218	61298	60330
22:05	1538	805	0	0	1538	805	51.7	50.5	17443	12094	17353	16992	64423	63412
23:05	1616	844	0	0	1616	844	51.6	49.5	18235	12845	18145	17765	67546	66485
0:04	1694.63501	883	0	0	1694.63501	883	51.5	49.0	19030	13597	18937	18532	70664	69557

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	78.4280014	39	0	0	78.4280014	39	49.1	49.1	795	750	793	762	3109	3058
2:05	157	79	0	0	157	79	49.9	50.6	1589	1499	1584	1521	6213	6117
3:05	233	118	0	0	233	118	50.1	50.5	2370	2239	2362	2281	9279	9133
4:05	307	156	0	0	307	156	50.2	50.4	3138	2967	3128	3032	12301	12112
5:05	384	195	0	0	384	195	50.2	50.4	3932	3716	3919	3805	15421	15185
6:05	461	235	0	0	461	235	50.4	51.4	4729	4470	4711	4578	18541	18258
7:05	539	274	0	0	539	274	50.3	49.5	5523	5220	5507	5344	21661	21332
8:05	618	314	0	0	618	314	50.2	49.9	6317	5974	6299	6103	24771	24390
9:05	697	353	0	0	697	353	50.0	48.4	7112	6725	7090	6852	27876	27448
10:05	777	392	0	0	777	392	49.9	48.6	7905	7473	7882	7603	30980	30504
11:05	856	431	0	0	856	431	49.8	48.5	8699	8223	8674	8348	34081	33556
12:05	935	470	0	0	935	470	49.6	48.5	9494	8972	9468	9100	37190	36614
13:05	1015	509	0	0	1015	509	49.6	48.6	10288	9721	10262	9858	40303	39674
14:05	1094	548	0	0	1094	548	49.5	48.4	11083	10473	11055	10616	43419	42735
15:05	1172	586	0	0	1172	586	49.4	48.1	11862	11211	11835	11361	46481	45742
16:05	1251	625	0	0	1251	625	49.4	48.9	12658	11951	12630	12116	49582	48788
17:05	1329	663	0	0	1329	663	49.3	48.5	13452	12643	13423	12873	52632	51786
18:05	1406	701	0	0	1406	701	49.3	48.7	14246	13334	14216	13631	55702	54804
19:05	1481	740	0	0	1481	740	49.4	51.2	15039	14023	15013	14392	58760	57813
20:05	1553	779	0	0	1553	779	49.6	53.8	15834	14716	15808	15167	61832	60838
21:05	1624	818	0	0	1624	818	49.8	53.9	16627	15406	16602	15941	64901	63862
22:05	1696	857	0	0	1696	857	49.9	53.6	17420	16097	17396	16714	67969	66881
23:05	1768	896	0	0	1768	896	50.1	53.5	18215	16786	18189	17488	71039	69906
0:04	1840.40405	935	0	0	1840.40405	935	50.2	53.4	19008	17478	18982	18262	74106	72929

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	72.5220032	39	0	0	72.5220032	39	53.1	53.1	793	692	794	773	3068	3020
2:05	145	78	0	0	145	78	53.0	52.9	1586	1385	1589	1545	6129	6036
3:05	218	117	0	0	218	117	53.1	53.3	2378	2077	2388	2319	9196	9054
4:05	290	156	0	0	290	156	53.2	53.3	3173	2770	3175	3093	12261	12077
5:05	362	195	0	0	362	195	53.2	53.5	3966	3461	3969	3867	15325	15097
6:05	434	234	0	0	434	234	53.3	53.4	4759	4152	4763	4641	18385	18112
7:05	506	273	0	0	506	273	53.3	53.3	5552	4844	5555	5416	21450	21134
8:05	579	312	0	0	579	312	53.3	53.2	6345	5536	6346	6191	24515	24153
9:05	651	351	0	0	651	351	53.3	53.3	7138	6226	7139	6965	27581	27175
10:05	724	391	0	0	724	391	53.3	53.9	7946	6928	7946	7753	30702	30250
11:05	796	430	0	0	796	430	53.4	53.9	8740	7620	8741	8527	33773	33274
12:05	867	469	0	0	867	469	53.4	54.0	9535	8312	9535	9300	36845	36298
13:05	937	507	0	0	937	507	53.4	53.5	10316	8992	10317	10061	39864	39270
14:05	1006	544	0	0	1006	544	53.4	53.1	11083	9659	11084	10808	42833	42192
15:05	1077	582	0	0	1077	582	53.4	52.8	11877	10350	11879	11582	45906	45216
16:05	1148	620	0	0	1148	620	53.3	52.9	12669	11042	12673	12355	48979	48240
17:05	1220	658	0	0	1220	658	53.3	52.6	13463	11734	13469	13128	52049	51262
18:05	1291	697	0	0	1291	697	53.3	53.9	14257	12425	14264	13902	55119	54285
19:05	1363	736	0	0	1363	736	53.4	53.6	15050	13118	15060	14676	58187	57306
20:05	1434	774	0	0	1434	774	53.3	52.7	15842	13811	15851	15450	61259	60331
21:05	1506	813	0	0	1506	813	53.3	53.7	16635	14504	16648	16224	64331	63356
22:05	1578	852	0	0	1578	852	53.3	53.4	17429	15198	17442	16997	67403	66382
23:05	1651	891	0	0	1651	891	53.3	53.2	18221	15890	18236	17771	70475	69409
0:04	1722.25	930	0	0	1722.25	930	53.4	54.0	19002	16570	19015	18532	73490	72377

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	70.5270004	38	0	0	70.5270004	38	53.2	53.2	766	668	767	749	2963	2922
2:05	145	78	0	0	145	78	53.3	53.4	1573	1371	1573	1535	6076	5987
3:05	217	117	0	0	217	117	53.2	53.0	2366	2062	2365	2311	9139	9008
4:05	287	155	0	0	287	155	53.4	54.0	3092	2755	3088	3021	12003	11827
5:05	313	170	0	0	313	170	53.6	56.4	3092	3452	3088	3021	12697	12509
6:05	340	185	0	0	340	185	53.8	55.6	3186	4160	3088	3189	13664	13453
7:05	402	219	0	0	402	219	53.8	53.9	4009	4953	3452	4001	16465	16221
8:05	482	260	0	0	482	260	53.3	50.9	4824	5745	4265	4805	19698	19406
9:05	563	301	0	0	563	301	52.8	49.6	5650	6546	5089	5579	22950	22601
10:05	645	341	0	0	645	341	52.2	48.2	6475	7349	5911	6334	26171	25766
11:05	724	380	0	0	724	380	51.9	48.9	7260	8110	6694	7043	29224	28765
12:05	804	419	0	0	804	419	51.5	48.1	8058	8886	7492	7767	32335	31821
13:05	885	458	0	0	885	458	51.1	47.5	8864	9672	8294	8497	35474	34904
14:05	952	492	0	0	952	492	51.1	50.6	9530	10318	8960	9145	38122	37508
15:05	1027	532	0	0	1027	532	51.2	52.9	10346	11109	9774	9938	41350	40686
16:05	1102	573	0	0	1102	573	51.4	53.9	11162	11901	10588	10732	44580	43869
17:05	1177	613	0	0	1177	613	51.5	52.7	11979	12692	11401	11525	47806	47047
18:05	1252	654	0	0	1252	654	51.6	53.7	12794	13481	12213	12318	51034	50227
19:05	1328	695	0	0	1328	695	51.7	53.6	13607	14272	13026	13111	54264	53409
20:05	1404	736	0	0	1404	736	51.8	53.4	14422	15063	13838	13904	57494	56587
21:05	1475	774	0	0	1475	774	51.9	53.0	15181	15802	14595	14644	60510	59558
22:05	1548	813	0	0	1548	813	51.9	52.2	15969	16568	15382	15411	63630	62629
23:05	1625	854	0	0	1625	854	51.9	52.8	16783	17359	16196	16204	66855	65804
0:04	1701.84497	895	0	0	1701.84497	895	52.0	52.8	17599	18150	17010	16998	70081	68982

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	75.6470032	40	0	0	75.6470032	40	52.3	52.3	803	778	802	780	3171	3120
2:05	153	81	0	0	153	81	52.4	52.5	1618	1570	1616	1576	6399	6299
3:05	230	122	0	0	230	122	52.4	52.4	2434	2362	2428	2371	9625	9474
4:05	307	163	0	0	307	163	52.4	52.5	3251	3152	3244	3165	12849	12647
5:05	386	205	0	0	386	205	52.5	52.8	4081	3958	4071	3974	16130	15878
6:05	464	246	0	0	464	246	52.4	52.3	4897	4750	4885	4768	19354	19049
7:05	540	286	0	0	540	286	52.4	51.9	5698	5527	5684	5549	22527	22175
8:05	615	326	0	0	615	326	52.4	52.6	6486	6291	6470	6314	25644	25240
9:05	690	366	0	0	690	366	52.4	52.7	7276	7055	7258	7081	28761	28308
10:05	767	407	0	0	767	407	52.4	52.4	8093	7844	8074	7874	31986	31478
11:05	843	447	0	0	843	447	52.4	52.1	8896	8621	8875	8655	35164	34601
12:05	920	487	0	0	920	487	52.3	51.2	9710	9411	9693	9449	38396	37776
13:05	997	527	0	0	997	527	52.2	51.3	10526	10201	10508	10242	41625	40948
14:05	1074	567	0	0	1074	567	52.2	51.6	11341	10991	11323	11035	44854	44121
15:05	1151	607	0	0	1151	607	52.1	51.5	12156	11782	12139	11828	48082	47293
16:05	1228	647	0	0	1228	647	52.1	51.3	12972	12574	12955	12622	51308	50465
17:05	1305	687	0	0	1305	687	52.0	51.2	13787	13364	13771	13415	54536	53640
18:05	1382	727	0	0	1382	727	52.0	51.1	14602	14154	14586	14206	57760	56813
19:05	1457	766	0	0	1457	766	51.9	51.5	15390	14919	15374	14972	60880	59884
20:05	1532	805	0	0	1532	805	51.9	51.5	16178	15685	16162	15738	64000	62955
21:05	1610	845	0	0	1610	845	51.9	50.8	16991	16477	16977	16530	67223	66128
22:05	1688	886	0	0	1688	886	51.9	51.6	17805	17267	17790	17324	70447	69299
23:05	1767	927	0	0	1767	927	51.8	51.7	18619	18059	18603	18115	73670	72472
0:04	1845.53406	968	0	0	1845.53406	968	51.8	51.4	19433	18849	19416	18910	76894	75644

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	78.3389969	41	0	0	78.3389969	41	51.7	51.7	814	791	815	791	3223	3172
2:05	157	82	0	0	157	82	51.7	51.6	1628	1581	1630	1585	6446	6344
3:05	235	123	0	0	235	123	51.7	51.6	2443	2372	2445	2375	9665	9512
4:05	314	164	0	0	314	164	51.6	51.5	3257	3163	3260	3166	12888	12684
5:05	390	204	0	0	390	204	51.7	52.0	4044	3929	4048	3931	16004	15750
6:05	465	243	0	0	465	243	51.7	51.5	4819	4678	4823	4682	19064	18761
7:05	544	284	0	0	544	284	51.6	51.3	5633	5467	5637	5473	22289	21933
8:05	622	325	0	0	622	325	51.6	51.5	6449	6257	6452	6264	25513	25105
9:05	700	365	0	0	700	365	51.5	50.8	7254	7040	7256	7047	28705	28241
10:05	778	405	0	0	778	405	51.5	50.9	8054	7814	8055	7827	31885	31366
11:05	855	445	0	0	855	445	51.4	51.4	8853	8589	8854	8608	35068	34493
12:05	931	485	0	0	931	485	51.5	51.7	9651	9363	9652	9388	38249	37618
13:05	1007	524	0	0	1007	524	51.4	50.9	10453	10141	10454	10171	41445	40758
14:05	1082	563	0	0	1082	563	51.4	50.9	11256	10924	11260	10955	44646	43903
15:05	1159	603	0	0	1159	603	51.4	51.6	12059	11707	12065	11737	47846	47047
16:05	1236	643	0	0	1236	643	51.4	51.6	12862	12489	12870	12518	51048	50193
17:05	1312	683	0	0	1312	683	51.4	51.7	13664	13269	13673	13299	54249	53341
18:05	1385	721	0	0	1385	721	51.4	51.5	14426	14010	14437	14043	57292	56335
19:05	1462	761	0	0	1462	761	51.4	51.2	15228	14795	15240	14824	60493	59484
20:05	1538	800	0	0	1538	800	51.4	50.8	16019	15566	16033	15594	63642	62582
21:05	1614	840	0	0	1614	840	51.4	51.7	16810	16337	16822	16366	66788	65679
22:05	1692	880	0	0	1692	880	51.4	51.0	17613	17120	17625	17149	69989	68829
23:05	1770	920	0	0	1770	920	51.4	50.8	18415	17901	18431	17932	73187	71978
0:04	1847.18896	960	0	0	1847.18896	960	51.4	51.1	19220	18681	19234	18715	76387	75128

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	77.3430023	40	0	0	77.3430023	40	51.1	51.1	803	781	807	783	3199	3150
2:05	155	80	0	0	155	80	51.1	51.1	1606	1565	1612	1567	6397	6300
3:05	232	120	0	0	232	120	51.1	51.0	2409	2350	2416	2349	9591	9446
4:05	308	160	0	0	308	160	51.3	52.0	3197	3116	3208	3118	12727	12534
5:05	382	199	0	0	382	199	51.5	52.4	3961	3859	3974	3862	15764	15524
6:05	456	238	0	0	456	238	51.6	52.1	4724	4602	4738	4606	18797	18511
7:05	533	278	0	0	533	278	51.5	51.0	5526	5383	5541	5388	21995	21659
8:05	611	318	0	0	611	318	51.5	51.0	6330	6161	6342	6171	25195	24809
9:05	685	357	0	0	685	357	51.5	51.7	7102	6912	7113	6923	28263	27826
10:05	760	396	0	0	760	396	51.5	51.6	7884	7670	7892	7685	31372	30881
11:05	836	435	0	0	836	435	51.4	50.9	8677	8437	8685	8458	34532	33985
12:05	911	474	0	0	911	474	51.4	51.0	9470	9208	9480	9232	37691	37088
13:05	987	513	0	0	987	513	51.4	50.9	10264	9979	10273	10007	40851	40192
14:05	1063	552	0	0	1063	552	51.3	50.8	11058	10748	11066	10780	44013	43298
15:05	1136	590	0	0	1136	590	51.3	51.3	11825	11493	11832	11527	47068	46300
16:05	1207	627	0	0	1207	627	51.3	51.5	12566	12211	12571	12249	50017	49197
17:05	1282	666	0	0	1282	666	51.3	51.3	13346	12967	13350	13010	53127	52259
18:05	1357	705	0	0	1357	705	51.3	51.4	14125	13726	14129	13771	56233	55316
19:05	1433	744	0	0	1433	744	51.3	50.4	14919	14496	14924	14544	59394	58423
20:05	1500	778	0	0	1500	778	51.3	50.7	15607	15165	15613	15215	62133	61119
21:05	1575	817	0	0	1575	817	51.3	51.3	16388	15923	16396	15977	65242	64173
22:05	1651	857	0	0	1651	857	51.3	51.6	17182	16694	17191	16750	68399	67280
23:05	1728	897	0	0	1728	897	51.3	51.5	17974	17466	17982	17521	71555	70381
0:04	1805.16296	937	0	0	1805.16296	937	51.3	51.4	18767	18239	18782	18293	74709	73487

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	76.6660004	40	0	0	76.6660004	40	51.6	51.6	792	773	791	773	3156	3102
2:05	152	79	0	0	152	79	51.3	51.1	1572	1533	1573	1533	6258	6157
3:05	224	116	0	0	224	116	51.2	50.9	2313	2252	2315	2255	9205	9054
4:05	302	156	0	0	302	156	51.0	50.3	3118	3035	3122	3041	12415	12215
5:05	374	193	0	0	374	193	50.9	50.8	3859	3755	3865	3763	15360	15109
6:05	452	233	0	0	452	233	51.0	51.2	4653	4526	4656	4536	18515	18215
7:05	529	273	0	0	529	273	51.0	51.1	5445	5296	5450	5309	21672	21318
8:05	606	313	0	0	606	313	51.0	51.1	6239	6066	6243	6083	24831	24423
9:05	684	352	0	0	684	352	50.9	50.0	7032	6839	7038	6856	27989	27528
10:05	761	391	0	0	761	391	50.8	49.8	7825	7608	7829	7629	31149	30632
11:05	839	431	0	0	839	431	50.8	50.9	8617	8382	8623	8401	34311	33738
12:05	916	470	0	0	916	470	50.7	50.1	9411	9152	9416	9173	37473	36844
13:05	992	509	0	0	992	509	50.7	50.2	10204	9923	10209	9946	40635	39950
14:05	1066	547	0	0	1066	547	50.7	50.6	10970	10668	10975	10694	43693	42954
15:05	1144	586	0	0	1144	586	50.6	49.8	11775	11446	11780	11476	46895	46100
16:05	1219	624	0	0	1219	624	50.6	50.2	12548	12198	12553	12231	49976	49132
17:05	1293	663	0	0	1293	663	50.6	51.5	13322	12950	13325	12983	53055	52163
18:05	1368	702	0	0	1368	702	50.7	51.4	14094	13701	14097	13735	56136	55191
19:05	1443	741	0	0	1443	741	50.7	51.4	14866	14453	14869	14488	59213	58220
20:05	1519	780	0	0	1519	780	50.7	51.2	15641	15205	15646	15243	62293	61246
21:05	1594	819	0	0	1594	819	50.8	51.0	16415	15959	16421	15998	65371	64272
22:05	1669	857	0	0	1669	857	50.7	50.0	17187	16710	17197	16753	68444	67296
23:05	1742	894	0	0	1742	894	50.7	50.3	17935	17438	17943	17483	71424	70225
0:04	1813.31604	931	0	0	1813.31604	931	50.7	51.3	18667	18150	18675	18197	74345	73102

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	73.9089966	38	0	0	73.9089966	38	50.8	50.8	760	738	761	742	3027	2976
2:05	150	77	0	0	150	77	50.9	51.0	1534	1490	1535	1497	6110	6009
3:05	225	116	0	0	225	116	51.0	51.2	2308	2241	2306	2250	9187	9038
4:05	300	155	0	0	300	155	51.1	51.3	3082	2991	3079	3004	12268	12067
5:05	375	194	0	0	375	194	51.1	51.1	3854	3744	3851	3759	15344	15098
6:05	451	232	0	0	451	232	50.9	49.9	4627	4498	4625	4515	18422	18126
7:05	526	271	0	0	526	271	50.9	51.1	5399	5250	5399	5269	21496	21151
8:05	601	309	0	0	601	309	50.8	49.9	6171	6002	6171	6021	24575	24181
9:05	676	347	0	0	676	347	50.7	50.1	6944	6751	6944	6776	27654	27207
10:05	750	385	0	0	750	385	50.7	50.9	7704	7489	7704	7518	30681	30187
11:05	819	420	0	0	819	420	50.7	50.5	8414	8177	8414	8209	33505	32967
12:05	889	456	0	0	889	456	50.7	50.2	9150	8894	9148	8925	36432	35848
13:05	962	493	0	0	962	493	50.6	50.1	9909	9633	9909	9666	39461	38829
14:05	1036	531	0	0	1036	531	50.6	50.8	10682	10386	10683	10421	42543	41862
15:05	1110	569	0	0	1110	569	50.7	51.0	11454	11137	11457	11174	45624	44895
16:05	1184	607	0	0	1184	607	50.7	50.9	12226	11890	12231	11926	48703	47924
17:05	1258	645	0	0	1258	645	50.7	50.9	12998	12639	13004	12678	51784	50956
18:05	1331	683	0	0	1331	683	50.7	50.9	13771	13392	13779	13432	54863	53987
19:05	1406	722	0	0	1406	722	50.8	52.0	14544	14145	14554	14187	57944	57018
20:05	1480	761	0	0	1480	761	50.8	52.0	15317	14897	15329	14939	61022	60044
21:05	1553	799	0	0	1553	799	50.8	51.2	16078	15637	16090	15681	64047	63018
22:05	1623	835	0	0	1623	835	50.8	50.9	16800	16340	16812	16386	66922	65848
23:05	1690	870	0	0	1690	870	50.9	51.4	17496	17018	17508	17065	69694	68573
0:04	1763.65198	908	0	0	1763.65198	908	50.9	51.2	18254	17761	18267	17807	72721	71553

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	73.0999985	38	0	0	73.0999985	38	51.4	51.4	760	738	761	742	3030	2981
2:05	148	77	0	0	148	77	51.3	51.2	1546	1503	1547	1510	6164	6065
3:05	222	115	0	0	222	115	51.1	50.8	2319	2253	2322	2264	9240	9095
4:05	296	153	0	0	296	153	51.0	50.8	3092	3006	3096	3019	12318	12121
5:05	370	191	0	0	370	191	51.0	50.8	3866	3757	3871	3775	15399	15157
6:05	444	230	0	0	444	230	51.2	52.0	4640	4508	4646	4529	18477	18184
7:05	517	268	0	0	517	268	51.2	51.7	5399	5247	5405	5271	21502	21165
8:05	589	306	0	0	589	306	51.3	51.8	6160	5985	6167	6013	24533	24145
9:05	660	343	0	0	660	343	51.3	51.4	6906	6712	6913	6742	27510	27077
10:05	732	380	0	0	732	380	51.3	51.4	7653	7437	7662	7472	30490	30006
11:05	801	417	0	0	801	417	51.4	52.5	8389	8151	8399	8187	33416	32887
12:05	874	456	0	0	874	456	51.5	52.6	9163	8902	9173	8940	36498	35921
13:05	947	494	0	0	947	494	51.5	51.7	9937	9653	9943	9695	39579	38954
14:05	1020	532	0	0	1020	532	51.6	51.8	10711	10404	10714	10449	42662	41989
15:05	1092	570	0	0	1092	570	51.6	52.2	11486	11155	11488	11203	45744	45023
16:05	1163	608	0	0	1163	608	51.6	52.3	12260	11906	12261	11958	48826	48057
17:05	1235	646	0	0	1235	646	51.7	52.1	13036	12658	13035	12711	51905	51088
18:05	1308	684	0	0	1308	684	51.7	51.7	13810	13409	13810	13465	54987	54122
19:05	1378	721	0	0	1378	721	51.7	52.6	14546	14121	14545	14180	57913	56999
20:05	1446	757	0	0	1446	757	51.7	52.2	15268	14821	15267	14884	60790	59831
21:05	1515	794	0	0	1515	794	51.8	52.4	16004	15534	16001	15600	63715	62707
22:05	1587	832	0	0	1587	832	51.8	52.7	16752	16261	16748	16328	66695	65641
23:05	1660	871	0	0	1660	871	51.9	52.8	17511	17001	17509	17069	69721	68615
0:04	1733.64404	910	0	0	1733.64404	910	51.9	52.1	18282	17754	18284	17822	72801	71646

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	74.210985	39	0	0	74.210985	39	51.9	51.9	773	751	774	754	3078	3028
2:05	148	78	0	0	148	78	52.0	52.0	1545	1502	1547	1508	6157	6054
3:05	222	117	0	0	222	117	52.0	52.1	2318	2252	2321	2262	9233	9087
4:05	296	156	0	0	296	156	52.1	52.5	3092	3005	3095	3016	12310	12114
5:05	368	194	0	0	368	194	52.1	52.2	3852	3743	3856	3757	15336	15096
6:05	439	231	0	0	439	231	51.9	50.9	4611	4482	4616	4497	18361	18076
7:05	508	267	0	0	508	267	51.9	51.8	5330	5185	5336	5201	21232	20902
8:05	581	305	0	0	581	305	51.9	51.4	6103	5935	6109	5953	24307	23933
9:05	655	344	0	0	655	344	51.9	52.3	6880	6690	6883	6709	27398	26972
10:05	724	380	0	0	724	380	51.8	51.2	7492	7429	7643	7451	30277	29804
11:05	777	408	0	0	777	408	51.9	52.6	7492	8202	8259	8226	32458	31952
12:05	820	432	0	0	820	432	52.1	55.2	7715	8981	8259	9006	34245	33713
13:05	886	469	0	0	886	469	52.3	55.3	8543	9770	8756	9798	37174	36602
14:05	960	509	0	0	960	509	52.4	53.5	9372	10561	9570	10590	40425	39806
15:05	1034	549	0	0	1034	549	52.4	53.2	10201	11352	10385	11380	43679	43011
16:05	1106	587	0	0	1106	587	52.5	52.6	10987	12105	11160	12135	46775	46061
17:05	1180	627	0	0	1180	627	52.5	53.4	11790	12876	11953	12908	49944	49183
18:05	1254	666	0	0	1254	666	52.5	52.0	12593	13646	12746	13683	53114	52303
19:05	1328	705	0	0	1328	705	52.5	52.3	13399	14420	13540	14459	56286	55425
20:05	1402	745	0	0	1402	745	52.5	53.0	14203	15190	14335	15233	59455	58546
21:05	1477	785	0	0	1477	785	52.5	52.6	15008	15960	15130	16007	62626	61664
22:05	1553	825	0	0	1553	825	52.5	52.5	15812	16734	15927	16782	65795	64786
23:05	1628	865	0	0	1628	865	52.5	52.2	16614	17507	16720	17556	68960	67898
0:04	1704.39905	905	0	0	1704.39905	905	52.5	51.9	17417	18279	17512	18331	72128	71015

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	76.1920013	40	0	0	76.1920013	40	51.9	51.9	803	773	793	773	3166	3117
2:05	153	80	0	0	153	80	51.8	51.7	1606	1546	1586	1550	6337	6233
3:05	227	119	0	0	227	119	51.7	51.6	2397	2307	2366	2312	9452	9302
4:05	304	159	0	0	304	159	51.8	51.8	3201	3079	3161	3087	12621	12416
5:05	380	199	0	0	380	199	51.8	51.8	4004	3854	3955	3859	15786	15532
6:05	456	239	0	0	456	239	51.8	52.0	4805	4623	4748	4633	18950	18644
7:05	532	279	0	0	532	279	51.8	51.8	5608	5395	5542	5407	22114	21755
8:05	608	319	0	0	608	319	51.8	52.0	6409	6163	6335	6181	25282	24874
9:05	684	358	0	0	684	358	51.7	50.7	7203	6936	7127	6956	28439	27975
10:05	760	397	0	0	760	397	51.6	51.1	7996	7708	7920	7729	31598	31084
11:05	830	434	0	0	830	434	51.7	52.0	8791	8480	8498	8502	34540	33978
12:05	906	473	0	0	906	473	51.6	51.0	9599	9268	9303	9288	37750	37134
13:05	979	511	0	0	979	511	51.6	51.4	10385	10033	10081	10053	40869	40193
14:05	1052	549	0	0	1052	549	51.6	51.0	11176	10800	10866	10822	44012	43281
15:05	1127	588	0	0	1127	588	51.6	51.8	11970	11567	11659	11594	47169	46383
16:05	1202	627	0	0	1202	627	51.6	51.4	12764	12337	12450	12368	50332	49485
17:05	1278	667	0	0	1278	667	51.6	51.7	13556	13109	13241	13142	53497	52596
18:05	1355	707	0	0	1355	707	51.6	51.4	14350	13880	14034	13917	56660	55698
19:05	1432	747	0	0	1432	747	51.5	51.2	15145	14650	14826	14693	59822	58804
20:05	1510	787	0	0	1510	787	51.5	50.9	15940	15420	15620	15468	62982	61903
21:05	1589	827	0	0	1589	827	51.4	50.0	16748	16203	16427	16255	66188	65050
22:05	1661	864	0	0	1661	864	51.4	50.7	17489	16922	17168	16981	69136	67950
23:05	1737	903	0	0	1737	903	51.4	50.4	18268	17678	17947	17742	72243	71000
0:04	1812.23596	942	0	0	1812.23596	942	51.4	51.4	19034	18426	18716	18487	75289	73998

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	76.2470016	39	0	0	76.2470016	39	50.5	50.5	780	761	781	760	3105	3051
2:05	150	77	0	0	150	77	50.8	51.0	1534	1494	1536	1495	6102	5997
3:05	228	117	0	0	228	117	50.8	50.7	2328	2267	2332	2270	9259	9103
4:05	305	157	0	0	305	157	50.8	51.1	3122	3039	3127	3044	12414	12202
5:05	383	197	0	0	383	197	50.8	50.9	3915	3809	3920	3815	15568	15307
6:05	461	237	0	0	461	237	50.8	50.8	4709	4582	4714	4589	18729	18410
7:05	537	276	0	0	537	276	50.8	50.5	5487	5341	5493	5348	21833	21464
8:05	611	314	0	0	611	314	50.8	50.9	6241	6074	6246	6082	24828	24405
9:05	685	352	0	0	685	352	50.7	50.3	7007	6819	7013	6830	27883	27409
10:05	759	390	0	0	759	390	50.8	50.9	7770	7560	7776	7574	30922	30394
11:05	836	429	0	0	836	429	50.7	50.1	8562	8336	8568	8360	34099	33511
12:05	914	469	0	0	914	469	50.7	50.8	9361	9126	9371	9168	37332	36683
13:05	992	509	0	0	992	509	50.7	50.8	10160	9916	10173	9973	40563	39853
14:05	1069	548	0	0	1069	548	50.7	49.9	10959	10706	10977	10775	43789	43017
15:05	1146	588	0	0	1146	588	50.7	51.0	11756	11497	11780	11580	47017	46184
16:05	1223	628	0	0	1223	628	50.7	51.5	12553	12272	12576	12372	50214	49322
17:05	1300	668	0	0	1300	668	50.8	51.4	13348	13046	13376	13160	53406	52457
18:05	1376	707	0	0	1376	707	50.8	51.0	14133	13808	14160	13939	56550	55543
19:05	1452	747	0	0	1452	747	50.8	52.0	14916	14572	14943	14718	59691	58628
20:05	1530	787	0	0	1530	787	50.8	50.7	15717	15349	15740	15512	62886	61759
21:05	1608	828	0	0	1608	828	50.9	51.6	16517	16128	16535	16305	66073	64890
22:05	1686	868	0	0	1686	868	50.9	50.7	17315	16904	17330	17098	69266	68028
23:05	1764	908	0	0	1764	908	50.9	50.5	18114	17682	18126	17889	72459	71163
0:04	1842.828	948	0	0	1842.828	948	50.8	50.4	18911	18459	18921	18679	75646	74299

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	78.1709976	40	0	0	78.1709976	40	50.6	50.6	798	780	798	792	3192	3134
2:05	157	81	0	0	157	81	51.1	51.6	1598	1557	1597	1583	6387	6276
3:05	235	122	0	0	235	122	51.3	51.6	2398	2336	2396	2373	9576	9411
4:05	312	162	0	0	312	162	51.3	51.3	3182	3102	3181	3152	12711	12491
5:05	391	203	0	0	391	203	51.3	51.6	3981	3879	3980	3943	15898	15627
6:05	466	242	0	0	466	242	51.3	50.9	4751	4630	4750	4708	18981	18653
7:05	545	283	0	0	545	283	51.3	51.5	5548	5409	5547	5501	22175	21795
8:05	624	324	0	0	624	324	51.3	51.4	6346	6186	6344	6294	25367	24929
9:05	701	364	0	0	701	364	51.3	51.4	7128	6948	7126	7062	28491	28000
10:05	776	403	0	0	776	403	51.3	51.0	7900	7701	7898	7819	31575	31028
11:05	851	442	0	0	851	442	51.3	51.4	8673	8452	8669	8572	34654	34048
12:05	925	481	0	0	925	481	51.4	51.9	9445	9202	9442	9325	37734	37073
13:05	999	519	0	0	999	519	51.3	50.8	10217	9951	10215	10076	40814	40098
14:05	1070	556	0	0	1070	556	51.3	51.3	10964	10675	10962	10803	43791	43022



CommonWealth

New Bedford Energy LLC

Hourly Report

Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
							0							
11:05	811	426	0	0	811	426	51.9	51.9	8474	8245	8478	8260	33757	33171
12:05	886	465	0	0	886	465	51.9	51.7	9246	8998	9251	9013	36838	36193
13:05	960	504	0	0	960	504	51.9	51.9	10017	9748	10025	9765	39918	39217
14:05	1033	543	0	0	1033	543	51.9	52.7	10789	10499	10799	10517	42999	42243
15:05	1106	581	0	0	1106	581	51.9	51.7	11564	11251	11574	11271	46084	45273
16:05	1178	619	0	0	1178	619	51.9	51.9	12337	12003	12348	12023	49164	48304
17:05	1250	656	0	0	1250	656	51.9	50.8	13109	12758	13122	12775	52245	51337
18:05	1322	694	0	0	1322	694	51.9	51.9	13881	13512	13898	13527	55327	54371
19:05	1394	731	0	0	1394	731	51.8	50.8	14640	14250	14658	14266	58353	57351
20:05	1460	765	0	0	1460	765	51.8	51.6	15322	14914	15343	14932	61074	60030
21:05	1525	799	0	0	1525	799	51.8	51.3	16005	15578	16028	15598	63795	62709
22:05	1587	831	0	0	1587	831	51.7	50.9	16648	16206	16673	16224	66359	65234
23:05	1659	868	0	0	1659	868	51.7	50.8	17395	16933	17424	16951	69335	68164
0:04	1732.29504	906	0	0	1732.29504	906	51.7	51.3	18156	17670	18187	17691	72364	71147

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	74.3690033	39	0	0	74.3690033	39	51.8	51.8	773	754	773	752	3076	3031
2:05	149	78	0	0	149	78	51.8	51.7	1547	1508	1544	1506	6151	6062
3:05	224	117	0	0	224	117	51.7	51.7	2318	2261	2318	2258	9225	9088
4:05	298	156	0	0	298	156	51.7	51.8	3091	3012	3091	3011	12299	12119
5:05	372	195	0	0	372	195	51.8	51.9	3863	3762	3865	3765	15375	15152
6:05	446	234	0	0	446	234	51.8	51.8	4635	4514	4638	4519	18451	18186
7:05	514	269	0	0	514	269	51.8	51.5	5330	5193	5335	5198	21218	20912
8:05	581	304	0	0	581	304	51.7	51.6	6025	5869	6031	5876	23988	23642
9:05	655	343	0	0	655	343	51.7	51.7	6798	6620	6804	6629	27066	26675
10:05	727	380	0	0	727	380	51.6	50.8	7543	7347	7552	7355	30043	29606
11:05	801	418	0	0	801	418	51.6	50.8	8315	8100	8327	8108	33122	32637
12:05	875	456	0	0	875	456	51.5	51.2	9088	8852	9102	8860	36199	35666
13:05	947	494	0	0	947	494	51.5	51.6	9862	9604	9878	9612	39275	38694
14:05	1020	532	0	0	1020	532	51.5	51.5	10634	10354	10654	10362	42355	41725
15:05	1093	570	0	0	1093	570	51.5	51.7	11407	11107	11429	11113	45435	44756
16:05	1165	608	0	0	1165	608	51.5	51.7	12181	11859	12206	11864	48516	47789
17:05	1238	646	0	0	1238	646	51.6	51.7	12953	12614	12981	12616	51594	50819
18:05	1311	684	0	0	1311	684	51.5	51.4	13724	13366	13757	13368	54671	53848
19:05	1391	725	0	0	1391	725	51.5	51.1	14560	14182	14598	14182	58004	57130
20:05	1453	757	0	0	1453	757	51.5	50.6	15219	14822	15259	14822	60621	59706
21:05	1523	793	0	0	1523	793	51.4	50.7	15954	15538	15998	15538	63545	62585
22:05	1597	831	0	0	1597	831	51.4	50.8	16727	16291	16773	16292	66625	65617
23:05	1671	869	0	0	1671	869	51.4	50.9	17500	17044	17547	17045	69705	68649
0:04	1744.61401	908	0	0	1744.61401	908	51.4	52.2	18272	17799	18322	17796	72782	71678

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	73.7369995	39	0	0	73.7369995	39	52.3	52.3	774	752	774	753	3078	3031
2:05	147	78	0	0	147	78	52.3	52.4	1548	1506	1548	1507	6159	6065
3:05	221	117	0	0	221	117	52.3	52.3	2321	2260	2323	2261	9236	9095
4:05	295	156	0	0	295	156	52.3	52.3	3092	3013	3097	3015	12312	12125
5:05	368	195	0	0	368	195	52.3	52.5	3864	3765	3873	3768	15389	15155
6:05	441	234	0	0	441	234	52.4	52.6	4636	4517	4646	4521	18466	18188
7:05	514	272	0	0	514	272	52.2	51.3	5406	5270	5420	5275	21542	21219
8:05	580	307	0	0	580	307	52.3	52.6	6101	5946	6116	5952	24308	23944
9:05	650	344	0	0	650	344	52.3	52.6	6836	6658	6851	6667	27235	26826
10:05	721	383	0	0	721	383	52.5	53.8	7596	7398	7610	7409	30266	29808
11:05	794	422	0	0	794	422	52.5	53.0	8370	8150	8383	8165	33346	32841
12:05	866	461	0	0	866	461	52.6	53.4	9144	8901	9157	8920	36427	35875
13:05	938	500	0	0	938	500	52.7	53.6	9918	9650	9931	9675	39509	38910
14:05	1010	538	0	0	1010	538	52.7	52.5	10692	10400	10705	10430	42591	41944
15:05	1081	576	0	0	1081	576	52.7	52.8	11465	11155	11479	11186	45676	44980
16:05	1152	614	0	0	1152	614	52.7	52.7	12239	11909	12252	11941	48759	48016
17:05	1223	652	0	0	1223	652	52.7	52.8	13013	12661	13027	12695	51841	51051
18:05	1294	691	0	0	1294	691	52.8	54.1	13786	13412	13803	13447	54917	54080
19:05	1366	730	0	0	1366	730	52.8	54.0	14560	14162	14578	14199	57995	57111
20:05	1433	767	0	0	1433	767	52.9	54.5	15284	14866	15301	14902	60871	59943
21:05	1499	803	0	0	1499	803	52.9	54.1	15994	15555	16012	15593	63694	62723
22:05	1570	842	0	0	1570	842	53.0	53.7	16768	16309	16787	16349	66776	65760
23:05	1642	881	0	0	1642	881	53.0	54.0	17540	17060	17563	17103	69853	68793
0:04	1713.10205	920	0	0	1713.10205	920	53.1	54.0	18312	17815	18338	17855	72929	71827

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	71.5049973	39	0	0	71.5049973	39	53.9	53.9	773	752	775	753	3078	3033
2:05	143	78	0	0	143	78	54.0	54.0	1548	1505	1551	1506	6154	6068
3:05	214	117	0	0	214	117	54.0	54.1	2321	2257	2326	2258	9228	9101
4:05	285	156	0	0	285	156	54.0	54.1	3094	3009	3101	3011	12302	12135
5:05	357	195	0	0	357	195	54.0	54.1	3868	3761	3874	3763	15378	15170
6:05	429	235	0	0	429	235	54.1	54.3	4653	4522	4660	4529	18504	18252
7:05	496	272	0	0	496	272	54.2	54.7	5374	5222	5381	5231	21375	21084
8:05	555	304	0	0	555	304	54.1	53.8	6006	5837	6010	5846	23889	23564
9:05	624	342	0	0	624	342	54.1	54.1	6754	6563	6757	6574	26865	26497
10:05	697	382	0	0	697	382	54.2	54.8	7534	7317	7535	7333	29964	29548
11:05	769	422	0	0	769	422	54.2	54.7	8319	8076	8318	8097	33086	32621
12:05	841	461	0	0	841	461	54.2	53.3	9103	8837	9100	8859	36206	35692
13:05	913	500	0	0	913	500	54.1	53.3	9885	9597	9885	9621	39322	38758
14:05	986	539	0	0	986	539	54.0	53.3	10668	10358	10668	10384	42440	41827
15:05	1058	578	0	0	1058	578	54.0	53.2	11447	11117	11445	11143	45538	44876
16:05	1130	617	0	0	1130	617	53.9	53.4	12219	11868	12218	11895	48619	47909
17:05	1202	656	0	0	1202	656	53.9	53.4	12992	12619	12990	12649	51701	50944
18:05	1270	692	0	0	1270	692	53.9	52.9	13713	13321	13711	13353	54575	53774
19:05	1336	728	0	0	1336	728	53.8	53.5	14422	14008	14420	14043	57400	56555
20:05	1405	765	0	0	1405	765	53.8	53.0	15158	14724	15155	14758	60328	59438
21:05	1478	804	0	0	1478	804	53.7	52.8	15933	15477	15929	15512	63409	62472
22:05	1551	843	0	0	1551	843	53.7	52.8	16706	16230	16702	16267	66487	65503
23:05	1624	882	0	0	1624	882	53.7	52.8	17477	16983	17474	17021	69566	68533
0:04	1697.06897	921	0	0	1697.06897	921	53.6	52.8	18249	17733	18248	17773	72644	71569

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0	0		0	0	0	0	0	0
1:05	73.1819992	39	0	0	73.1819992	39	52.7	52.7	773	752	774	754	3077	3031
2:05	146	78	0	0	146	78	52.6	52.6	1546	1505	1549	1508	6155	6067
3:05	219	117	0	0	219	117	52.7	52.8	2319	2254	2323	2262	9230	9100
4:05	293	156	0	0	293	156	52.7	52.5	3091	3006	3100	3016	12304	12126
5:05	366	195	0	0	366	195	52.7	52.6	3863	3758	3874	3769	15377	15158
6:05	431	228	0	0	431	228	52.3	50.5	4544	4421	4558	4434	18093	17833
7:05	498	264	0	0	498	264	52.4	53.0	5252	5110	5265	5125	20917	20617
8:05	564	299	0	0	564	299	52.4	52.3	5947	5783	5960	5802	23687	23348
9:05	636	337	0	0	636	337	52.3	51.8	6708	6522	6720	6543	26714	26327
10:05	709	375	0	0	709	375	52.2	51.3	7480	7271	7495	7296	29793	29354
11:05	782	413	0	0	782	413	52.2	51.4	8252	8021	8268	8048	32872	32379
12:05	855	451	0	0	855	451	52.1	51.5	9024	8774	9043	8801	35950	35404
13:05	928	489	0	0	928	489	52.1	52.0	9796	9526	9816	9553	39030	38431
14:05	1000	526	0	0	1000	526	52.0	50.7	10568	10279	10589	10305	42113	41460
15:05	1072	564	0	0	1072	564	52.0	51.7	11341	11030	11363	11058	45192	44485
16:05	1145	602	0	0	1145	602	52.0	51.6	12113	11783	12136	11810	48272	47513
17:05	1218	640	0	0	1218	640	51.9	51.5	12885	12536	12910	12562	51349	50542
18:05	1285	675	0	0	1285	675	51.9	51.6	13593	13228	13619	13251	54172	53321
19:05	1350	709	0	0	1350	709	51.9	51.9	14276	13895	14302	13917	56892	55999
20:05	1422	746	0	0	1422	746	51.8	50.6	15037	14636	15063	14660	59920	58979
21:05	1496	785	0	0	1496	785	51.8	51.9	15811	15386	15839	15415	62998	62009
22:05	1571	824	0	0	1571	824	51.8	51.6	16585	16139	16614	16170	66074	65038
23:05	1646	863	0	0	1646	863	51.8	51.5	17357	16893	17386	16922	69148	68066
0:04	1720	902	0	0	1720	902	51.8	51.9	18131	17646	18159	17676	72225	71097

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	57.6899986	33	0	0	57.6899986	33	56.5	56.5	842	817	0	817	2487	2451
2:05	115	66	0	0	115	66	56.7	56.9	1684	1635	0	1636	4975	4902
3:05	172	99	0	0	172	99	56.8	56.9	2524	2452	0	2455	7459	7351
4:05	233	133	0	0	233	133	56.3	55.1	3421	3323	0	3325	10107	9962
5:05	278	159	0	0	278	159	56.5	57.1	4079	3961	0	3965	12054	11882
6:05	331	189	0	0	331	189	56.4	56.3	4849	4712	0	4713	14333	14129
7:05	388	221	0	0	388	221	56.3	55.7	5688	5527	0	5529	16814	16575
8:05	444	253	0	0	444	253	56.3	56.0	6529	6343	0	6347	19299	19025
9:05	500	285	0	0	500	285	56.3	56.2	7370	7159	0	7165	21785	21468
10:05	556	317	0	0	556	317	56.3	56.7	8212	7976	0	7983	24274	23909
11:05	604	345	0	0	604	345	56.4	57.3	9025	8766	0	8465	26376	25967
12:05	653	373	0	0	653	373	56.4	56.5	9783	9502	0	9180	28594	28140
13:05	708	404	0	0	708	404	56.4	56.5	10624	10319	0	9972	31057	30552
14:05	770	440	0	0	770	440	56.5	57.2	11464	11135	284	10768	33808	33247
15:05	843	482	0	0	843	482	56.5	56.4	12306	11953	1124	11585	37144	36512
16:05	917	523	0	0	917	523	56.4	55.0	13139	12762	1955	12392	40451	39748
17:05	988	563	0	0	988	563	56.3	55.6	13931	13532	2748	13164	43605	42837
18:05	1058	602	0	0	1058	602	56.2	55.3	14697	14277	3513	13911	46651	45821
19:05	1123	638	0	0	1123	638	56.1	54.4	15411	14972	4227	14606	49489	48602
20:05	1196	678	0	0	1196	678	56.0	54.2	16206	15742	5019	15378	52642	51693
21:05	1270	718	0	0	1270	718	55.9	53.7	17001	16513	5812	16151	55795	54786
22:05	1344	759	0	0	1344	759	55.8	54.9	17795	17284	6604	16924	58946	57876
23:05	1418	800	0	0	1418	800	55.7	54.4	18589	18054	7396	17696	62095	60964
0:04	1492.84399	841	0	0	1492.84399	841	55.7	54.3	19384	18827	8189	18469	65251	64058

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	74.5370026	40	0	0	74.5370026	40	53.0	53.0	794	773	792	773	3154	3092
2:05	149	80	0	0	149	80	53.1	53.1	1586	1544	1585	1545	6303	6180
3:05	224	121	0	0	224	121	53.5	54.3	2380	2316	2378	2316	9452	9268
4:05	298	162	0	0	298	162	53.7	54.3	3173	3086	3171	3088	12602	12357
5:05	373	202	0	0	373	202	53.5	52.9	3965	3858	3963	3860	15750	15444
6:05	445	241	0	0	445	241	53.5	53.2	4733	4603	4728	4606	18795	18428
7:05	513	277	0	0	513	277	53.4	52.6	5448	5296	5440	5299	21630	21205
8:05	587	317	0	0	587	317	53.4	53.5	6230	6052	6221	6059	24731	24241
9:05	662	357	0	0	662	357	53.3	52.7	7025	6824	7016	6832	27883	27323
10:05	737	397	0	0	737	397	53.2	52.6	7821	7596	7810	7604	31044	30411
11:05	812	437	0	0	812	437	53.2	52.8	8616	8369	8603	8375	34198	33493
12:05	887	477	0	0	887	477	53.1	52.6	9409	9142	9399	9146	37358	36580
13:05	963	517	0	0	963	517	53.1	52.3	10203	9914	10192	9917	40511	39661
14:05	1037	557	0	0	1037	557	53.1	53.1	10990	10677	10978	10680	43634	42712
15:05	1112	596	0	0	1112	596	53.0	51.8	11775	11439	11762	11441	46751	45757
16:05	1185	635	0	0	1185	635	52.9	52.3	12560	12199	12547	12204	49870	48803
17:05	1258	674	0	0	1258	674	52.9	52.7	13345	12961	13332	12966	52989	51851
18:05	1325	709	0	0	1325	709	52.9	51.6	14066	13659	14051	13664	55847	54644
19:05	1390	743	0	0	1390	743	52.8	51.7	14759	14332	14745	14336	58599	57334
20:05	1462	781	0	0	1462	781	52.8	52.3	15519	15068	15503	15071	61614	60281
21:05	1537	821	0	0	1537	821	52.8	52.5	16305	15828	16288	15832	64730	63327
22:05	1613	861	0	0	1613	861	52.7	52.1	17088	16589	17071	16594	67844	66373
23:05	1690	902	0	0	1690	902	52.8	53.1	17873	17351	17855	17354	70959	69420
0:04	1766.00598	943	0	0	1766.00598	943	52.8	53.0	18658	18111	18638	18116	74073	72467

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	76.788002	41	0	0	76.788002	41	52.8	52.8	783	761	783	764	3114	3047
2:05	154	82	0	0	154	82	52.7	52.7	1566	1522	1565	1526	6225	6092
3:05	231	123	0	0	231	123	52.6	52.5	2351	2285	2348	2288	9336	9137
4:05	308	163	0	0	308	163	52.3	51.4	3135	3046	3132	3049	12446	12181
5:05	385	203	0	0	385	203	52.1	51.4	3918	3805	3916	3811	15558	15227
6:05	462	243	0	0	462	243	52.0	51.4	4703	4565	4700	4572	18670	18274
7:05	532	280	0	0	532	280	52.0	51.7	5420	5261	5417	5270	21520	21065
8:05	607	319	0	0	607	319	51.9	51.5	6177	5997	6175	6007	24529	24011
9:05	684	359	0	0	684	359	51.8	51.2	6961	6755	6956	6767	27631	27045
10:05	759	398	0	0	759	398	51.8	51.6	7727	7498	7720	7509	30667	30009
11:05	833	436	0	0	833	436	51.7	50.9	8492	8242	8485	8251	33703	32972
12:05	906	474	0	0	906	474	51.7	51.3	9259	8985	9252	8996	36747	35943
13:05	979	512	0	0	979	512	51.7	51.3	10028	9733	10022	9743	39800	38923
14:05	1052	550	0	0	1052	550	51.7	51.5	10797	10480	10793	10490	42856	41906
15:05	1125	588	0	0	1125	588	51.6	51.4	11570	11230	11567	11240	45926	44903
16:05	1199	627	0	0	1199	627	51.7	51.8	12345	11981	12343	11993	49002	47908
17:05	1275	666	0	0	1275	666	51.6	51.2	13118	12732	13116	12745	52078	50915
18:05	1349	705	0	0	1349	705	51.6	51.8	13881	13471	13877	13484	55101	53871
19:05	1416	740	0	0	1416	740	51.6	51.6	14566	14136	14560	14148	57816	56526
20:05	1490	778	0	0	1490	778	51.6	51.1	15315	14863	15307	14876	60788	59432
21:05	1566	818	0	0	1566	818	51.6	51.7	16090	15614	16082	15629	63860	62435
22:05	1643	858	0	0	1643	858	51.6	51.5	16862	16365	16854	16382	66928	65435
23:05	1720	898	0	0	1720	898	51.6	51.2	17634	17114	17627	17134	69999	68438
0:04	1796.75403	938	0	0	1796.75403	938	51.6	51.4	18408	17866	18401	17887	73071	71443

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	77.1849976	40	0	0	77.1849976	40	51.2	51.2	774	742	774	754	3066	2999
2:05	153	80	0	0	153	80	51.6	52.0	1547	1435	1548	1508	6082	5949
3:05	229	119	0	0	229	119	51.4	51.0	2324	2127	2322	2260	9094	8897
4:05	304	158	0	0	304	158	51.4	51.3	3098	2819	3094	3012	12105	11845
5:05	379	197	0	0	379	197	51.3	51.2	3872	3511	3868	3764	15116	14793
6:05	445	231	0	0	445	231	51.3	51.2	4543	4110	4537	4416	17728	17350
7:05	520	270	0	0	520	270	51.3	51.0	5316	4803	5311	5168	20737	20297
8:05	596	309	0	0	596	309	51.2	51.1	6089	5495	6083	5918	23750	23247
9:05	671	348	0	0	671	348	51.2	51.1	6857	6206	6849	6664	26769	26202
10:05	747	387	0	0	747	387	51.2	51.0	7615	6943	7605	7399	29780	29145
11:05	822	426	0	0	822	426	51.2	51.2	8371	7678	8360	8133	32791	32088
12:05	897	465	0	0	897	465	51.2	51.5	9128	8414	9116	8868	35803	35029
13:05	971	504	0	0	971	504	51.3	51.8	9887	9151	9874	9605	38820	37973
14:05	1046	543	0	0	1046	543	51.3	51.7	10649	9892	10637	10346	41853	40933
15:05	1120	582	0	0	1120	582	51.3	51.7	11415	10635	11403	11090	44899	43906
16:05	1194	620	0	0	1194	620	51.3	50.6	12182	11381	12171	11835	47955	46890
17:05	1263	655	0	0	1263	655	51.3	50.7	12886	12063	12875	12519	50758	49627
18:05	1332	691	0	0	1332	691	51.3	51.1	13603	12759	13592	13214	53611	52415
19:05	1407	730	0	0	1407	730	51.3	51.4	14370	13505	14360	13960	56667	55400
20:05	1483	769	0	0	1483	769	51.2	51.0	15138	14251	15127	14706	59722	58387
21:05	1559	809	0	0	1559	809	51.3	51.8	15907	14998	15895	15454	62776	61373
22:05	1636	849	0	0	1636	849	51.3	51.6	16676	15744	16663	16202	65829	64358
23:05	1713	889	0	0	1713	889	51.3	51.3	17442	16490	17428	16949	68882	67345
0:04	1790.22803	929	0	0	1790.22803	929	51.3	51.0	18211	17238	18196	17697	71935	70332

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	77.6640015	40	0	0	77.6640015	40	50.9	50.9	771	748	767	749	3056	2990
2:05	155	80	0	0	155	80	50.9	50.9	1541	1496	1535	1498	6113	5981
3:05	233	120	0	0	233	120	50.9	50.9	2309	2243	2303	2244	9166	8968
4:05	311	160	0	0	311	160	50.9	50.9	3078	2989	3072	2992	12218	11954
5:05	383	198	0	0	383	198	51.0	51.7	3796	3686	3788	3689	15070	14744
6:05	456	236	0	0	456	236	51.2	51.8	4515	4383	4504	4387	17921	17533
7:05	533	276	0	0	533	276	51.2	51.2	5283	5128	5272	5134	20973	20519
8:05	610	315	0	0	610	315	51.0	49.9	6051	5873	6037	5880	24026	23506
9:05	687	354	0	0	687	354	50.9	50.5	6812	6612	6796	6618	27048	26459
10:05	762	393	0	0	762	393	51.0	51.4	7565	7342	7549	7349	30041	29381
11:05	836	431	0	0	836	431	51.0	50.6	8317	8072	8301	8079	33033	32302
12:05	910	470	0	0	910	470	51.0	51.8	9069	8802	9053	8809	36026	35224
13:05	985	505	0	0	985	505	50.7	46.5	9823	9532	9803	9539	39016	38144
14:05	1059	544	0	0	1059	544	50.8	51.7	10575	10262	10555	10269	42007	41066
15:05	1133	583	0	0	1133	583	50.8	51.8	11328	10994	11307	10999	45002	43994
16:05	1208	622	0	0	1208	622	50.9	51.8	12081	11726	12057	11731	47997	46924
17:05	1274	657	0	0	1274	657	50.9	51.9	12758	12383	12733	12390	50693	49563
18:05	1346	695	0	0	1346	695	51.0	52.5	13487	13089	13459	13099	53585	52394
19:05	1418	733	0	0	1418	733	51.1	52.0	14227	13808	14197	13819	56524	55273
20:05	1492	772	0	0	1492	772	51.1	52.5	14980	14538	14949	14550	59516	58205
21:05	1565	811	0	0	1565	811	51.2	52.5	15732	15268	15700	15283	62505	61133
22:05	1639	850	0	0	1639	850	51.3	52.3	16485	16001	16452	16017	65497	64065
23:05	1712	889	0	0	1712	889	51.3	52.5	17238	16732	17203	16749	68488	66996
0:04	1785.64404	928	0	0	1785.64404	928	51.4	52.5	17994	17467	17957	17482	71481	69930

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	73.7399979	39	0	0	73.7399979	39	52.3	52.3	755	733	754	733	2997	2937
2:05	147	79	0	0	147	79	52.9	53.6	1510	1466	1507	1465	5993	5873
3:05	221	119	0	0	221	119	53.2	53.8	2263	2198	2259	2198	8987	8807
4:05	290	156	0	0	290	156	53.1	52.9	2977	2895	2972	2895	11833	11596
5:05	357	192	0	0	357	192	53.2	53.3	3669	3566	3660	3567	14582	14290
6:05	430	232	0	0	430	232	53.3	53.9	4422	4297	4411	4300	17575	17224
7:05	503	272	0	0	503	272	53.4	54.0	5155	5009	5164	5033	20527	20115
8:05	575	311	0	0	575	311	53.5	53.9	5870	5703	5918	5767	23444	22974
9:05	647	350	0	0	647	350	53.5	53.6	6581	6394	6671	6499	26358	25830
10:05	718	389	0	0	718	389	53.5	53.9	7294	7087	7424	7231	29271	28684
11:05	790	428	0	0	790	428	53.6	54.0	8006	7780	8177	7964	32184	31537
12:05	860	466	0	0	860	466	53.5	53.0	8720	8472	8929	8697	35099	34391
13:05	931	504	0	0	931	504	53.5	53.3	9434	9165	9681	9429	38014	37245
14:05	1001	542	0	0	1001	542	53.5	53.6	10146	9856	10434	10161	40927	40096
15:05	1071	580	0	0	1071	580	53.5	53.9	10859	10548	11185	10893	43842	42947
16:05	1139	617	0	0	1139	617	53.5	53.8	11561	11228	11925	11613	46709	45751
17:05	1202	651	0	0	1202	651	53.5	52.7	12227	11874	12628	12296	49429	48410
18:05	1264	685	0	0	1264	685	53.5	54.3	12867	12498	13305	12955	52052	50975
19:05	1332	722	0	0	1332	722	53.6	53.8	13569	13179	14047	13675	54916	53778
20:05	1402	760	0	0	1402	760	53.6	53.9	14283	13872	14802	14407	57828	56628
21:05	1472	798	0	0	1472	798	53.6	53.5	14996	14565	15554	15139	60741	59479
22:05	1543	836	0	0	1543	836	53.5	53.3	15709	15258	16308	15871	63652	62329
23:05	1614	874	0	0	1614	874	53.5	52.6	16421	15949	17061	16604	66563	65180
0:04	1684.91199	912	0	0	1684.91199	912	53.5	53.0	17132	16641	17812	17336	69476	68034

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	70.5670013	38	0	0	70.5670013	38	53.2	53.2	714	692	750	732	2912	2853
2:05	141	76	0	0	141	76	53.3	53.3	1426	1386	1502	1466	5825	5707
3:05	212	114	0	0	212	114	53.2	53.1	2135	2076	2255	2199	8733	8555
4:05	282	152	0	0	282	152	53.3	53.6	2847	2769	3010	2932	11649	11411
5:05	352	190	0	0	352	190	53.4	53.7	3560	3462	3761	3666	14562	14264
6:05	424	229	0	0	424	229	53.4	53.6	4282	4166	4525	4411	17523	17165
7:05	489	264	0	0	489	264	53.4	53.2	4938	4800	5216	5083	20193	19781
8:05	557	301	0	0	557	301	53.4	53.2	5638	5481	5955	5803	23056	22584
9:05	626	338	0	0	626	338	53.3	52.9	6350	6172	6706	6533	25971	25434
10:05	694	375	0	0	694	375	53.4	54.0	7063	6863	7457	7266	28885	28283
11:05	762	411	0	0	762	411	53.3	52.6	7774	7556	8212	7999	31801	31134
12:05	829	447	0	0	829	447	53.3	53.2	8487	8249	8968	8731	34719	33987
13:05	895	483	0	0	895	483	53.3	53.5	9198	8940	9722	9461	37636	36838
14:05	962	519	0	0	962	519	53.3	53.5	9911	9632	10477	10191	40553	39689
15:05	1028	555	0	0	1028	555	53.4	53.6	10626	10324	11233	10923	43473	42543
16:05	1094	592	0	0	1094	592	53.5	55.0	11338	11017	11988	11655	46389	45392
17:05	1161	629	0	0	1161	629	53.5	54.5	12050	11710	12744	12386	49304	48241
18:05	1229	666	0	0	1229	666	53.5	54.0	12764	12403	13500	13118	52219	51091
19:05	1296	703	0	0	1296	703	53.6	54.4	13477	13097	14254	13849	55135	53942
20:05	1365	741	0	0	1365	741	53.6	54.8	14191	13790	15010	14581	58053	56795
21:05	1429	776	0	0	1429	776	53.7	54.3	14855	14438	15714	15264	60776	59458
22:05	1491	810	0	0	1491	810	53.7	54.2	15483	15051	16380	15910	63352	61976
23:05	1560	848	0	0	1560	848	53.7	53.8	16195	15744	17136	16642	66270	64830
0:04	1629.75806	886	0	0	1629.75806	886	53.7	54.1	16908	16435	17888	17374	69185	67682

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
							Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		%	%	Hours	Hours	Hours	Hours	kW	kW
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU								
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	69.5	38	0	0	69.5	38	54.0	54.0	712	694	752	731	2915	2853
2:05	139	76	0	0	139	76	54.0	53.9	1423	1386	1507	1462	5829	5705
3:05	209	115	0	0	209	115	54.3	54.9	2137	2078	2261	2195	8747	8561
4:05	279	153	0	0	279	153	54.2	54.1	2849	2771	3015	2927	11659	11413
5:05	348	191	0	0	348	191	54.2	53.9	3560	3463	3768	3660	14572	14266
6:05	420	230	0	0	420	230	54.1	54.0	4270	4156	4521	4392	17482	17115
7:05	489	268	0	0	489	268	54.1	54.0	4983	4848	5273	5123	20391	19965
8:05	559	305	0	0	559	305	53.9	52.6	5695	5540	6026	5855	23303	22818
9:05	630	344	0	0	630	344	54.0	54.2	6434	6252	6766	6576	26241	25689
10:05	699	382	0	0	699	382	54.0	54.0	7176	6958	7508	7297	29179	28561
11:05	764	417	0	0	764	417	53.9	53.5	7863	7606	8195	7958	31881	31200
12:05	836	456	0	0	836	456	53.9	53.4	8626	8313	8960	8692	34877	34125
13:05	905	493	0	0	905	493	53.8	53.3	9366	8993	9700	9400	37772	36951
14:05	975	531	0	0	975	531	53.8	53.6	10119	9709	10454	10128	40750	39857
15:05	1045	569	0	0	1045	569	53.8	53.7	10872	10418	11206	10859	43718	42754
16:05	1115	607	0	0	1115	607	53.8	53.8	11619	11143	11954	11586	46689	45655
17:05	1184	645	0	0	1184	645	53.8	53.7	12362	11867	12700	12311	49656	48555
18:05	1255	683	0	0	1255	683	53.8	53.6	13091	12576	13449	13037	52591	51424
19:05	1323	720	0	0	1323	720	53.8	53.1	13802	13267	14196	13764	55493	54261
20:05	1393	757	0	0	1393	757	53.7	52.8	14512	13958	14943	14491	58394	57098
21:05	1462	794	0	0	1462	794	53.7	52.7	15224	14651	15691	15219	61297	59938
22:05	1532	832	0	0	1532	832	53.7	53.6	15935	15342	16439	15947	64199	62778
23:05	1603	870	0	0	1603	870	53.6	53.0	16645	16033	17185	16672	67099	65616
0:04	1663.25598	903	0	0	1663.25598	903	53.6	54.0	17250	16622	17820	17289	69566	68030

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	68.110006	37	0	0	68.110006	37	53.7	53.7	688	669	722	704	2804	2746
2:05	138	75	0	0	138	75	53.5	53.4	1400	1361	1470	1431	5703	5587
3:05	209	113	0	0	209	113	53.5	53.5	2114	2053	2217	2159	8603	8429
4:05	279	151	0	0	279	151	53.4	53.2	2826	2744	2965	2886	11501	11269
5:05	350	190	0	0	350	190	53.6	54.2	3539	3436	3713	3614	14406	14114
6:05	420	228	0	0	420	228	53.6	53.7	4250	4127	4460	4342	17307	16957
7:05	490	266	0	0	490	266	53.7	53.9	4962	4817	5207	5069	20208	19799
8:05	559	304	0	0	559	304	53.7	54.1	5674	5508	5954	5795	23107	22639
9:05	628	341	0	0	628	341	53.6	53.2	6389	6191	6687	6508	25978	25447
10:05	690	375	0	0	690	375	53.7	54.3	7037	6821	7335	7136	28553	27965
11:05	750	407	0	0	750	407	53.6	52.7	7666	7430	7956	7740	31039	30396
12:05	822	446	0	0	822	446	53.6	53.3	8417	8161	8702	8465	34021	33313
13:05	895	485	0	0	895	485	53.6	53.2	9168	8891	9450	9194	37008	36234
14:05	967	524	0	0	967	524	53.5	53.0	9921	9626	10202	9928	40008	39168
15:05	1040	563	0	0	1040	563	53.5	53.2	10667	10354	10951	10657	42992	42088
16:05	1112	602	0	0	1112	602	53.5	53.6	11411	11075	11697	11378	45952	44987
17:05	1183	641	0	0	1183	641	53.5	53.7	12158	11795	12443	12100	48913	47887
18:05	1255	680	0	0	1255	680	53.5	53.9	12906	12515	13189	12822	51876	50789
19:05	1323	717	0	0	1323	717	53.5	53.6	13611	13200	13898	13507	54687	53542
20:05	1384	750	0	0	1384	750	53.5	53.4	14246	13811	14532	14120	57204	56007
21:05	1455	788	0	0	1455	788	53.5	53.4	14981	14522	15268	14831	60117	58860
22:05	1526	827	0	0	1526	827	53.5	53.5	15729	15243	16012	15553	63080	61761
23:05	1598	866	0	0	1598	866	53.5	53.7	16476	15964	16758	16273	66042	64662
0:04	1669.88098	905	0	0	1669.88098	905	53.6	53.8	17223	16688	17504	16995	69006	67565

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	71.8119965	39	0	0	71.8119965	39	53.7	53.7	747	722	747	722	2962	2902
2:05	144	78	0	0	144	78	53.6	53.6	1494	1444	1494	1445	5922	5802
3:05	216	117	0	0	216	117	53.6	53.6	2242	2167	2239	2167	8885	8704
4:05	287	156	0	0	287	156	53.7	53.8	2990	2888	2985	2889	11845	11603
5:05	359	195	0	0	359	195	53.7	53.7	3736	3611	3732	3610	14806	14504
6:05	431	234	0	0	431	234	53.7	53.8	4484	4332	4479	4333	17769	17408
7:05	502	273	0	0	502	273	53.7	53.9	5233	5054	5225	5055	20733	20312
8:05	571	310	0	0	571	310	53.6	52.9	5955	5753	5945	5753	23597	23117
9:05	640	347	0	0	640	347	53.6	53.7	6665	6441	6657	6442	26421	25881
10:05	712	386	0	0	712	386	53.6	53.3	7421	7172	7408	7172	29412	28805
11:05	783	424	0	0	783	424	53.5	52.7	8156	7888	8144	7886	32332	31660
12:05	856	463	0	0	856	463	53.5	53.1	8907	8620	8896	8617	35325	34585
13:05	928	502	0	0	928	502	53.5	53.3	9658	9351	9654	9352	38330	37521
14:05	1001	541	0	0	1001	541	53.4	53.0	10411	10082	10411	10087	41335	40457
15:05	1073	580	0	0	1073	580	53.4	53.1	11161	10812	11167	10821	44337	43390
16:05	1145	619	0	0	1145	619	53.4	53.5	11915	11547	11924	11557	47348	46334
17:05	1214	656	0	0	1214	656	53.4	53.2	12634	12245	12641	12256	50210	49134
18:05	1277	690	0	0	1277	690	53.4	53.6	13290	12883	13299	12894	52820	51687
19:05	1346	727	0	0	1346	727	53.4	52.9	14010	13581	14018	13593	55680	54485
20:05	1419	767	0	0	1419	767	53.4	54.0	14770	14317	14775	14331	58693	57432
21:05	1492	807	0	0	1492	807	53.4	53.8	15529	15053	15534	15069	61705	60379
22:05	1566	847	0	0	1566	847	53.4	53.5	16286	15789	16291	15805	64717	63325
23:05	1640	887	0	0	1640	887	53.4	53.4	17043	16526	17047	16540	67729	66271
0:04	1714.40503	927	0	0	1714.40503	927	53.4	53.4	17801	17263	17804	17277	70741	69217

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	74.0370026	40	0	0	74.0370026	40	53.4	53.4	758	738	757	737	3012	2946
2:05	148	80	0	0	148	80	53.4	53.3	1515	1476	1514	1474	6025	5893
3:05	222	120	0	0	222	120	53.3	53.2	2273	2212	2270	2211	9035	8838
4:05	297	160	0	0	297	160	53.3	53.3	3030	2949	3026	2948	12045	11783
5:05	365	197	0	0	365	197	53.3	53.6	3723	3623	3720	3623	14805	14483
6:05	432	232	0	0	432	232	53.1	51.9	4406	4286	4401	4285	17513	17134
7:05	504	271	0	0	504	271	53.1	53.0	5151	5009	5145	5008	20472	20030
8:05	578	310	0	0	578	310	53.0	52.2	5909	5744	5902	5744	23483	22976
9:05	650	348	0	0	650	348	52.9	52.4	6643	6456	6633	6456	26396	25823
10:05	722	387	0	0	722	387	52.9	53.1	7389	7181	7377	7178	29359	28719
11:05	793	425	0	0	793	425	52.9	52.8	8120	7891	8108	7888	32269	31563
12:05	867	461	0	0	867	461	52.5	48.4	8878	8626	8864	8625	35282	34506
13:05	940	500	0	0	940	500	52.5	52.5	9635	9360	9620	9360	38294	37447
14:05	1014	539	0	0	1014	539	52.6	52.7	10393	10096	10377	10095	41308	40389
15:05	1086	578	0	0	1086	578	52.6	52.8	11151	10832	11134	10829	44318	43327
16:05	1159	617	0	0	1159	617	52.6	52.9	11909	11569	11891	11564	47333	46272
17:05	1226	653	0	0	1226	653	52.6	53.2	12604	12240	12584	12238	50096	48974
18:05	1291	688	0	0	1291	688	52.7	53.6	13272	12890	13253	12888	52757	51576
19:05	1363	727	0	0	1363	727	52.7	53.6	14016	13613	13998	13611	55719	54473
20:05	1436	767	0	0	1436	767	52.8	53.8	14776	14349	14753	14348	58731	57419
21:05	1510	807	0	0	1510	807	52.8	53.7	15535	15085	15512	15086	61745	60367
22:05	1583	847	0	0	1583	847	52.9	53.6	16292	15820	16269	15823	64754	63311
23:05	1657	887	0	0	1657	887	52.9	53.6	17050	16556	17025	16558	67766	66258
0:04	1730.52698	927	0	0	1730.52698	927	52.9	53.7	17808	17293	17782	17295	70780	69207

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	73.2440033	40	0	0	73.2440033	40	54.0	54.0	756	735	757	736	3012	2948
2:05	147	81	0	0	147	81	54.4	54.9	1514	1472	1515	1472	6028	5899
3:05	221	121	0	0	221	121	54.2	53.7	2272	2209	2272	2208	9038	8846
4:05	294	161	0	0	294	161	54.1	53.9	3029	2944	3030	2943	12049	11793
5:05	367	201	0	0	367	201	54.1	54.2	3787	3681	3786	3679	15062	14741
6:05	439	241	0	0	439	241	54.2	54.5	4543	4418	4545	4416	18073	17687
7:05	512	281	0	0	512	281	54.2	54.5	5301	5154	5302	5150	21082	20631
8:05	577	316	0	0	577	316	54.2	53.5	5981	5816	5982	5811	23791	23281
9:05	645	354	0	0	645	354	54.2	54.9	6702	6517	6706	6513	26669	26095
10:05	706	388	0	0	706	388	54.3	54.9	7517	7308	7517	6633	29227	28596
11:05	766	422	0	0	766	422	54.4	55.8	8357	8122	8353	6636	31742	31058
12:05	840	463	0	0	840	463	54.4	54.7	9164	8901	9157	7381	34902	34149
13:05	915	504	0	0	915	504	54.4	54.5	9968	9682	9961	8162	38099	37274
14:05	988	545	0	0	988	545	54.5	55.0	10773	10384	10766	8943	41218	40323
15:05	1061	585	0	0	1061	585	54.5	54.5	11563	11107	11555	9711	44319	43357
16:05	1133	625	0	0	1133	625	54.5	54.7	12340	11863	12334	10467	47413	46386
17:05	1204	664	0	0	1204	664	54.5	54.1	13107	12606	13102	11211	50458	49367
18:05	1280	705	0	0	1280	705	54.4	53.8	13911	13388	13907	11993	53659	52500
19:05	1343	740	0	0	1343	740	54.5	54.9	14544	14008	14596	12662	56292	55076
20:05	1413	779	0	0	1413	779	54.5	54.7	15256	14699	15375	13419	59257	57978
21:05	1482	817	0	0	1482	817	54.5	54.5	15955	15379	16143	14164	62174	60833
22:05	1552	856	0	0	1552	856	54.5	54.7	16668	16072	16923	14922	65138	63734
23:05	1623	895	0	0	1623	895	54.5	54.6	17382	16764	17701	15679	68104	66638
0:04	1693.77698	934	0	0	1693.77698	934	54.5	54.5	18093	17454	18479	16434	71069	69542



CommonWealth

New Bedford Energy LLC

Hourly Report

Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
	0:05	0	0	0	0	0	0			0	0	0	0	0
1:05	70.8769989	39	0	0	70.8769989	39	54.4	54.4	708	690	779	755	2959	2900
2:05	142	78	0	0	142	78	54.5	54.6	1419	1381	1559	1511	5920	5802
3:05	212	117	0	0	212	117	54.4	54.4	2130	2072	2339	2267	8881	8705
4:05	283	156	0	0	283	156	54.4	54.3	2843	2763	3118	3023	11843	11609
5:05	354	195	0	0	354	195	54.4	54.2	3557	3455	3897	3779	14805	14513
6:05	426	234	0	0	426	234	54.3	54.0	4270	4146	4676	4536	17766	17416
7:05	495	272	0	0	495	272	54.3	54.2	4942	4804	5416	5254	20578	20171
8:05	555	305	0	0	555	305	54.3	54.2	5533	5380	6064	5883	23047	22590
9:05	622	342	0	0	622	342	54.3	54.5	6209	6037	6803	6601	25864	25348
10:05	692	380	0	0	692	380	54.2	53.8	6933	6743	7560	7335	28809	28231
11:05	763	418	0	0	763	418	54.1	53.1	7694	7436	8324	8077	31798	31155
12:05	833	456	0	0	833	456	54.1	53.9	8460	8129	9091	8820	34786	34078
13:05	902	494	0	0	902	494	54.1	54.1	9223	8821	9856	9563	37772	36999
14:05	971	532	0	0	971	532	54.1	54.4	9986	9512	10621	10305	40759	39921
15:05	1040	570	0	0	1040	570	54.1	54.3	10750	10205	11387	11047	43746	42843
16:05	1109	608	0	0	1109	608	54.2	54.3	11513	10897	12151	11789	46734	45766
17:05	1179	646	0	0	1179	646	54.1	53.7	12275	11590	12916	12531	49719	48686
18:05	1250	685	0	0	1250	685	54.2	54.8	13041	12283	13682	13273	52707	51609
19:05	1321	724	0	0	1321	724	54.2	54.2	13801	12975	14446	14016	55691	54529
20:05	1393	764	0	0	1393	764	54.2	54.8	14565	13668	15210	14758	58678	57451
21:05	1463	803	0	0	1463	803	54.2	55.0	15315	14348	15961	15487	61614	60326
22:05	1522	835	0	0	1522	835	54.2	53.8	15940	14914	16584	16092	64050	62710
23:05	1594	875	0	0	1594	875	54.2	54.6	16704	15605	17349	16833	67037	65635
0:04	1666.328	915	0	0	1666.328	915	54.3	54.8	17465	16295	18114	17574	70020	68557

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.0699997	40	0	0	72.0699997	40	54.8	54.8	763	691	764	740	2985	2926
2:05	144	80	0	0	144	80	54.8	54.7	1525	1382	1527	1481	5968	5850
3:05	218	121	0	0	218	121	54.8	54.8	2284	2071	2290	2223	8943	8764
4:05	290	161	0	0	290	161	54.8	55.0	3047	2760	3052	2964	11922	11686
5:05	362	200	0	0	362	200	54.6	53.7	3808	3449	3812	3704	14900	14606
6:05	434	239	0	0	434	239	54.4	53.6	4570	4138	4573	4444	17881	17529
7:05	505	278	0	0	505	278	54.4	53.9	5332	4828	5333	5186	20861	20453
8:05	577	318	0	0	577	318	54.4	54.9	6093	5519	6094	5928	23839	23374
9:05	650	357	0	0	650	357	54.3	53.1	6857	6211	6858	6670	26818	26294
10:05	717	394	0	0	717	394	54.3	54.4	7569	6855	7571	7361	29597	29019
11:05	786	432	0	0	786	432	54.3	54.5	8307	7523	8307	8077	32482	31847
12:05	857	471	0	0	857	471	54.3	54.2	9070	8215	9069	8819	35463	34767
13:05	928	510	0	0	928	510	54.3	54.3	9832	8908	9834	9561	38448	37690
14:05	999	549	0	0	999	549	54.3	54.7	10595	9598	10598	10303	41433	40612
15:05	1069	588	0	0	1069	588	54.4	54.9	11358	10287	11362	11044	44419	43534
16:05	1139	626	0	0	1139	626	54.3	53.6	12121	10979	12126	11785	47401	46452
17:05	1209	665	0	0	1209	665	54.4	55.0	12884	11668	12888	12526	50389	49377
18:05	1279	704	0	0	1279	704	54.4	54.8	13647	12359	13651	13269	53375	52301
19:05	1350	743	0	0	1350	743	54.4	54.5	14409	13050	14415	14011	56358	55222
20:05	1422	783	0	0	1422	783	54.4	54.7	15172	13742	15177	14753	59344	58145
21:05	1494	822	0	0	1494	822	54.4	54.0	15934	14434	15941	15493	62326	61068
22:05	1566	862	0	0	1566	862	54.4	54.8	16693	15127	16704	16235	65309	63991
23:05	1632	898	0	0	1632	898	54.4	53.6	17381	15751	17390	16902	67996	66625
0:04	1702.01794	937	0	0	1702.01794	937	54.4	55.0	18120	16421	18128	17618	70880	69453

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.473999	40	0	0	72.473999	40	54.5	54.5	761	691	765	742	2986	2928
2:05	145	80	0	0	145	80	54.6	54.6	1524	1384	1528	1485	5969	5854
3:05	217	120	0	0	217	120	54.6	54.6	2287	2076	2291	2227	8952	8780
4:05	289	160	0	0	289	160	54.6	54.8	3049	2767	3053	2967	11934	11705
5:05	363	200	0	0	363	200	54.5	53.8	3812	3460	3815	3709	14918	14630
6:05	435	240	0	0	435	240	54.5	54.4	4575	4154	4578	4451	17903	17558
7:05	508	280	0	0	508	280	54.5	54.7	5339	4847	5341	5193	20886	20484
8:05	580	319	0	0	580	319	54.4	53.5	6103	5541	6104	5935	23871	23411
9:05	652	358	0	0	652	358	54.3	53.5	6855	6257	6863	6673	26858	26336
10:05	723	397	0	0	723	397	54.3	54.2	7607	6985	7612	7401	29839	29255
11:05	788	433	0	0	788	433	54.3	54.3	8284	7645	8286	8058	32534	31892
12:05	846	464	0	0	846	464	54.2	53.2	8876	8220	8877	8634	34892	34199
13:05	906	497	0	0	906	497	54.2	54.1	9518	8843	9518	9257	37443	36696
14:05	968	531	0	0	968	531	54.2	54.4	10191	9494	10190	9910	40112	39308
15:05	1040	570	0	0	1040	570	54.2	53.7	10964	10225	10964	10661	43163	42293
16:05	1110	608	0	0	1110	608	54.1	53.0	11719	10957	11718	11393	46158	45224
17:05	1184	648	0	0	1184	648	54.1	53.8	12489	11704	12487	12140	49216	48217
18:05	1258	688	0	0	1258	688	54.1	53.7	13258	12451	13257	12887	52272	51208
19:05	1332	728	0	0	1332	728	54.0	53.5	14028	13192	14027	13635	55317	54189
20:05	1405	767	0	0	1405	767	54.0	52.7	14800	13885	14797	14385	58320	57131
21:05	1477	806	0	0	1477	806	53.9	53.3	15557	14568	15555	15120	61267	60019
22:05	1549	845	0	0	1549	845	53.9	53.3	16313	15250	16311	15856	64215	62908
23:05	1612	879	0	0	1612	879	53.9	53.2	16965	15837	16963	16491	66768	65409
0:04	1683.771	917	0	0	1683.771	917	53.8	52.5	17707	16507	17707	17213	69664	68248

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	73.7089996	40	0	0	73.7089996	40	53.6	53.6	770	693	769	748	3000	2941
2:05	148	80	0	0	148	80	53.5	53.3	1537	1385	1538	1495	5997	5879
3:05	222	120	0	0	222	120	53.4	53.4	2275	2077	2306	2241	8965	8789
4:05	295	159	0	0	295	159	53.3	53.0	2987	2769	3075	2988	11905	11672
5:05	367	198	0	0	367	198	53.3	53.1	3699	3461	3843	3734	14846	14556
6:05	440	237	0	0	440	237	53.3	53.1	4412	4153	4612	4481	17790	17443
7:05	512	276	0	0	512	276	53.2	53.2	5123	4845	5380	5227	20732	20328
8:05	585	315	0	0	585	315	53.2	53.1	5835	5537	6147	5974	23674	23212
9:05	658	354	0	0	658	354	53.1	52.3	6576	6255	6913	6721	26670	26148
10:05	733	393	0	0	733	393	53.0	51.8	7344	7000	7681	7468	29717	29132
11:05	807	432	0	0	807	432	52.9	52.0	8111	7745	8450	8218	32774	32124
12:05	882	472	0	0	882	472	52.9	53.0	8878	8492	9233	8984	35862	35144
13:05	956	511	0	0	956	511	52.8	51.8	9646	9239	10022	9750	38958	38172
14:05	1030	550	0	0	1030	550	52.8	51.9	10418	9984	10811	10516	42054	41200
15:05	1105	589	0	0	1105	589	52.7	51.8	11186	10731	11600	11282	45150	44227
16:05	1179	628	0	0	1179	628	52.6	51.8	11953	11479	12389	12048	48246	47255
17:05	1254	668	0	0	1254	668	52.6	52.8	12721	12225	13177	12814	51340	50283
18:05	1329	708	0	0	1329	708	52.6	52.7	13489	12970	13966	13581	54435	53312
19:05	1397	744	0	0	1397	744	52.6	52.3	14182	13643	14674	14271	57219	56038
20:05	1462	778	0	0	1462	778	52.6	52.0	14835	14274	15345	14922	59848	58612
21:05	1538	818	0	0	1538	818	52.5	51.6	15604	15021	16134	15689	62943	61643
22:05	1614	858	0	0	1614	858	52.5	52.2	16361	15758	16910	16443	65983	64621
23:05	1691	898	0	0	1691	898	52.5	51.0	17125	16503	17697	17211	69072	67648
0:04	1769.32605	939	0	0	1769.32605	939	52.4	52.0	17893	17251	18485	17978	72170	70684

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	78.2190018	41	0	0	78.2190018	41	51.8	51.8	765	745	786	767	3092	3029
2:05	156	82	0	0	156	82	52.1	52.3	1533	1440	1577	1534	6128	6005
3:05	232	123	0	0	232	123	52.3	52.8	2301	2132	2365	2302	9163	8981
4:05	309	163	0	0	309	163	52.2	51.7	3069	2822	3155	3069	12200	11959
5:05	385	203	0	0	385	203	52.1	51.6	3836	3510	3943	3837	15234	14934
6:05	463	244	0	0	463	244	52.1	52.0	4616	4212	4743	4616	18313	17954
7:05	532	280	0	0	532	280	52.0	51.8	5310	4835	5452	5307	21050	20638
8:05	606	319	0	0	606	319	52.0	51.8	6068	5513	6226	6061	24038	23566
9:05	677	356	0	0	677	356	52.0	51.8	6613	6240	7029	6842	26913	26379
10:05	735	388	0	0	735	388	52.2	54.1	6613	7056	7865	7656	29393	28804
11:05	796	419	0	0	796	419	52.0	50.1	6613	7875	8703	8469	31881	31234
12:05	847	444	0	0	847	444	51.8	48.4	6613	8462	9302	9079	33684	32987
13:05	900	471	0	0	900	471	51.7	50.6	6986	8903	9756	9672	35574	34825
14:05	957	502	0	0	957	502	51.9	54.2	7512	9446	10318	10320	37883	37079
15:05	1026	541	0	0	1026	541	52.1	55.9	8283	10194	11108	11086	40985	40115
16:05	1096	580	0	0	1096	580	52.3	54.7	9063	10950	11903	11857	44108	43172
17:05	1157	614	0	0	1157	614	52.4	55.0	9737	11604	12594	12525	46817	45824
18:05	1227	653	0	0	1227	653	52.6	55.3	10504	12349	13375	13285	49891	48835
19:05	1298	693	0	0	1298	693	52.7	55.3	11282	13105	14170	14057	53016	51896
20:05	1370	733	0	0	1370	733	52.9	55.1	12062	13860	14965	14828	56141	54958
21:05	1442	774	0	0	1442	774	53.0	55.9	12841	14615	15761	15599	59268	58023
22:05	1515	815	0	0	1515	815	53.2	55.9	13620	15372	16555	16372	62391	61085
23:05	1587	856	0	0	1587	856	53.3	55.9	14400	16129	17349	17144	65515	64149
0:04	1659.61902	896	0	0	1659.61902	896	53.3	54.7	15180	16888	18144	17918	68640	67215

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.2220001	40	0	0	72.2220001	40	54.7	54.7	781	758	793	774	3125	3066
2:05	145	81	0	0	145	81	55.3	55.8	1560	1513	1587	1548	6244	6126
3:05	217	122	0	0	217	122	55.4	55.8	2339	2270	2380	2321	9362	9187
4:05	288	161	0	0	288	161	55.3	54.9	3092	2999	3147	3068	12378	12148
5:05	349	195	0	0	349	195	55.2	54.6	3753	3640	3821	3724	15028	14749
6:05	419	234	0	0	419	234	55.1	55.0	4505	4370	4587	4470	18042	17708
7:05	492	275	0	0	492	275	55.3	55.9	5285	5126	5381	5242	21162	20769
8:05	565	316	0	0	565	316	55.3	55.6	6065	5882	6174	6013	24284	23831
9:05	637	356	0	0	637	356	55.2	54.4	6848	6644	6972	6788	27426	26910
10:05	707	395	0	0	707	395	55.2	55.3	7597	7371	7733	7529	30426	29848
11:05	779	436	0	0	779	436	55.3	55.8	8386	8137	8537	8310	33589	32946
12:05	852	477	0	0	852	477	55.3	55.8	9175	8905	9339	9090	36749	36040
13:05	924	517	0	0	924	517	55.3	54.7	9963	9669	10141	9870	39910	39134
14:05	997	557	0	0	997	557	55.2	54.6	10752	10434	10944	10650	43070	42228
15:05	1069	597	0	0	1069	597	55.2	54.6	11542	11201	11748	11430	46233	45324
16:05	1134	633	0	0	1134	633	55.2	54.6	12250	11890	12470	12133	49078	48109
17:05	1199	670	0	0	1199	670	55.2	56.0	12961	12580	13192	12836	51928	50901
18:05	1272	711	0	0	1272	711	55.2	55.8	13750	13345	13995	13618	55090	54001
19:05	1345	752	0	0	1345	752	55.3	55.7	14538	14112	14800	14400	58254	57103
20:05	1418	793	0	0	1418	793	55.3	55.5	15328	14877	15604	15182	61414	60201
21:05	1490	833	0	0	1490	833	55.3	55.0	16107	15633	16396	15951	64525	63251
22:05	1563	874	0	0	1563	874	55.3	55.3	16896	16401	17202	16733	67687	66351
23:05	1636	915	0	0	1636	915	55.3	55.4	17684	17167	18004	17514	70850	69451
0:04	1708.83398	956	0	0	1708.83398	956	55.3	55.7	18472	17933	18808	18294	74014	72554

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.7789993	41	0	0	72.7789993	41	55.7	55.7	789	768	805	781	3164	3102
2:05	145	82	0	0	145	82	55.7	55.8	1578	1534	1609	1562	6326	6202
3:05	217	122	0	0	217	122	55.6	55.4	2356	2287	2399	2330	9433	9250
4:05	287	161	0	0	287	161	55.5	55.1	3119	3027	3175	3085	12488	12245
5:05	358	201	0	0	358	201	55.5	55.4	3893	3779	3966	3853	15601	15297
6:05	422	237	0	0	422	237	55.5	55.5	4588	4454	4676	4543	18391	18031
7:05	494	278	0	0	494	278	55.6	56.0	5376	5220	5480	5324	21554	21133
8:05	566	319	0	0	566	319	55.7	56.4	6166	5987	6283	6104	24717	24236
9:05	639	360	0	0	639	360	55.7	55.6	6964	6764	7089	6889	27905	27361
10:05	714	402	0	0	714	402	55.6	55.5	7794	7568	7920	7695	31204	30591
11:05	788	444	0	0	788	444	55.7	55.8	8625	8374	8752	8501	34499	33815
12:05	863	481	0	0	863	481	55.1	48.7	9464	9187	9590	9313	37826	37071
13:05	938	523	0	0	938	523	55.1	55.3	10302	10004	10429	10129	41161	40335
14:05	1014	565	0	0	1014	565	55.1	55.1	11143	10822	11270	10944	44498	43600
15:05	1086	605	0	0	1086	605	55.1	54.7	11936	11591	12072	11724	47669	46705
16:05	1145	638	0	0	1145	638	55.1	55.5	12581	12218	12728	12362	50254	49237
17:05	1210	675	0	0	1210	675	55.1	56.0	13305	12921	13465	13078	53157	52081
18:05	1275	711	0	0	1275	711	55.1	54.5	14030	13623	14203	13794	56057	54922
19:05	1344	749	0	0	1344	749	55.1	54.7	14793	14365	14982	14549	59115	57918
20:05	1415	789	0	0	1415	789	55.1	55.4	15583	15131	15787	15329	62280	61019
21:05	1487	829	0	0	1487	829	55.1	54.8	16373	15899	16592	16110	65444	64119
22:05	1559	869	0	0	1559	869	55.1	54.8	17162	16668	17397	16892	68610	67221
23:05	1632	909	0	0	1632	909	55.0	54.6	17950	17434	18202	17673	71772	70319
0:04	1704.00903	949	0	0	1704.00903	949	55.0	54.7	18738	18200	19006	18452	74937	73420

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.2630005	40	0	0	72.2630005	40	54.7	54.7	787	766	805	780	3161	3097
2:05	145	81	0	0	145	81	55.3	55.9	1575	1529	1609	1560	6322	6197
3:05	217	121	0	0	217	121	55.2	55.0	2350	2281	2398	2327	9427	9242
4:05	281	157	0	0	281	157	55.2	55.3	3045	2957	3107	3016	12216	11978
5:05	347	194	0	0	347	194	55.2	55.0	3769	3658	3844	3731	15113	14819
6:05	420	235	0	0	420	235	55.3	55.9	4557	4424	4648	4510	18267	17914
7:05	492	276	0	0	492	276	55.4	56.0	5346	5189	5453	5290	21428	21016
8:05	565	317	0	0	565	317	55.4	55.7	6134	5953	6258	6069	24588	24115
9:05	637	357	0	0	637	357	55.4	54.7	6922	6718	7061	6849	27752	27215
10:05	709	397	0	0	709	397	55.3	55.0	7712	7483	7865	7630	30915	30314
11:05	781	437	0	0	781	437	55.3	55.2	8502	8250	8671	8411	34078	33413
12:05	852	477	0	0	852	477	55.3	55.3	9294	9018	9477	9193	37241	36511
13:05	923	517	0	0	923	517	55.4	55.9	10084	9786	10283	9974	40406	39611
14:05	993	557	0	0	993	557	55.4	56.0	10873	10553	11088	10754	43569	42709
15:05	1064	597	0	0	1064	597	55.4	55.9	11662	11320	11893	11534	46731	45806
16:05	1135	637	0	0	1135	637	55.4	55.5	12451	12087	12698	12315	49897	48907
17:05	1202	674	0	0	1202	674	55.4	55.1	13188	12803	13451	13044	52851	51801
18:05	1262	708	0	0	1262	708	55.4	55.5	13857	13454	14137	13707	55535	54431
19:05	1331	746	0	0	1331	746	55.4	54.6	14610	14182	14903	14448	58544	57379
20:05	1401	785	0	0	1401	785	55.4	54.8	15386	14934	15693	15213	61653	60425
21:05	1473	826	0	0	1473	826	55.4	56.3	16173	15699	16498	15992	64816	63523
22:05	1546	867	0	0	1546	867	55.4	55.9	16962	16466	17302	16771	67977	66620
23:05	1618	908	0	0	1618	908	55.4	55.8	17752	17235	18108	17552	71143	69722
0:04	1691.04297	949	0	0	1691.04297	949	55.5	55.8	18539	17997	18912	18333	74305	72821

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.461998	41	0	0	72.461998	41	55.9	55.9	787	765	804	780	3161	3098
2:05	144	82	0	0	144	82	56.3	56.6	1574	1531	1608	1559	6321	6196
3:05	216	123	0	0	216	123	56.4	56.5	2362	2299	2413	2339	9485	9298
4:05	288	164	0	0	288	164	56.3	56.2	3150	3063	3218	3120	12646	12397
5:05	360	205	0	0	360	205	56.2	55.7	3938	3825	4022	3900	15807	15496
6:05	428	243	0	0	428	243	56.1	55.4	4673	4540	4772	4628	18756	18388
7:05	488	277	0	0	488	277	56.1	56.3	5316	5164	5428	5266	21335	20918
8:05	560	317	0	0	560	317	55.9	54.8	6103	5930	6233	6046	24491	24015
9:05	632	357	0	0	632	357	55.8	55.0	6891	6695	7037	6824	27653	27116
10:05	704	397	0	0	704	397	55.7	54.9	7679	7458	7840	7604	30813	30214
11:05	776	437	0	0	776	437	55.6	54.7	8468	8225	8642	8385	33977	33316
12:05	848	477	0	0	848	477	55.6	54.9	9256	8991	9445	9164	37138	36414
13:05	920	517	0	0	920	517	55.5	55.0	10045	9759	10250	9945	40300	39512
14:05	992	557	0	0	992	557	55.5	55.0	10832	10524	11054	10726	43462	42610
15:05	1064	597	0	0	1064	597	55.5	55.1	11620	11290	11858	11507	46624	45708
16:05	1136	637	0	0	1136	637	55.4	54.9	12407	12056	12661	12288	49787	48807
17:05	1208	678	0	0	1208	678	55.5	56.1	13195	12821	13466	13070	52950	51907
18:05	1280	718	0	0	1280	718	55.4	54.6	13983	13588	14269	13852	56113	55007
19:05	1348	756	0	0	1348	756	55.4	55.5	14720	14302	15019	14580	59064	57899
20:05	1416	794	0	0	1416	794	55.4	55.5	15456	15017	15770	15309	62016	60792
21:05	1488	835	0	0	1488	835	55.4	55.9	16245	15784	16574	16090	65179	63893
22:05	1561	876	0	0	1561	876	55.5	55.8	17033	16550	17379	16871	68339	66989
23:05	1633	917	0	0	1633	917	55.5	55.8	17818	17316	18182	17652	71499	70086
0:04	1705.60095	958	0	0	1705.60095	958	55.5	56.0	18606	18082	18986	18432	74659	73183

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.6989975	41	0	0	72.6989975	41	55.7	55.7	786	765	804	780	3158	3096
2:05	145	82	0	0	145	82	55.8	55.9	1573	1531	1607	1560	6317	6193
3:05	218	123	0	0	218	123	55.8	55.9	2361	2296	2410	2340	9477	9291
4:05	291	164	0	0	291	164	55.7	55.2	3149	3063	3212	3120	12638	12391
5:05	365	205	0	0	365	205	55.5	54.8	3936	3827	4013	3899	15793	15486
6:05	439	246	0	0	439	246	55.4	54.7	4725	4590	4816	4681	18947	18581
7:05	509	285	0	0	509	285	55.3	55.1	5473	5317	5581	5421	21947	21524
8:05	578	323	0	0	578	323	55.2	54.6	6208	6031	6332	6147	24898	24418
9:05	650	364	0	0	650	364	55.3	56.0	6988	6786	7123	6915	28018	27477
10:05	718	402	0	0	718	402	55.3	55.1	7731	7508	7874	7645	30988	30387
11:05	792	444	0	0	792	444	55.4	56.0	8547	8299	8700	8447	34247	33580
12:05	868	486	0	0	868	486	55.3	55.0	9375	9104	9540	9263	37560	36825
13:05	943	528	0	0	943	528	55.3	54.9	10204	9909	10379	10079	40871	40069
14:05	1019	570	0	0	1019	570	55.3	54.7	11033	10714	11219	10894	44182	43313
15:05	1095	613	0	0	1095	613	55.3	55.8	11860	11519	12059	11709	47491	46554
16:05	1169	654	0	0	1169	654	55.3	54.9	12661	12296	12873	12501	50695	49694
17:05	1243	695	0	0	1243	695	55.2	54.8	13463	13071	13688	13292	53899	52835
18:05	1312	734	0	0	1312	734	55.3	56.0	14211	13797	14449	14032	56888	55766
19:05	1381	773	0	0	1381	773	55.3	55.3	14970	14533	15224	14783	59928	58747
20:05	1454	813	0	0	1454	813	55.3	54.7	15756	15296	16025	15562	63078	61836
21:05	1525	853	0	0	1525	853	55.3	55.4	16528	16047	16813	16326	66173	64871
22:05	1598	894	0	0	1598	894	55.3	55.6	17315	16810	17614	17104	69319	67955
23:05	1672	935	0	0	1672	935	55.3	54.7	18115	17584	18428	17894	72518	71091
0:04	1746.20996	977	0	0	1746.20996	977	55.3	55.9	18916	18360	19243	18683	75718	74229

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	73.8909988	41	0	0	73.8909988	41	54.8	54.8	799	775	815	791	3201	3139
2:05	147	82	0	0	147	82	55.0	55.1	1597	1550	1629	1581	6401	6279
3:05	221	123	0	0	221	123	55.1	55.2	2394	2327	2441	2371	9599	9418
4:05	294	164	0	0	294	164	55.2	55.5	3192	3104	3254	3161	12797	12557
5:05	366	205	0	0	366	205	55.3	55.8	3990	3882	4066	3951	15996	15697
6:05	439	246	0	0	439	246	55.4	55.9	4788	4658	4880	4741	19191	18834
7:05	511	287	0	0	511	287	55.5	55.9	5585	5433	5693	5532	22391	21975
8:05	584	328	0	0	584	328	55.5	55.6	6385	6209	6507	6321	25592	25117
9:05	649	364	0	0	649	364	55.4	54.8	7179	6657	7307	7099	28429	27899
10:05	701	393	0	0	701	393	55.4	55.5	7924	6657	8044	7817	30639	30064
11:05	759	427	0	0	759	427	55.6	57.6	8764	6657	8877	8630	33139	32514
12:05	817	461	0	0	817	461	55.7	58.0	9607	6657	9710	9445	35641	34965
13:05	874	494	0	0	874	494	55.8	56.9	10448	6657	10546	10259	38141	37414
14:05	931	527	0	0	931	527	56.0	57.9	11287	6657	11347	11073	40609	39832
15:05	971	551	0	0	971	551	56.1	58.8	12132	6657	11347	11889	42269	41453
16:05	1013	576	0	0	1013	576	56.2	58.7	12974	6693	11347	12707	43961	43107
17:05	1066	607	0	0	1066	607	56.3	58.0	13772	7255	11477	13482	46238	45340
18:05	1130	644	0	0	1130	644	56.3	57.5	14498	7959	12210	14195	49129	48180
19:05	1201	685	0	0	1201	685	56.4	56.7	15301	8742	13025	14986	52339	51334
20:05	1273	727	0	0	1273	727	56.4	57.8	16105	9521	13838	15777	55548	54486
21:05	1345	769	0	0	1345	769	56.5	57.5	16910	10303	14652	16568	58757	57638
22:05	1417	811	0	0	1417	811	56.5	57.5	17714	11087	15467	17360	61964	60787
23:05	1490	853	0	0	1490	853	56.6	57.2	18517	11866	16281	18150	65172	63936
0:04	1562.17603	895	0	0	1562.17603	895	56.6	57.3	19322	12646	17094	18940	68384	67089

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	72.3259964	41	0	0	72.3259964	41	56.0	56.0	803	782	814	789	3207	3149
2:05	145	82	0	0	145	82	56.0	56.0	1607	1563	1628	1579	6413	6297
3:05	217	124	0	0	217	124	56.3	57.0	2415	2343	2442	2368	9623	9449
4:05	291	166	0	0	291	166	56.3	56.2	3217	3124	3255	3158	12830	12596
5:05	356	203	0	0	356	203	56.4	56.8	3912	3800	3961	3843	15612	15328
6:05	426	243	0	0	426	243	56.4	56.1	4677	4544	4733	4593	18657	18317
7:05	500	285	0	0	500	285	56.3	55.9	5480	5320	5547	5384	21865	21467
8:05	575	328	0	0	575	328	56.4	56.9	6282	6104	6362	6173	25075	24618
9:05	650	371	0	0	650	371	56.4	56.8	7080	6881	7174	6961	28266	27745
10:05	725	413	0	0	725	413	56.3	55.5	7886	7664	8006	7766	31515	30930
11:05	800	455	0	0	800	455	56.2	55.4	8703	8458	8846	8581	34808	34157
12:05	875	497	0	0	875	497	56.2	55.3	9527	9263	9686	9395	38114	37397
13:05	950	539	0	0	950	539	56.1	55.1	10353	10073	10527	10209	41428	40643
14:05	1026	578	0	0	1026	578	55.7	51.0	11182	10881	11368	11021	44746	43892
15:05	1101	615	0	0	1101	615	55.2	48.4	12011	11692	12209	11836	48064	47140
16:05	1162	649	0	0	1162	649	55.2	54.7	12682	12342	12887	12493	50740	49762
17:05	1229	686	0	0	1229	686	55.2	55.0	13405	13046	13620	13205	53631	52594
18:05	1299	725	0	0	1299	725	55.2	55.1	14168	13784	14394	13955	56682	55583
19:05	1373	767	0	0	1373	767	55.2	56.0	14973	14562	15208	14745	59894	58730
20:05	1447	809	0	0	1447	809	55.2	55.8	15778	15343	16022	15535	63109	61880
21:05	1522	851	0	0	1522	851	55.3	55.9	16581	16123	16838	16326	66321	65028
22:05	1596	893	0	0	1596	893	55.3	55.7	17386	16905	17654	17118	69530	68173
23:05	1671	935	0	0	1671	935	55.3	55.6	18189	17686	18468	17908	72742	71321
0:04	1745.52295	977	0	0	1745.52295	977	55.3	55.5	18992	18465	19283	18698	75954	74470

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	74.8690033	42	0	0	74.8690033	42	55.4	55.4	804	781	815	789	3211	3147
2:05	150	84	0	0	150	84	55.5	55.5	1609	1565	1630	1580	6423	6297
3:05	224	126	0	0	224	126	55.5	55.5	2413	2346	2444	2370	9635	9447
4:05	292	164	0	0	292	164	55.5	55.6	3137	3050	3176	3082	12526	12282
5:05	363	204	0	0	363	204	55.5	55.5	3901	3789	3950	3832	15577	15273
6:05	439	246	0	0	439	246	55.4	55.1	4703	4569	4766	4622	18787	18422
7:05	514	288	0	0	514	288	55.4	55.2	5504	5351	5580	5410	21997	21570
8:05	589	330	0	0	589	330	55.4	55.3	6307	6129	6395	6199	25206	24715
9:05	665	373	0	0	665	373	55.4	55.9	7128	6928	7228	7007	28488	27929
10:05	742	416	0	0	742	416	55.4	55.2	7963	7737	8068	7822	31815	31184
11:05	818	458	0	0	818	458	55.3	54.3	8799	8550	8910	8636	35145	34443
12:05	895	500	0	0	895	500	55.2	54.2	9635	9362	9751	9450	38475	37701
13:05	971	542	0	0	971	542	55.2	54.4	10466	10174	10593	10263	41798	40952
14:05	1047	584	0	0	1047	584	55.1	54.4	11300	10979	11434	11075	45121	44202
15:05	1120	624	0	0	1120	624	55.1	54.6	12094	11750	12234	11848	48280	47292
16:05	1186	660	0	0	1186	660	55.0	53.5	12817	12453	12977	12567	51197	50149
17:05	1256	698	0	0	1256	698	54.9	53.9	13580	13194	13761	13326	54269	53156
18:05	1329	738	0	0	1329	738	54.9	54.1	14383	13972	14588	14125	57502	56321
19:05	1402	778	0	0	1402	778	54.8	53.8	15186	14751	15414	14923	60734	59487
20:05	1476	819	0	0	1476	819	54.8	54.8	15988	15530	16241	15721	63963	62650
21:05	1551	860	0	0	1551	860	54.8	54.4	16791	16312	17067	16519	67194	65816
22:05	1626	902	0	0	1626	902	54.8	55.4	17596	17092	17892	17318	70427	68983
23:05	1701	944	0	0	1701	944	54.8	55.2	18399	17872	18717	18117	73662	72153
0:04	1776.00806	986	0	0	1776.00806	986	54.9	55.1	19201	18653	19542	18915	76891	75318

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	75.3069992	42	0	0	75.3069992	42	55.1	55.1	805	784	826	800	3233	3169
2:05	150	84	0	0	150	84	55.2	55.2	1607	1563	1650	1599	6461	6333
3:05	226	126	0	0	226	126	55.2	55.3	2408	2343	2475	2399	9688	9497
4:05	302	169	0	0	302	169	55.3	55.5	3224	3135	3314	3211	12971	12716
5:05	375	210	0	0	375	210	55.4	55.8	3999	3890	4112	3985	16092	15776
6:05	445	249	0	0	445	249	55.3	54.8	4749	4621	4881	4731	19107	18732
7:05	520	291	0	0	520	291	55.3	55.1	5552	5401	5707	5529	22338	21899
8:05	595	332	0	0	595	332	55.1	54.2	6353	6182	6534	6326	25570	25066
9:05	671	374	0	0	671	374	55.1	54.9	7170	6975	7369	7133	28850	28277
10:05	747	416	0	0	747	416	55.0	54.4	8005	7782	8211	7947	32172	31527
11:05	823	458	0	0	823	458	55.0	54.4	8838	8592	9052	8760	35496	34779
12:05	899	500	0	0	899	500	55.0	54.6	9672	9401	9892	9574	38819	38029
13:05	975	542	0	0	975	542	54.9	54.7	10505	10212	10734	10388	42142	41278
14:05	1051	584	0	0	1051	584	54.9	54.4	11339	11024	11576	11202	45465	44528
15:05	1126	625	0	0	1126	625	54.9	54.4	12151	11813	12400	11999	48710	47704
16:05	1199	665	0	0	1199	665	54.8	53.7	12957	12593	13218	12789	51923	50850
17:05	1270	704	0	0	1270	704	54.8	54.9	13733	13349	14008	13552	55032	53891
18:05	1337	741	0	0	1337	741	54.8	54.1	14485	14077	14772	14289	58033	56827
19:05	1407	779	0	0	1407	779	54.7	53.8	15251	14820	15549	15041	61088	59819
20:05	1480	819	0	0	1480	819	54.7	54.5	16042	15588	16352	15817	64248	62913
21:05	1554	860	0	0	1554	860	54.7	54.7	16847	16369	17169	16606	67461	66061
22:05	1628	901	0	0	1628	901	54.7	54.4	17651	17148	17986	17396	70674	69208
23:05	1703	942	0	0	1703	942	54.7	54.4	18455	17930	18803	18186	73886	72355
0:04	1777.073	983	0	0	1777.073	983	54.7	54.4	19258	18711	19620	18975	77098	75502

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	74.3809967	41	0	0	74.3809967	41	54.5	54.5	804	778	816	789	3213	3148
2:05	149	82	0	0	149	82	54.4	54.4	1608	1557	1632	1578	6425	6295
3:05	223	124	0	0	223	124	54.8	55.6	2413	2340	2448	2368	9640	9446
4:05	298	166	0	0	298	166	55.0	55.5	3217	3123	3265	3158	12852	12594
5:05	373	207	0	0	373	207	54.8	54.1	4022	3902	4080	3949	16066	15744
6:05	448	248	0	0	448	248	54.7	54.0	4826	4685	4895	4739	19279	18894
7:05	518	287	0	0	518	287	54.7	55.0	5578	5416	5656	5476	22277	21833
8:05	579	320	0	0	579	320	54.6	53.7	6234	6052	6322	6120	24901	24404
9:05	649	359	0	0	649	359	54.6	54.9	6998	6795	7095	6870	27954	27395
10:05	723	399	0	0	723	399	54.6	53.8	7804	7576	7912	7661	31169	30544
11:05	795	439	0	0	795	439	54.5	54.4	8608	8357	8729	8450	34380	33689
12:05	868	479	0	0	868	479	54.6	54.6	9413	9137	9549	9239	37595	36836
13:05	940	519	0	0	940	519	54.5	54.3	10217	9917	10369	10028	40810	39981
14:05	1013	559	0	0	1013	559	54.5	54.2	11022	10697	11188	10818	44029	43128
15:05	1086	599	0	0	1086	599	54.5	54.6	11825	11478	12007	11606	47248	46275
16:05	1159	639	0	0	1159	639	54.5	54.1	12629	12261	12824	12394	50465	49420
17:05	1232	679	0	0	1232	679	54.4	53.7	13433	13041	13642	13184	53680	52564
18:05	1307	720	0	0	1307	720	54.4	54.2	14237	13821	14459	13974	56895	55710
19:05	1381	761	0	0	1381	761	54.4	54.7	15040	14605	15277	14763	60109	58857
20:05	1455	802	0	0	1455	802	54.5	54.8	15845	15387	16095	15553	63321	62003
21:05	1529	843	0	0	1529	843	54.5	54.5	16650	16168	16913	16343	66534	65150
22:05	1603	884	0	0	1603	884	54.5	54.6	17453	16915	17730	17133	69715	68265
23:05	1674	923	0	0	1674	923	54.5	54.7	18231	17585	18521	17896	72738	71225
0:04	1741.59802	960	0	0	1741.59802	960	54.5	54.0	18980	18230	19282	18633	75656	74083

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	66.5130005	37	0	0	66.5130005	37	55.0	55.0	733	632	747	722	2862	2803
2:05	139	78	0	0	139	78	55.3	55.6	1537	1323	1564	1511	5990	5867
3:05	212	119	0	0	212	119	55.3	55.5	2342	2014	2380	2301	9117	8931
4:05	286	160	0	0	286	160	55.3	55.4	3145	2705	3196	3090	12239	11992
5:05	359	201	0	0	359	201	55.4	55.5	3949	3395	4012	3879	15364	15055
6:05	432	242	0	0	432	242	55.4	55.5	4753	4086	4829	4668	18488	18118
7:05	504	283	0	0	504	283	55.4	55.7	5557	4778	5643	5457	21612	21181
8:05	577	324	0	0	577	324	55.5	55.6	6360	5470	6460	6246	24734	24243
9:05	650	365	0	0	650	365	55.5	55.6	7165	6162	7276	7035	27860	27307
10:05	723	406	0	0	723	406	55.5	55.6	7968	6853	8091	7825	30987	30372
11:05	795	446	0	0	795	446	55.4	54.7	8772	7544	8906	8616	34112	33435
12:05	865	485	0	0	865	485	55.4	55.3	9550	8212	9696	9379	37132	36393
13:05	925	518	0	0	925	518	55.4	54.7	10221	8789	10377	10038	39738	38945
14:05	994	557	0	0	994	557	55.4	55.9	10999	9458	11167	10802	42763	41907
15:05	1064	597	0	0	1064	597	55.4	55.8	11802	10151	11983	11592	45890	44970
16:05	1136	637	0	0	1136	637	55.4	55.5	12606	10844	12798	12383	49018	48033
17:05	1207	677	0	0	1207	677	55.4	55.2	13409	11535	13613	13172	52143	51094
18:05	1279	717	0	0	1279	717	55.4	55.0	14211	12226	14427	13962	55267	54154
19:05	1351	757	0	0	1351	757	55.4	55.1	15015	12916	15244	14751	58393	57216
20:05	1423	797	0	0	1423	797	55.4	55.2	15818	13607	16060	15539	61518	60277
21:05	1495	837	0	0	1495	837	55.3	54.9	16622	14300	16876	16328	64646	63341
22:05	1566	877	0	0	1566	877	55.3	55.1	17425	14991	17692	17117	67768	66399
23:05	1638	917	0	0	1638	917	55.3	55.1	18228	15682	18507	17907	70895	69463
0:04	1710.08398	958	0	0	1710.08398	958	55.4	56.2	19031	16373	19322	18695	74018	72525

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	71.2630005	41	0	0	71.2630005	41	56.9	56.9	790	680	802	777	3072	3011
2:05	137	78	0	0	137	78	56.1	55.2	1526	1313	1551	1501	5934	5819
3:05	208	118	0	0	208	118	56.2	56.4	2305	1982	2341	2264	8952	8779
4:05	280	159	0	0	280	159	56.2	56.2	3112	2674	3157	3054	12076	11844
5:05	352	200	0	0	352	200	56.2	56.3	3918	3367	3973	3843	15198	14907
6:05	424	241	0	0	424	241	56.2	56.3	4724	4060	4789	4633	18321	17970
7:05	496	282	0	0	496	282	56.2	56.0	5529	4752	5605	5424	21447	21036
8:05	568	323	0	0	568	323	56.2	56.0	6333	5444	6420	6213	24575	24103
9:05	642	365	0	0	642	365	56.2	56.6	7145	6183	7245	7013	27775	27239
10:05	718	407	0	0	718	407	56.1	54.8	7985	6999	8086	7828	31114	30508
11:05	793	449	0	0	793	449	55.9	54.7	8826	7817	8927	8643	34450	33773
12:05	869	492	0	0	869	492	55.9	55.9	9666	8632	9767	9458	37787	37037
13:05	944	534	0	0	944	534	55.9	55.3	10493	9435	10596	10259	41068	40247
14:05	1017	574	0	0	1017	574	55.8	54.6	11292	10210	11396	11035	44244	43354
15:05	1077	607	0	0	1077	607	55.7	54.1	11964	10863	12071	11687	46917	45968
16:05	1142	643	0	0	1142	643	55.6	54.7	12687	11565	12803	12394	49803	48791
17:05	1214	683	0	0	1214	683	55.6	55.1	13477	12335	13606	13171	52968	51888
18:05	1287	723	0	0	1287	723	55.5	54.1	14281	13116	14425	13961	56184	55038
19:05	1360	764	0	0	1360	764	55.5	55.2	15083	13898	15243	14750	59399	58188
20:05	1434	805	0	0	1434	805	55.5	54.8	15888	14679	16061	15540	62619	61343
21:05	1509	846	0	0	1509	846	55.4	54.4	16693	15461	16878	16329	65833	64492
22:05	1583	887	0	0	1583	887	55.4	54.2	17499	16241	17694	17119	69048	67642
23:05	1658	928	0	0	1658	928	55.3	54.0	18302	17022	18511	17909	72265	70794
0:04	1733.59998	970	0	0	1733.59998	970	55.3	55.2	19108	17805	19326	18699	75480	73944

 CommonWealth New Bedford Energy LLC Hourly Report														
Date	7/16/2009													
Time	LFG Flow to Engines		LFG Flow to Flare		Total LFG Flow		Cumulative Average Methane Content	Each hour Average Methane Content	Generator 1 Power Output	Generator 2 Power Output	Generator 3 Power Output	Generator 4 Power Output	Gross Power Output	Net Power Output
	KSCF	MMBTU	KSCF	MMBTU	KSCF	MMBTU	%	%	Hours	Hours	Hours	Hours	kW	kW
0:05	0	0	0	0	0	0			0	0	0	0	0	0
1:05	75.0960007	42	0	0	75.0960007	42	55.3	55.3	805	780	816	792	3213	3148
2:05	145	81	0	0	145	81	55.1	54.9	1557	1511	1578	1531	6213	6088
3:05	213	118	0	0	213	118	54.7	54.0	2281	2215	2311	2243	9107	8925
4:05	288	159	0	0	288	159	54.5	53.8	3085	2995	3127	3034	12320	12073
5:05	363	200	0	0	363	200	54.4	53.9	3888	3773	3942	3824	15533	15222
6:05	439	241	0	0	439	241	54.3	53.7	4691	4555	4757	4615	18746	18372
7:05	514	283	0	0	514	283	54.4	54.9	5494	5338	5574	5405	21961	21523
8:05	590	325	0	0	590	325	54.4	54.9	6298	6119	6389	6196	25174	24672
9:05	665	366	0	0	665	366	54.4	53.9	7103	6899	7206	6987	28388	27820
10:05	740	407	0	0	740	407	54.3	54.0	7909	7679	8022	7778	31602	30965
11:05	815	448	0	0	815	448	54.3	54.1	8719	8468	8847	8576	34849	34140
12:05	890	489	0	0	890	489	54.3	54.2	9538	9264	9681	9384	38129	37347
13:05	965	530	0	0	965	530	54.3	53.8	10368	10071	10525	10199	41446	40589
14:05	1037	568	0	0	1037	568	54.1	52.6	11156	10836	11327	10972	44600	43667
15:05	1100	602	0	0	1100	602	54.1	53.2	11849	11506	12031	11650	47368	46368
16:05	1167	638	0	0	1167	638	54.0	52.9	12582	12218	12779	12371	50308	49239
17:05	1239	677	0	0	1239	677	54.0	53.7	13362	12975	13584	13147	53452	52312
18:05	1313	717	0	0	1313	717	54.0	53.6	14155	13748	14403	13936	56651	55440
19:05	1387	757	0	0	1387	757	53.9	53.4	14950	14519	15222	14726	59847	58568
20:05	1461	797	0	0	1461	797	53.9	53.0	15743	15292	16039	15515	63042	61698
21:05	1536	837	0	0	1536	837	53.8	52.8	16535	16064	16857	16305	66234	64824
22:05	1611	878	0	0	1611	878	53.8	54.0	17329	16837	17676	17095	69426	67951
23:05	1686	919	0	0	1686	919	53.8	53.9	18123	17608	18495	17885	72622	71082
0:04	1761	960	0	0	1761	960	53.9	54.3	18917	18382	19310	18675	75819	74214